

1 Q. With respect to MF1320, this report indicates firm generation of 515 MWc, not 824
2 MWc at Muskrat Falls. Why?

3

4

5 A. The 515 MWc rating is the MW-continuous rating and is a means of expressing the
6 firm capability based on water availability. The 824 MW value refers to the
7 nameplate capacity rating of the plant, comprised of four units at 206 MW each.
8 (MF1320, as of the date of this response, July 26, 2011, has not been disclosed to
9 the public as it may contain commercially sensitive or confidential information.
10 Some or all of this report may be released at a later date.)