

1    Q.    What was the HVDC design voltage related to the capital costs used in the CPW calculation?

2

3

4    A.    The HVdc design voltage used in the current capital cost estimate is 320kV. Please  
5        refer to the response to MHI-Nalcor-19, MHI-Nalcor-21, and Exhibit CE-32.