

1 Q. Please provide a project description and schedule for the systems improvements  
2 outlined in Section 2.4.3 of document DC1210\_filed.pdf “HVDC Sensitivity  
3 Studies”, July 2010 required to mitigate the 3 phase fault at Bay d’Espoir. The  
4 system improvements noted are a cross tripping/over frequency protection  
5 system, a new 230 kV circuit between Bay d’Espoir and Western Avalon, plus two  
6 new 230 kV circuits between Bay d’Espoir and Sunnyside.

7  
8  
9 A. Stability studies of the existing Island system under peak load conditions  
10 demonstrate that a 230 kV three phase fault at Bay d’Espoir with tripping of a  
11 230 kV transmission line between Bay d’Espoir and Sunnyside will result in  
12 angular instability. In other words, the system does not recover from the fault  
13 and an outage will occur. To the extent that the existing AC system cannot  
14 survive a three phase fault at Bay d’Espoir during peak load conditions, the  
15 DC1210 – “HVDC Sensitivity Studies” contemplated an Island system with an  
16 HVdc interconnection having performance similar to the existing Isolated Island  
17 Scenario. This was outlined in section 2 of the study, last paragraph of page 2-1  
18 which states:

19  
20 ...It is also based on the assumption that the three-phase  
21 Bay d’Espoir fault will not be considered when determining  
22 the synchronous condenser requirements and system  
23 upgrades. This fault is not considered in this sensitivity  
24 analysis as the intent is to determine the system additions  
25 for the HVdc integration with system performance  
26 comparable to that of the existing system.

27

1 For clarification, Section 2.4.3 of DC1210 – “HVDC Sensitivity Studies” does not  
2 state that two new 230 kV circuits between Bay d’Espoir and Sunnyside are  
3 required to mitigate a 3 phase fault at Bay d’Espoir.

4

5 Section 2.4.3 states at page 2-5:

6 However, if the new 230 kV circuit between Bay d’Espoir  
7 and Western Avalon is built and if this new circuit plus the  
8 two circuits between Bay d’Espoir and Sunnyside are 50%  
9 series compensated, AND if 2x300 MVAR high inertia  
10 Toshiba synchronous condensers are in service at Soldiers  
11 Pond (which means 3x300 MVAR installed to account for  
12 maintenance outages), the system is able to recover from  
13 a three-phase fault at Bay d’Espoir within criteria.

14

15 The “two circuits between Bay d’Espoir and Sunnyside” refer to the two existing  
16 circuits between these locations (i.e. TL202 and TL206).

17

18 The upgrades necessary to recover from a three phase fault at Bay d’Espoir are:

19

20 1) A new 230 kV circuit between Bay d’Espoir and Western Avalon

21 This circuit is common to both the Interconnected and Isolated scenarios, and is  
22 included in NL Hydro’s 2012 capital budget submission. Construction of the 230  
23 kV transmission line between Bay d’Espoir and Western Avalon has a five year  
24 completion schedule and includes:

25

- Addition of three 230 kV circuit breaker bays at Bay d’Espoir Terminal  
26 Station #2 to complete the breaker and one half arrangement on legs 1  
27 and 2 with the new line termination on leg 3;

- 1           • Construction of 188 km of overhead 230 kV transmission line consisting
- 2           of 795 kcmil ACSR “DRAKE” conductor on steel towers with overhead
- 3           shield wire along the entire length; and
- 4           • Addition of a four 230 kV GIS circuit breaker ring bus arrangement at
- 5           Western Avalon.

6

7           2) Three 300 MVAR high inertia synchronous condensers at Soldier’s Pond.

8           Three 300 MVAR units are currently in the Basis of Design for the Labrador-

9           Island Transmission Link, but quantities and final rating will be determined

10          during detailed engineering. The applicable design criteria will be to ensure

11          that the Island system remains stable for faults under which the Island

12          system remains stable today.

13

14          3) 50% series compensation of the two existing and one new transmission line

15          (from (1)) between Bay d’Espoir and Sunnyside. This work is neither

16          budgeted nor scheduled. Nalcor has not opted to install the series

17          compensation on each of the three 230 kV transmission lines between Bay

18          d’Espoir and the eastern portion of the system. Given the extremely low

19          probability of the event, the increase in cost for series compensation in the

20          HVdc scenario was deemed to unnecessarily penalize the Interconnected

21          Scenario over the Continued Isolated Scenario from a performance

22          perspective.

23

24          Similar to the existing Island System, there are load scenarios in the

25          interconnected case where the system will survive the 230 kV bus fault at Bay

26          d’Espoir. Preliminary analysis of the Interconnected System with a simplified

27          model of the Labrador – Island HVdc Link reveals that the Island System will

1            remain stable following a three phase fault at Bay d'Espoir with the 230 kV  
2            transmission line between Bay d'Espoir and Western Avalon added and all  
3            synchronous condensers in service during the spring/fall intermediate load  
4            levels.  
5