MHI-Nalcor-86 Muskrat Falls Review

Page 1 of 1

1	Q.	Are any further system reinforcements planned or required to mitigate a 3 phase
2		fault at Bay d'Espoir?
3		
4		
5	A.	No further system reinforcements are planned to mitigate a three phase fault at
6		Bay d'Espoir.