

- 1 Q. Please provide all historical demand (MW) information for the non-coincident utility
2 peak demand, non-coincident industrial peak demand, coincident Island peak
3 demand, NLH transmission losses peak demand and coincident NLH peak demand.
4
5
6 A. Please refer to the table on page 2. Please note that industrial demand information
7 is only available from 1990 onwards and peak loss information is only available from
8 2000 onwards.

NL Island Interconnected System - Historical Demand Information (MW)

	NP Peak Demand	NLH Rural Peak Demand	Industrial Demand ⁽¹⁾	Estimated NLH Peak Demand Transmission	Island Interconnected System Peak Demand	NLH System Peak Demand
1967	156.3	-	-	-	-	-
1968	172.9	-	-	-	-	-
1969	188.8	-	-	-	-	-
1970	223.7	-	-	-	-	-
1971	267.5	-	-	-	-	-
1972	316.1	-	-	-	-	-
1973	336.3	-	-	-	-	-
1974	408.4	-	-	-	-	538
1975	488.2	-	-	-	-	527
1976	585.4	-	-	-	-	681
1977	584.2	-	-	-	-	679
1978	639.9	-	-	-	939	718
1979	664.1	-	-	-	997	821
1980	662.7	-	-	-	1030	836
1981	716.2	-	-	-	978	834
1982	731.8	-	-	-	1083	880
1983	742.6	49.2	-	-	1251	1040
1984	833.8	45.6	-	-	1186	1013
1985	825.6	48.4	-	-	1180	1009
1986	847.8	43.9	-	-	1291	1084
1987	886.0	54.6	-	-	1204	1065
1988	957.3	58.9	-	-	1435	1232
1989	1068.7	69.9	-	-	1383	1230
1990	1041.4	70.3	356.2	-	1500	1316
1991	1087.7	70.8	355.4	-	1488	1281
1992	1014.9	68.6	357.7	-	1457	1303
1993	1085.9	69.0	356.0	-	1452	1288
1994	1019.3	67.8	351.9	-	1492	1305
1995	1104.2	68.5	346.0	-	1429	1250
1996	1060.4	81.2	348.0	-	1563	1318
1997	1049.0	76.9	357.8	-	1418	1229
1998	1022.8	80.2	364.3	-	1491	1295
1999	995.7	84.8	358.3	-	1465	1265
2000	1025.5	80.1	358.3	39.1	1443	1240
2001	1175.9	82.3	359.5	43.5	1435	1262
2002	1118.3	81.3	363.7	51.4	1592	1403
2003	1099.5	87.3	364.5	40.5	1595	1402
2004	1167.3	82.2	371.2	44.1	1598	1405
2005	1130.9	80.2	366.0	36.9	1595	1361
2006	1142.3	81.4	293.0	48.6	1517	1310
2007	1180.5	81.5	291.0	46.4	1540	1323
2008	1218.6	88.9	280.0	40.9	1520	1323
2009	1205.8	81.7	197.5	39.2	1601	1390

Notes: (1) Industrial demand is the sum of customer owned capacity and industrial firm power requirement from NLH.