

1 Q. On p. 13 of Exhibit 101, key finding 38 states: "*Relative to the Isolated Island*  
2 *alternative, the Interconnected Island alternative is also expected to provide similar*  
3 *levels of security and reliability, significantly reduced GHG emissions and*  
4 *significantly less risk and uncertainty.*" Please describe in detail how these "*similar*  
5 *levels of security and reliability*" were determined for both options. Was a  
6 quantitative assessment of each option completed for comparative purposes? If so,  
7 please provide a copy of the assessment.

8

9 A. The Technical Note: Labrador – Island HVdc Link and Island Interconnected System  
10 Reliability filed as Exhibit 106 provides the analysis of the levels of security and  
11 reliability for each option. Navigant was provided with a draft of the report for  
12 their review.

13

14 The Nalcor analysis to determine the level of exposure and unserved energy as a  
15 result of a transmission failure begins with the hourly load data for the year in  
16 question. A comparison is made between the hourly load in MW and the available  
17 generating capacity to meet the load during the hour. For hours in which the  
18 available generating capacity exceeds the load there is no exposure and no  
19 unserved energy. For any hour in which the load exceeds the available generating  
20 capacity there is an hour of exposure and the difference between the available  
21 capacity and the load is taken as the MWh of unserved energy for that hour. The  
22 calculation is performed for each hour of the year. Next, a 14 day or 336 hour  
23 sliding window is used to determine the two week window having the largest total  
24 hours of exposure and unserved energy. This two week window is deemed to be  
25 the "worst case" two week window by Nalcor as it captures the maximum unserved  
26 energy for the two week repair period. In other words, the "worst case" gives the

1 maximum unserved energy should the transmission line failure occur at the most  
2 inopportune time.

3  
4 For the Isolated Island option the simultaneous loss of TL202 and TL206 connecting  
5 the Bay d'Espoir Generating Station and other hydroelectric resources to the Avalon  
6 Peninsula is viewed as the most significant transmission failure for the Isolated  
7 Island option. With both TL202 and TL206 in a common corridor and having the  
8 same design loading, failure of both lines can be expected for a storm resulting in  
9 loads that exceed the design load. Loss of both transmission lines, for all intents  
10 and purposes, isolates the Avalon Peninsula from the rest of the grid.

11  
12 For the Interconnected Island option the failure of the overhead HVdc transmission  
13 line is viewed as the most significant transmission line failure as it removes a  
14 nominal 900 MW of capacity to the Island with limited on Island resources to supply  
15 the load with Holyrood thermal generation unavailable.

16  
17 Table 5 of Exhibit 106 provides the results of the analysis. In summary it indicates  
18 that between 2017 and 2027 the Interconnected Island option has less unserved  
19 energy for the worst case two week outage window than the existing system today.  
20 In terms of level of exposure the availability values for the Isolated Island and  
21 Interconnected Island are very similar in the long term with both options providing  
22 energy availability values in excess of 99% and unsupplied energy values less than  
23 1% of the annual energy forecast in any year.