

1 Q. The response to PUB-Nalcor-61 states in lines 14-16 that it is not “currently” the
2 case that Hydro must comply with NERC reliability guidelines. What consideration
3 has been given as to whether such compliance will be required in the future?
4

5
6 A. Nalcor expects that compliance with NERC guidelines and standards will be required
7 for its new facilities in Labrador.
8

9 Since the Muskrat Falls generating facility, the AC transmission system between
10 Muskrat Falls and Churchill Falls, and the Labrador HVdc terminal are
11 interconnected to the North American grid via the AC interconnection between
12 Churchill Falls and the Hydro Quebec TransEnergie system, Nalcor and its EPCM
13 consultant will apply all relevant NERC reliability guidelines to the design,
14 construction, and operation of Nalcor’s new facilities. These requirements will be
15 coordinated with Quebec so that disturbances originating from Nalcor’s new
16 facilities do not cause problems in Quebec.
17

18 The new Nalcor facilities in Labrador must also ensure compliance with NERC
19 criteria for contingencies specified in the criteria originating from NL Hydro
20 facilities, including the Island Interconnected System and NL Hydro facilities in
21 Labrador. The HVdc interconnection between Labrador and Newfoundland
22 simplifies this task, as the HVdc link provides a high degree of control over the
23 interconnection between the two systems for many events. In effect, the
24 Newfoundland electricity system is ‘firewalled’ from Labrador and Nova Scotia
25 systems by HVdc interconnects, thus preventing events on the Newfoundland
26 system from cascading into Labrador and Nova Scotia, respectively.

1 In so far as the application of NERC reliability criteria on NL Hydro system is
2 concerned, NL Hydro continues to be guided by its existing standards and practices.
3 Any changes to these practices will be considered as required if and when NERC
4 reliability criteria are applied to NL Hydro's system.