

1 Q. Pg. 14, footnote 7 of Exhibit 106, refers to continuous monopolar rating of 552.6
2 MW. Is this correct? If not, the figure of 702.6 MW is also incorrect.

3

4

5 A. Footnote 7 is incorrect. The correct value for the continuous monopole rating is
6 530.6 MW, as stated in the last paragraph on page 14 of Exhibit 106. Together with
7 three combustion turbines, the available capacity is 680.6 MW, which exceeds the
8 645.7 MW peak deliveries to the Island Interconnected System.

9

10 Footnote 7 should read:

11

12 *The continuous monopolar rating of 530.6 MW plus start up of three 50 MW*
13 *combustion turbines (Stephenville, Hardwoods and the new unit scheduled for 2014)*
14 *results in a capacity of 680.6 MW, which exceeds the 645.7 MW Island*
15 *Interconnected System block thereby eliminating any shortfall.*