

- 1 Q. With reference to pg. 23, Table 5 of Exhibit 106, do the results for Island
2 Interconnected scenario (with and without Maritime Link) include the 230 kV
3 transmission line from Bay d’Espoir to Western Avalon being built before 2017?
4 (Footnote 1 is missing from both these scenarios). If not, why not?
5
6
7 A. The Island Interconnected scenario (with or without the Maritime Link) assumes the
8 new 230 kV transmission line is built from Bay d’Espoir to Western Avalon before
9 2017.