

- 1 Q. Does the current proposed criteria as of September 2011 require that the Labrador-  
2 Island HVdc system be able to withstand a three-phase fault at Bay d’Espoir?  
3  
4
- 5 A. The Island Interconnected System, operating as either the Isolated Island  
6 alternative or the Interconnected Island alternative with the Labrador – Island  
7 Transmission Link, will not be expected to withstand a three-phase fault at Bay  
8 d’Espoir.