

1 Q. Further to PUB-Nalcor-29, are these costs included in the CPW analysis?

2

3

4 A. The cost for the 230 kV transmission line from Bay d’Espoir to Western Avalon was
5 not included in the CPW analysis as it is a common cost to both the continued
6 isolated and interconnected scenarios.

7

8 The cost for the 50% series compensation of three 230 kV transmission lines was
9 not included in the CPW analysis in order to provide comparable system
10 performance for a three-phase fault on the 230 kV system east of Bay d’Espoir in
11 both the Interconnected Island and Isolated Island alternatives.

12

13 The cost for 3 x 300 MVAR high inertia synchronous condensers at Soldiers Pond
14 converter station was included in the CPW analysis as part of the Labrador-Island
15 HVdc Link cost.