

1 Q. Why was it necessary to replace in the year all of the waterwalls that were
2 replaced.

3

4

5 A. Without complete removal of the damaged waterwall sections, failures of the
6 same nature were highly possible and would most likely affect system
7 stability and reliability.