

1   **Re Page B-36:**

2   Q.    With reference to the anticipated Provincial Energy Plan, and/or Hydro  
3       strategic planning for future generation, is one of the options still being  
4       contemplated the conversion of the Holyrood plant, or its replacement, to  
5       natural gas generation? If the natural gas option is chosen, is it probable that  
6       it will be implemented within the next 20 years? If the natural gas option is  
7       implemented, what will be the utility of the current configuration of the tank  
8       farm (even if upgraded as proposed by this project)?

9

10

11   A.    The conversion of the Holyrood plant to natural gas generation is not being  
12       contemplated as a potential generation project in Hydro's current 20-year  
13       planning horizon.