

1 **Re Page B-36:**

2 Q. Identify specifically from Section 4.2.2 of the report at Section H Tab 2 what
3 work is intended to be performed under this project and confirm that no work
4 other than that outlined in this section is being undertaken.

5

6

7 A. Section 4.2.2 (Life Extension Recommendations) outlines the major items to
8 be addressed during the 4-year Upgrade Project. Based on the assessment
9 completed by SGE Acres, it is anticipated that the scope of work will include:

- 10 - upgrade roof plate;
11 - roof and shell coating;
12 - upgrade roof rafters;
13 - floor scan (including tank cleaning);
14 - floor coating;
15 - installation of scaffold/platform system (including fall protection system);
16 and
17 - inspections

18

19 It should be noted that the actual scope of work and extent of repairs will
20 depend on the outcome of inspections, as recommended in the SGE Acres
21 report.