

1   **Re Page B-14:**

2   Q.    Explain what is meant by campsite loading.

3

4

5   A.    The diesel generators at Burnt Dam are used to provide electrical energy for  
6       the spillway gate operation and also for the personnel accommodations unit  
7       at the site.

8

9       The operating experience statement in the project explanation uses the term  
10      ‘campsite loading’ which really means the same as the ‘domestic load’. This  
11      is the load required for the personnel accommodations units and storage  
12      sheds.

13

14      During the winter months, the 75kW diesel is used solely for spillway gate  
15      operation, because of the gate heater loads. During the winter, the campsite  
16      (or domestic load) must be provided by the 25 kW diesel.

17

18      During the summer, when the gate heaters are not required, the 40kW diesel  
19      can supply enough energy to operate the gates as well as supply the  
20      campsite (or domestic) load.