

1   **Re Page B-14:**

2   Q.     Why is the set being upgraded from a 40kW to 50kW?

3

4

5   A.     A 40 KW 'exact size' replacement unit is no longer currently available on the  
6           market. The closest available size is a 45 kW unit. In reviewing the budget  
7           cost estimates for this replacement it was determined that there is minimal  
8           cost increase between a 45 kW unit and a 50 kW unit. The 50 KW unit would  
9           be large enough to operate the spillway gate (without the heaters) whereas  
10          the 45kW and 25 kW would not be. For the minimal increase in cost it was  
11          decided to propose the 50 kW size to add the extra measure of reliability to  
12          the system.