

1   **Re Page B-14:**

2   Q.    Would any diesel generator retired within the last two years or scheduled for  
3       retirement within the next two years be capable of performing the functions  
4       intended to be performed by this generator?

5

6

7   A.    The diesel generators in service at Burnt Spillway are not unique and are  
8       similar to other diesel generators on the Hydro system in that they are prime  
9       power units designed to operate in isolated mode or in parallel with other  
10      diesels.

11

12       If any diesel generator was retired or scheduled to be retired, it would be  
13       because it had reached the end of its useful life as defined by the number of  
14       overhauls and operating hours. Therefore, it would not be capable of  
15       performing the functions required at Burnt Dam.