

1 **Re Page B-192:**

2 Q. Provide a complete description of the existing public address system,
3 number and location of speakers, number and location of devices by which
4 broadcasts may be made and indicate whether any personal pagers or other
5 mobile devices are part of the system.

6
7
8 A. The existing public address system was installed when the Holyrood
9 Generating Station was built, and consists of Gai-Tronics wall mount and
10 desk station phones (with integrated speaker), ceiling mount speakers, and
11 wall mount loudspeaker horns. There are 62 phones and 76 speakers in the
12 generator area, maintenance area and water treatment lab; 29 phones and
13 four speakers in the administrative office area; one phone in the Engineering
14 trailer; one phone and one speaker in each of the two pump houses; two
15 phones and two speakers in the waste water treatment plant; one phone and
16 one speaker in the water treatment basin; one external speaker at the
17 chemical storage building; one external phone and one speaker at the gas
18 storage building; three phones and two speakers at the maintenance
19 warehouse; one phone at the gas turbine building; one external phone and
20 one speaker at the tank farm; and one phone and speaker at the guard
21 house. The existing public address system does not utilize any personal
22 pagers or other mobile communication devices.