

1 **Re Page B-192:**

2 Q. Provide a complete description of the proposed new system including
3 number and location of speakers, number and location of devices by which
4 broadcasts may be made and indicating whether any personal pagers or
5 other mobile devices are part of the system.

6

7

8 A. The new paging system will replace all wall mount and desk station phones,
9 ceiling mount speakers and wall mount horns as described in the response to
10 IC50-NLH. In addition, areas of additional coverage have been identified by
11 plant personnel where the existing system provides poor coverage. Specific
12 numbers of devices are unavailable at this time since these will be
13 determined at the time of final system design and will be dependent on the
14 specific design and capabilities of the successful bidder's equipment.
15 Additional coverage will be provided within the generating station itself, as
16 well as the contractor trailer park, powerhouse perimeter, landfill, warehouse,
17 pipe shop, tank farm, jetty security building, jetty wharf building, and chemical
18 storage building. Personal pagers or other mobile devices are not part of the
19 public address system.