

1 **Re: Page B-192, Public Address System, \$1,139,100**

2 Q. What is considered to be the length of useful life of the existing system,
3 according to the manufacturer?

4

5

6 A. The manufacturer has informed Hydro that it considers the useful life of the
7 system in an environment such as that present at Holyrood Generating
8 Station to be in the range of 25 to 30 years.