

1 **Re: Page B-192, Public Address System, \$1,139,100**

2 Q. Please provide a cost benefit analysis of all options that were considered in
3 putting forward this project.

4

5

6 A. A cost/benefit analysis was not performed at this time. There are no other
7 viable options for supplying this service at the Holyrood Generating Station.
8 VHF pagers and portable radios were considered but were rejected due to
9 technical considerations which rendered alternatives unsuitable. See
10 responses to IC50-NLH – IC53-NLH for details. The tender for the supply of
11 the system will be structured to ensure that the least cost solution which
12 meets the functional requirements of the paging system will be selected.