

1 **Re: Page B-216, Install Computer Room Inergen Fire Protection System,**
2 **\$115,700**

3 Q. How long has Hydro been using the current pre-action sprinkler system to
4 protect the Information Systems Computer Room from fire?

5

6

7 A. The current pre-action sprinkler system was installed with the construction of
8 Hydro Place in 1990 and has been in service continuously since that time.