

1 **Re: Page B-25, Upgrade Intake #4 Gate Controls, \$115,500**

2 Q. What is the age of the controls currently being used?

3

4

5 A. The intake gate control system that is currently in place on Bay D'Espoir
6 intake gate #4 is the original system that was installed and commissioned in
7 December of 1977.