

1 **Re: Page B-56, Stack Breeching Study \$115,100**

2 Q. When was the breeching installed in each of the stacks?

3

4

5 A. The Units 1 and 2 breeching was originally installed in 1969 with the
6 construction of the facility. Unit 3 breeching was installed in 1979 when the
7 plant was expanded to increase capacity. Various repairs had to be
8 undertaken in the following years until complete new breechings were
9 installed for all three units between 1989 and 1991.