

1   **Re: Page B89, Replace Line Camp 98 – TL-228**

2   Q.   Please explain why there was “maintenance neglect” of this building if it is  
3       the most critical of the 15 survival buildings.

4

5

6   A.   The transmission line ground maintenance crew performed regular  
7       preventative maintenance on all survival buildings. This crew was eliminated  
8       more than ten years ago to reduce staffing levels at Hydro, as a cost  
9       reduction measure.