

1 **Re: Page B-92, Upgrade Line TL-212, \$463,700**

2 Q. Please provide a record of outages caused by low clearances over the period
3 from 2002-2007F.

4

5

6 A. There were two outages during this period caused by low clearances -
7 March 2, 2005 and December 29, 2005.