

1 **Re: Page B-92, Upgrade Line TL-212, \$463,700**

2 Q. Did the line meet the standards of the day at the time it was constructed?

3

4

5 A. Yes. The line met the design of the day. Experience with this line since it
6 was placed in service has indicated that actual ice loads encountered are far
7 greater than predicted by the standards which existed when the line was
8 designed.