

Newfoundland & Labrador Hydro



Hydro Plant Corrosion / Fouling Study 2002

Hinds Lake Generating Station

SERVICE WATER SYSTEM

Newfoundland & Labrador Hydro



Hinds Lake Generating Station

SERVICE WATER SYSTEM

Piping
Strainer
Supply Pump
Control Valves
Heat Exchangers

Prepared for: Newfoundland & Labrador Hydro
Hydro Generation

Submitted to: John Mallam, P.Eng
Mechanical Supervising Engineer

Submitted by: Shane White, B.Eng
Mechanical Engineer

Date: November 25, 2001

SUMMARY

It was determined that a hydro plant cooling water study was needed to determine the most effective solution to the cooling water fouling that is plaguing our hydro plants. The methodology for this study was planned out to include the following: prioritize plants and systems for review, review drawings, inspect coolers for extent of fouling, calculate actual flow rates, and determine the best solution for each hydro plant.

It was determined that Upper Salmon, Cat Arm, and Hinds Lake had the most problems with regards to cooling water.

In order to first determine which plant had the worse problems an in-depth analysis of each plants cooling water system had to be undertaken. Next a complete review of the plants work history had to be done. This was accomplished by reviewing all work orders related to the plants cooling water system in the J.D.Edwards. From this it can be determined which plant had the worse problems.

What was needed next was a review of how the plant's cooling water system has been operating. This was accomplished by using the Trend Monitoring Program that I designed. From the trend graphs one could see just how efficiently the plant has been operating and how the work on the cooling water system affects it. This gives us a time frame for cleaning components of the system so that we could set up a maintenance program for the cooling water system.

A cost analysis was done to determine the amount of money being spent on the current cooling water system in each plant. Also a cost analysis for replacing the piping was done using RSMeans Mechanical Cost Data for each plant.

Several solutions were presented to combat the fouling problem and they are; chemical cleaning of the system, replace the piping with corrosion resistant pipe, add a corrosion inhibitor to the water, use organic filters, or convert to a closed cooling water system.

From these solutions four were chosen for further investigation and they are; replace piping with corrosion resistant pipe, add a corrosion inhibitor to the water, convert the system to a closed system, and continue to operate as we have. Each solution was researched and a Net Present Worth calculation was done to determine the most economical solution. It was determine that replacing the piping with corrosion resistant pipe is the best solution, considering that the pipe has to be replaced in the next few years the other solutions did not seem economical.

The NPW of this solution for Hinds Lake is \$218,064 over the pipe life of 20 years. The NPW of continuing to operate as we have is \$152,494 but this does not include replacing the existing piping, which labour alone is \$52,000. The closed loop solution has a NPW of \$213,427 but the existing piping has to be replaced for this solution to be affective. The closed loop solution can always be added on after the piping is replaced.

TABLE OF CONTENTS

TABLE OF CONTENTS.....	1
SERVICE WATER SYSTEM.....	3
General Information.....	3
HISTORY OF SERVICE WATER SYSTEM	8
General Information.....	8
Review of Trend Monitoring Readings	9
Test Samples	23
Composition.....	23
Sample #1.....	23
Cost Analysis	25
Maintenance Cost for Cleaning	25
Total Cost to Clean SAC.....	26
Total Cost to Clean SAC Piping.....	26
Total Cost to Clean Lower Generator Coolers	27
Total Cost to Clean Lower Generator Cooler Piping.....	27
Total Cost to Clean Upper Generator Cooler	28
Total Cost to Clean Upper Generator Cooler Piping.....	28
ALTERNATIVE SOLUTIONS	29
General Information.....	29
Mechanical Cleaning	29
Chemical Cleaning.....	30
Replace Piping	30
Chemical Treatment of the Water.....	30
Flushing Maintenance Program	31
Organic Filters	31
Closed System Operation.....	31
VIAIBLE SOLUTIONS.....	32
Continue to Maintain Current Operation	32
Replace Piping Inside of Generator Housing.....	34
SAC Water Piping.....	34
Upper Generator Bearing Cooler Water Piping.....	35
Lower Generator Bearing Cooler Water Piping	37
Replace Piping Outside of Generator Housing.....	39
Inlet Header Piping	39
Discharge Header Piping	41
Closed System Operation.....	45
Heat Exchanger Selection.....	45
Pump Selection	45
Chemical Injection	48
CONCLUSIONS AND RECOMMENDATIONS	50

Appendix A

Flow Diagrams

Appendix B

BetzDearborn Water & Pipe Analysis

Appendix C

BetzDearborn Chemical Injection Proposal

Appendix D

NPW Analysis

Appendix E

RSMeans Mechanical Cost Data

Appendix F

AutoCAD Drawing for Lower Generator Bearing Cooler Piping

Appendix G

Design Flow Solution Analysis

Appendix H

Recirculation Pump Analysis

The generator surface air coolers are supplied by a common six inch header piped directly from discharge of the turbine/generator cooling water pump to the generator housing. The six inch discharge header has tap-ins for the generator bearing oil coolers, turbine bearing oil coolers and the turbine shaft seal. After the six inch discharge header penetrates the generator housing it branches in two four inch headers. One header serves coolers #1 & #4 while the second header serves coolers #2 & #3.

Surface air coolers are supplied with normally open isolation gate valves on both supply and return; air vent line complete with in-line water flow indicator and normally open gate valve; also drain line with normally closed gate valve.

Generator surface air cooler return lines are also divided into two four inch headers. One four inch header serves coolers #3 & #4 while the other four inch header serves coolers #1 & #2. Each return line has a Barton flow orifice and globe valve installed on the downstream generator face. Each Barton flow meter is piped to a flow panel located on column D outside the generator housing. The two four inch discharge headers join together into a six inch header and run through a trench along the upstream wall of the pump room where a six inch isolation valve and check valve are also located. From there the six inch discharge line is embedded into the pump room floor and travels directly to the tailrace surge chamber.

Generator upper guide bearing oil cooler is supplied by a two inch pipe, which taps into the six inch main supply header that feeds the surface air coolers. A normally open isolation valve is installed on the down streamside of the generator face directly above the catwalk.

The six generator lower guide bearing and thrust bearing coolers are supplied by a three inch pipe which also taps into the six inch main supply header that feeds the surface air coolers. Upon entering the generator housing the three inch pipe reduces to a two and half inch header, which feeds all six coolers. The supply and discharge pipes that branch from the two and half inch header and feed directly into the coolers are only two inches. There is a total of six coolers all equipped with normally open isolation valves on both the supply and discharge lines. Main isolation valve #W35V1 normally open is located on the downstream generator face.

The generator upper guide bearing oil cooler return line has a Barton flow orifice and a globe valve installed on the downstream generator face. The Barton flow orifice is piped to a flow meter panel located on column D outside the generator housing. The generator upper guide bearing oil cooler return line connects into a common four inch header with return lines from generator lower guide and turbine bearing cooler return. These returns travel through a trench in the floor and travel along the up stream wall of the pump room where a four inch check valve #W40RV2 and a normally open four inch isolation valve #W40RV3 are installed. From there the return header runs embedded in the pump room floor and travels directly to the tailrace surge chamber.

Generator lower guide bearing and thrust bearing cooler return has a Barton flow orifice and a globe valve installed on the downstream generator face. The Barton flow orifice is piped to a flow meter panel located on column D outside the generator housing. The generator lower guide bearing and thrust bearing cooler return lines connects into a common header described above.

Flow meter panel settings:

Flow Rates	Set Points
Surface Air Cooler Flow	1250 L/min per discharge header
Upper Generator Cooler Flow	60 L/min
Lower Generator Cooler Flow	640 L/min

Table 1

Turbine guide bearing coolers are supplied by a two inch pipe which also taps into the main six supply header that feeds the surface air coolers. There are a total of four coolers equipped with normally open isolation valves on both the supply and return lines. Main isolation valve normally open #W40V1 is located on the downstream generator face.

Turbine flow rate setting:

Flow Rate	Set Point
Turbine Cooler Flow	50 L/min

Table 2

The turbine guide bearing cooler return connects into a common header with the generator upper and lower guide bearing and returns to the tailrace as described above.

Turbine shaft seal supply taps into the six inch main supply header that feeds the surface air coolers. Shaft seal water passes through two strainers complete with isolation valves, which enable these strainers to act as backup to one another. Strainers and valves are located on the down streamside generator face. Strainers have to be checked and cleaned manually on a regular basis with the frequency established by experience.

Turbine shaft seal supply has a flow meter installed for visual inspection of the amount of flow (L/min) being supplied to the shaft seal, a pressure gauge for visual inspection of amount of pressure and a pressure switch which activates an alarm for low-set pressure in the supply line.

Turbine shaft seal flow rate setting:

Flow Rate	Set Point
Turbine Shaft Seal Flow Rate	50 L/min

Table 3

Turbine shaft seal water escaping above the head cover is drained via embedded pipes to the penstock head gallery where they terminate approximately six inches above a drain. Once in the drain it travels via embedded drainage pipe to the drainage sump.

If complete isolation of the unit is required all main shut off valves, which are normally in the open position when the station is running, should be placed in the closed position. These valves are as follows:

- Generator surface air cooler supply valve #W39V11
- Generator upper guide bearing supply valve #W35V2
- Generator lower guide bearing supply valve #W35V1
- Turbine bearing supply valve #W46V1
- Shaft Seal supply valve #W41V15

Also close the return valves located in the pump room. These valves are as follows:

- Cooling water return valve #W39RV4
- Generator upper and lower guide bearing return valve and turbine bearing valve #W40RV3

The Flow diagrams for Hinds Lake can be found in Appendix A.

HISTORY OF SERVICE WATER SYSTEM

General Information

All work orders that are in the J.D.Edwards system since fall 1994 pertaining to the service water pumps, strainers, and heat exchangers have been reviewed to piece together an overview of the major work done on the service water system. All of the major work done on this system is listed below in the following table. It can be seen from table 4 that the SAC's have only been cleaned once since 1993. It can also be seen that the SAC piping has been cleaned once since 1993. The rotary strainer is cleaned approximately every three years. The generator coolers have been cleaned only once since 1993, but from the amount of build up found within these coolers this cleaning frequency should have been more then what it was.

HLK - Work Order History												
	January	February	March	April	May	June	July	August	September	October	November	December
1993											Cleaned R.Strainer	
1994												
1995												
1996							Cleaned R.Strainer					
1997												
1998												Inspected 1-SAC
1999	Cleaned R.Strainer						Flushed Gen Coolers					
2000										Replaced H.P. Pump	Cleaned 2-SAC 3-G.Cooler	
2001	Cleaned 1-SAC 2-G.Cooler			Cleaned 1-SAC 1-G.Cooler			Flushed Coolers					

Table 4

Review of Trend Monitoring Readings


Trend Monitoring readings are taken weekly by operations for all hydro generating stations except Snooks Arm and Venams Bight. With knowledge of the work history performed on the generating station coupled with the trend monitoring readings one can develop a picture of how the generating station has operated over the last few years.

The Trend monitoring readings are now being stored into a database using Microsoft Access. A hard copy of the weekly readings is being kept on site for backup. The Microsoft Access Trend Monitoring program now allows quick graphing of operating parameters to help us determine the efficiency of the unit. The program is user friendly and allows operations to view the units operating parameters over an extended period of time.

Table 2 shows the missing trend monitoring readings for Hinds Lake.

DATES	Missing Dates	Period
	1999/08/20 to 1999/11/08	Fall 1999
	2000/07/31 to 2000/11/30	Late Summer 2000

Table 5



Graph 7 - Upper Generator Cooler Flow Rate

Graph 7 shows the upper generator cooler flow rate since November 1997. The recommended flow rate is 60 L/min. A low flow rate is 55 L/min and a high flow rate is 90 L/min.


Actual Velocity Calculations:

Flow Rate per tube $Q_t = 0.25$ L/sec

Area per tube $A_t = 1.23$ in²

Velocity per tube $V_t = \frac{Q_t}{A_t} = 1.03$ ft/sec

The upper guide bearing coolers flow rate is above the manufactures recommended normal flow of 60 L/min. The flow rate is not above the manufactures recommended high flow rate of 90 L/min but this extra cooling water that is being given to this cooler can be used else where in the system since all cooling water comes from the same common six inch header.




Graph 6 - Lower Generator Bearing Temperatures

Graph 6 shows the generators lower guide and thrust bearing temperatures since November 1997. One can see the temperature drop after the three coolers were cleaned in November 2000 and again in January 2001 after two more coolers were cleaned.

Lower Generator Bearing Temperature Set Points:


	Guide Bearing	Thrust Bearing
Alarm	70 °C	
Trip Unit	80 °C	

The guide bearing temperatures of 65 °C in the summer 2000 was close to the alarm set point of 70 °C. Since the coolers cleaning the temperatures have drop back towards normal.



Graph 5 - Lower Generator Cooler Water Temperatures

Graph 5 shows the water temperature differential for the generator coolers since November 1997. This graph clearly shows how the water temperatures fluctuate throughout the year, with increased temperatures during the summer months and decreased temperatures during the winter months.



Graph 4 - Lower Generator Cooler Flow Rates

Graph 4 shows the flow rates for the generator lower coolers since November 1997. The recommended flow rate is 640 L/min, with 510 L/min considered low and 960 L/min considered high. One can see the 60 L/min increased flow rate in November of 2000 when three of the six coolers were cleaned. The increase in February 2001 was when two of the remaining three coolers were cleaned and the increase in April 2001 was when the last of the six coolers was cleaned.

Actual Velocity Calculations:


Flow Rate per tube $Q_t = 0.070$ L/sec

Area per tube $A_t = 0.264$ in²

Velocity per tube $V_t = \frac{Q_t}{A_t} = 1.35$ ft/sec

The low flow rate of 400 L/min up until the summer 2000 was below the manufactures recommended low flow rate of 510 L/min and far below the normal recommended flow rate of 640 L/min. The flow rate as of this summer was improved to 535 L/min and this can be improved if the supply and discharge piping is cleaned.

The supply and discharge piping for the lower generator coolers was cleaned during the Fall 2001 outage. Have no data as of yet.



Graph 3 - Stator Temperatures

Graph 3 shows the stator temperatures since November 1997. This graph clearly shows how the stator temperatures fluctuate through out the year, with increased temperatures during the summer months and decreased temperatures during the winter months.


The stator iron alarm has been changed from 75 °C to 79 °C.

Stator Temperature Set Points:

Core Alarm	79 °C
Iron Alarm	79 °C


Table 6

During the summer of 1999 and 2000 the stator temperatures almost reached the iron and core alarm set point of 79 °C. The iron alarm was changed because of this.



Graph 2 – SAC Water Temperatures

Graph 2 shows the water temperature differential for the SAC's since November 1997. This clearly shows how the water temperatures fluctuate through out the year, with increased temperatures during the summer months and decreased temperatures during the winter months. Even though the temperature fluctuates the differential temperature between inlet and discharge remains constant around an average of 6 °C.



Graph 1 - SAC Flow Rates


Graph 1 shows the SAC's flow rates since November 1997. The recommended flow rates are 1250 L/min per bank, with 1000 L/min considered low and 1800 L/min considered high. One can see the 250 L/min increase in flow rate of the north bank around November 2000 after coolers #1 and #4 were cleaned. The 50 L/min increase in flow rate of the south bank around November 2000 was caused by cooler #3 being flushed in place. The second increase in flow rate of the south bank was the cleaning of cooler #2 in January 2001. Cooler #3 was removed and cleaned in April 2001.

Actual Velocity Calculations:

Flow Rate per tube $Q_t = 0.146$ L/sec


Area (elliptical cross section) per tube $A_t = 231$ mm²

Velocity per tube $V_t = \frac{Q_t}{A_t} = 2.08$ ft/sec



Graph 8 - Upper Generator Cooler Water Temperatures

Graph 8 shows the upper generator cooler water temperature since August 2001. This temperature was not being recorded before and it was recommended that we record this temperature for trending.




Graph 9 - Upper Generator Guide Bearing Temperature

Graph 9 shows the upper guide bearing temperature since November 1997.

Upper Guide Bearing Temperature Set Points:

	Guide Bearing Temperature
Alarm	70 °C
Trip Unit	80 °C

The upper guide bearing temperature is low due to the extra cooling water that has been supplied to the cooler. The upper guide bearing oil may be operating in a cooler than recommended range. The bearing oil maybe operating in a less than optimum heat range due to this.



Graph 10 - Turbine Cooler Flow Rate

Graph 10 shows the turbine cooler water flow rate since November 1997. The recommended flow rate is 50 L/min.


Actual Velocity Calculations:

Flow Rate $Q = 1.42 \text{ L/sec}$

Area of tube $A = 0.44 \text{ in}^2$


$$\text{Velocity } V = \frac{Q}{A} = 16.4 \text{ ft/sec}$$

The turbine cooler flow rate of 85L/min is above the manufactures recommended normal flow rate of 50 L/min. Again this extra cooling water can be used else where within the system seeing all cooling water is supplied form the same common six-inch header.



Graph 11 - Turbine Cooler Water Temperature

Graph 11 shows the turbine cooler water temperature since August 2001. This temperature was not being recorded before and it was recommended that we record this temperature for trending reasons.



Graph 12 - Turbine Bearing Temperature


Graph 12 shows the turbine guide bearing temperature since November 1997.

Turbine Bearing Temperature Set Points:

	Turbine Bearing Temperature
Alarm	75 °C
Trip Unit	85 °C

The turbine bearing during the summer months has had high temperatures of 70 °C bring the bearing near the temperature set alarm point of 75 °C. From this one would think that since the turbine bearing coolers are receiving extra cooling water the temperatures would be lower than what they are. It was recommended that the turbine bearing coolers be check for fouling during the Fall 2001 outage.

The turbine bearing coolers were cleaned during the Fall 2001 outage.



Graph 13 - Shaft Seal Pressure

Graph 13 shows the shaft seal pressure since November 1997. A new shaft seal was installed during the Fall 2000 outage. Due to leakage problems the seal was reseated in late Fall 2000.

Test Samples

In August 2001 water samples from the Hinds Lake plant were sent to BetzDearborn for analysis. The water sample is directly from the penstock supply. Table 3 shows the composition of the water sample.

Composition	Sample #1
PH	6.9
Specific Conductance @ 25C, umhos	25
Alkalinity "P" as CaCO ₃ , ppm	0
Alkalinity "M" as CaCO ₃ , ppm	7.1
Sulfur Total as SO ₄ , ppm	< 5
Chloride as CL, ppm	3.4
Hardness Total as CaCO ₃ , ppm	6.5
Calcium Hardness Total as CaCO ₃ , ppm	4.6
Magnesium Hardness Total as CaCO ₃ , ppm	1.9
Copper Total as Cu, ppm	0.05
Iron Total as Fe, ppm	4.3
Sodium as Na, ppm	2.0
Phosphate Total Inorganic as Po ₄ , ppm	< 0.2
Carbon Total Organic as C, ppm	2.4
Silica Total as SiO ₂ , ppm	1.2

Table 3

In the Fall 2000 two pipe deposits were taken from the SAC piping. Sample #1 was from the four inch supply header and sample #2 was from the 3 inch inlet branch into one of the coolers. Table 4 shows the composition of the SAC piping deposits.

Composition	Sample #1	Sample #2
Iron Fe ₂ O ₃ + Fe ₃ O ₄	74 %	19%
Loss on Ignition (LOI)	10%	24%
Manganese MnO ₂	12%	47%
Aluminum Al ₂ O ₃	1%	4%
Calcium CaO	1%	2%
Silicon SiO ₂	1%	1%
Copper CuO	1%	2%
Zinc ZnO		1%

Table 4

From the test samples one can see that the water is almost neutral with little organics. The pipe samples tell us that there is indeed corrosion with a 74% iron content and that there is organic build up with 24% LOI and 47% manganese. The low organics found in the water sample could be the result of when the water sample was taken. It is recommended that another test sample be taken during the spring run off when the organics would be the highest.

The BetzDearborn analysis of the water and piping deposits can be found in Appendix B.

Cost Analysis

Maintenance Cost for Cleaning

In order to clean the service water coolers and piping in Hinds Lake maintenance crew has to be assembled in Bay D'Espoir and drive to Hinds Lake. Travel time to Hinds Lake from Bay D'Espoir is normally six hours.

Travel Arrangements (normal workweek)

Monday: Leave Bay D'Espoir in the morning and drive to the West Coast. Work 4.0 hours upon arriving on site.

Tuesday to Thursday: Regular workweek 8.0 hours per day.

Friday: Work 4.0 hours and then drive back to Bay D'Espoir for the weekend.

Hours of actually work performed on site for one workweek is 32.0 hours.

Perdiem Expenses (\$9 Breakfast, \$11 Dinner, \$18 Supper, \$6 Incidentals (overnight))

Monday: \$34 (no breakfast)

Tuesday to Thursday: \$43 per day

Friday: \$20 (no supper or incidentals)

Total Perdiem charge per person per week: \$183

Having a work crew of more than 4 workers will require the services of a cook and perdiem will not be paid while the services of a cook is provided on site.

For the purpose of this study all workers will receive perdiem.

Minimum Work Crew and Wages

3 Workers at \$21.56 hr (2 workers on floor, 1 worker operating the crane)

1 Supervisor at \$23.72 hr (10% more than the worker)

Total over head costs = salary x 1.63

Travel to site will be by fleet vehicles, 2 required, one supervisor vehicle and one work crew truck. Tools and cleaning equipment will be transported to the site with these vehicles.

The supervisor is usually over seeing two or three jobs while on site. For this cost analysis 1/3 of the supervisors wage will be allocated to the job.

Required gas for travel is \$70 to site and \$70 return from site for one work truck.

Total Cost to Clean SAC

Time required to clean four SAC's for one work crew is four days (32.0 hrs), one cooler per day (8.0 hrs); this includes removal, cleaning, and reinstallation of cooler.

Labour: 3 (workers) x 40.0 hrs (32.0 cleaning, 8.0 driving) x \$21.56 = \$2,587.20
1 (supervisor) x 13.3 hrs (1/3 x 40.0 hrs) x \$23.72 = \$315.48

Total Over Head Costs: \$2,902.68 x 1.63 = \$4,731.37

Perdiem: 4 (work crew) x \$183 = \$732
(Monday \$34, Tuesday to Thursday \$129, Friday \$20)

Gas: 4 (2 vehicles) x \$70 = \$280

Total cost: \$5743.37

Total Cost to Clean SAC Piping

Time required to clean SAC piping inside of generator housing for one work crew is three days (24.0 hrs); this includes removal, cleaning, and reinstallation of piping.

Labour: 3 (workers) x 32.0 hrs (24.0 cleaning, 8.0 driving) x \$21.56 = \$2,069.76
1 (supervisor) x 10.7 hrs (1/3 x 32.0 hrs) x \$23.72 = \$253.80

Total Over Head Costs: \$2,323.56 x 1.63 = \$3,787.40

Perdiem: 4 (work crew) x \$140 = \$560
(Monday \$34, Tuesday to Wednesday \$86, Thursday \$20)

Gas: 4 (2 vehicles) x \$70 = \$280

Total cost: \$4,627.40

Total Cost to Clean Lower Generator Coolers

Time required to clean six lower generator coolers for one work crew is five days (36.0 hrs), one cooler every 6.0 hours; this includes removal of head cover, cleaning, and reinstallation of head cover.

Labour: 3 (workers) x 40.0 hrs (36.0 cleaning, 4.0 driving) x \$21.56 = \$2,587.20
3 (workers) x 4.0 hrs (4.0 driving) x \$43.12 = \$517.44 (Double Pay, Finish Job)
1 (supervisor) x 13.3 hrs (1/3 x 40.0 hrs) x \$23.72 = \$315.48

Total Over Head Costs: \$3,420.12 x 1.63 = \$5,574.80

Perdiem: 4 (work crew) x \$226 = \$904
(Monday \$34, Tuesday to Friday \$172, Saturday \$20)

Gas: 4 (2 vehicles) x \$70 = \$280

Total cost: \$6,758.80

Total Cost to Clean Lower Generator Cooler Piping

The lower generator cooler supply and discharge header piping cannot be removed for cleaning due to the confined space in which it is laid. Only the branch piping from the headers to the coolers can be removed for cleaning. Time required to clean branch piping for one crew is 2 days (16.0 hrs); this includes removal of piping, cleaning, and reinstallation of piping.

Labour: 3 (workers) x 24.0 hrs (16.0 cleaning, 8.0 driving) x \$21.56 = \$1,552.32
1 (supervisor) x 8.0 hrs (1/3 x 24.0 hrs) x \$23.72 = \$189.76

Total Over Head Costs: \$1,742.08 x 1.63 = \$2,839.59

Perdiem: 4 (work crew) x \$97 = \$388
(Monday \$34, Tuesday \$43, Wednesday \$20)

Gas: 4 (2 vehicles) x \$70 = \$280

Total cost: \$3,507.59

Total Cost to Clean Upper Generator Cooler

Due to the configuration and location of this cooler mechanical cleaning methods are not practicable. Chemical cleaning could be considered for this cooler. There is no record in J.D.Edwards of this cooler being cleaned.

Total Cost to Clean Upper Generator Cooler Piping

Time required too clean upper generator piping for one crew is 2 days (16 hrs); this includes removal of piping, cleaning, and reinstallation of piping.

Labour: 3 (workers) x 24.0 hrs (16.0 cleaning, 8.0 driving) x \$21.56 = \$1,552.32
1 (supervisor) x 8.0 hrs (1/3 x 24.0 hrs) x \$23.72 = \$189.76

Total Over Head Costs: \$1,742.08 x 1.63 = \$2,839.59

Perdiem: 4 (work crew) x \$97 = \$388
(Monday \$34, Tuesday \$43, Wednesday \$20)

Gas: 4 (2 vehicles) x \$70 = \$280

Total cost: \$3,507.59

ALTERNATIVE SOLUTIONS

General Information

The fouling problem with regard to the cooling water system is being caused by two problems. The first problem is corrosion of the piping system and the second problem is organic build up. The acidic water supply is causing the piping system to corrode and the organics are then attaching themselves to the corroded pipe. Over time the organics build up and are able to clog the pipe. The heat transferred into the cooling water from the heat exchangers cause the suspended organics in the water to participate out. This then causes the discharge piping to become clogged with organics and choke off the flow rate. A decreased flow rate allows for more organics to settle within the cooling water system. Eventually the entire cooling water system will become clogged with organics.

The following is a list of solutions that can be used to combat this problem.

1. Mechanical cleaning of the system.
2. Chemical cleaning of the system.
3. Replace the piping with corrosion resistant pipe.
4. Chemically treat the water.
5. Develop a flushing maintenance program.
6. Incorporate organic filters.
7. Convert the system to a closed loop operation.

A brief description of each proposed solution is discussed below.

Mechanical Cleaning

Mechanical cleaning of the cooling water system will require a maintenance cleaning program if this solution is going to be considered. Without a maintenance cleaning program the reliability of the service water system will be compromised and forced unit outages will happen.

Mechanically cleaning the service water system will require a cleaning maintenance crew and scheduled plant outages to perform the work. The piping and heat exchangers have to be removed from service and physically cleaned by hand. This hand cleaning decreases the life expectancy of both the piping and heat exchangers. The hand cleaning of piping and cooler tubes is done with rotating nylon brushes that physically scrape the pipe walls of organic build up. Also the possibility of mechanical damage is increased when man handling the piping and heat exchangers.

Chemical Cleaning

Chemical cleaning of the service water system requires a maintenance cleaning program to be established. Without a maintenance cleaning program the reliability of the service water system will be compromised and forced unit outages will happen.

Chemically cleaning the service water system will require a cleaning maintenance crew and scheduled plant outages to perform the work. The piping and heat exchangers do don't have to be removed from the system. Instead isolation valves upstream and downstream are closed and mechanical branch connections are attached to the piping system in both upstream and downstream locations. The chemical mixture is then pumped through the system to dissolve any organic build up.

Chemical treatment is harsh on the piping and heat exchangers and decreases their life expectancy. The chemical leaves the metal in an unpassivated state and corrosion will occur very rapidly after returning the system to service.

Replace Piping

Currently the piping material is mild steel schedule 40. Two different piping materials have been considered for replacement of the mild steel pipe, they are 316 stainless steel pipe schedule 10 and polyvinyl chloride (PVC) pipe schedule 80.

The 316 stainless steel schedule 10 pipe is considered because of its corrosion resistance and mechanical properties. The stainless steel pipe will be placed in high traffic areas or in areas where the piping is likely to be hit to prevent damage.

The PVC schedule 80 pipe is considered because of its corrosion resistance, mechanical properties, and thermal properties. Schedule 80 will be more durable when compared with schedule 40. Due to PVC's excellent thermal properties there will be no need to insulate the pipe as compared to stainless steel. The PVC pipe will be placed in low traffic areas where the probability of the pipe being damaged is remote.

Chemical Treatment of the Water

The water can be chemically treated to reduce the acidity of the water by raising the ph level and also help keep all organic materials in a suspended state. The existing service water system is a once through operation and will require large amounts of chemical. BetzDearborn purposed a chemical treatment solution, which can be found in Appendix C. It is estimated to cost \$5,000 to set up this system and \$30,000 per year for chemical usage.

Flushing Maintenance Program

Flushing each cooler individually to remove any organic build up will help keep the service water system clear. Flushing is performed when all water flow is directed through one particular cooler for a predetermined amount of time. Any loose organic material will be forced out of the cooler and washed away.

If a flushing program was implemented it would reduce the amount of loose organic build up within the service water system. The program would consist of flushing the coolers every four weeks starting in the spring and continuing over the summer. The effectiveness of this has not yet been determined.

Organic Filters

Organic filters can be incorporated at the beginning of the service water system to remove the organics from the water. Sand filters are an effective method of removing organics from water. Typical flow rates for sizing a sand filter are 3-6 gpm for every square foot of surface area. The smallest sand filter for Hinds Lake would be around 12 ft in diameter to allow for 630 gpm. Space would then become a problem with this solution.

Closed System Operation

By adding another heat exchanger to the existing service water system one can create a closed system. There are various heat exchangers that can be implemented into the system such as water-to-water, air-to-water, or chemical-to-water.

Water-to-water would be the most practical in this situation due to the amount of heat that is being transferred through the exchanger. An air-to-water heat exchanger would have a very large surface area in order to remove the quantity of heat within the system, making this solution not practical. Using a chemical within the closed circuit system is not necessary considering the temperatures that we are dealing with.

This additional heat exchanger will require pumps, piping and valves in order to be incorporated into the service water system. In addition the style and location of this new heat exchanger will be incorporated into the design of the new system so that maintenance will be easier. Also this system will have 100% capacity back up so that cleaning of the heat exchanger will not require any unit outages.

The use of a cooling pond to supply water to the service water system can be considered a closed loop system because you are reusing the existing water that is in the cooling pond. The water in the cooling pond can be chemically treated to ensure that it remains neutral and does not become acidic. Again space would be a restriction with this type of solution.

VIABLE SOLUTIONS

In order to compare the viable solutions the Net Present Worth (NPW) method will be used to determine which solution is most feasible from a financial point of view. The NPW method will only take into account the investment dollars needed to bring the solution to life. Other benefits to each solution is not taken into account using the NPW method because of the many variables involved in placing a dollar sign on there worth.

In the conclusions and recommendations section each solution will be discussed including all of the advantages and disadvantages associated with that solution.


Continue to Maintain Current Operation

The “do nothing” approach is to continue operating the plant as we have in the past. This means mechanically cleaning the SAC’s every ten years, generator bearing coolers every five years, SAC piping every ten years, and generator bearing cooler piping every ten years. This solution will require high maintenance and unit outages so that the work can be performed.

NPW Analysis

Below is the NPW analysis of the “do nothing” solution. There is no capital expenditures related to this solution only yearly operating costs as can be seen below.

Graph 14 is the NPW analyse of “do nothing” solution:



Graph 14

Table 7 shows the costs associated with this solution:

Capital Cost	
Total	0

Operating Cost	
Pump consumption (49 weeks)	\$11,936
Clean SAC (10 yr)	\$5,743
Clean SAC Piping (10 yr)	\$4,627
Clean L Gen Brg Coolers (5 yr)	\$6,759
Clean L Gen Brg Cooler Piping (10 yr)	\$3,508
Clean U Gen Brg Cooler Piping (10 yr)	\$3,508

Table 7

The NPW is calculated over the life span of the piping, which is 20 years. The inflation rate used is 2%, the power rate used for the pump is \$0.05 kWh, and the rate of return for Hydro is 8.5%.

The total NPW of this solution is \$152,494 for both units.

The spreadsheet for the NPW graph showing the yearly increases can be found in Appendix D.

Replace Piping Inside of Generator Housing

Stainless Steel is recommended as the ideal piping material to be used inside of the generator housing due to its corrosion resistance and mechanical properties. The SAC piping, upper generator cooler piping, and lower generator cooler piping is carbon steel and should be replaced with stainless steel. The turbine cooler piping and shaft seal piping is already stainless steel inside of the generator housing.

SAC Water Piping

The SAC cooler water piping is currently carbon steel with flanges for all the connections. It is recommended to replace the carbon steel with stainless steel sch 10 inside the generator housing. The following table is a list of parts needed to replace the piping with stainless steel. The price quote is from EMCO Distribution Ltd.

Parts Table:

Item #	Part Description	Quantity	Price	Total
1	3" Pipe s.s sch 10	40	\$11.41	\$456.40
2	4" Pipe s.s sch 10	240	\$12.97	\$3,112.80
3	4"x3" Reducer s.s Vic	4	\$90.22	\$360.88
4	4"x4"x4" Tee s.s Vic	1	\$292.93	\$292.93
5	4"x4"x3" Tee s.s Vic	4	\$170.41	\$681.64
6	4" 90-Elbow s.s Vic	1	\$140.58	\$140.58
7	4" 45-Elbow s.s Vic	12	\$101.06	\$1,212.72
8	3" 90-Elbow s.s Vic	12	\$77.76	\$933.12
9	3" 45-Elbow s.s Vic	10	\$70.88	\$708.80
10	3" Butterfly valve c.s Vic-300	8	\$160.02	\$1,280.16
11	3" Flange adapter Vic-741	8	\$41.13	\$329.04
12	3" Coupling c.s Vic-77 with E-Gasket	64	\$16.86	\$1,079.04
13	4" Flange adapter Vic-741	3	\$47.51	\$142.53
14	4" Coupling c.s Vic-77 with E-Gasket	64	\$26.57	\$1,700.48

The total cost for parts is \$12,431.12

Cost Analysis to Replace SAC Water Piping

The labour time required for a crew to replace the piping was calculated using RS Means Mechanical Cost Data 2000. An additional 25% labour time was added to the RS Means calculation for pipe location and space restrictions. Also an additional 15% labour time was added to the RS Means calculation for removal of old piping system. Two additional workers will be placed on this job, shortening the labour time by 50%. RS Means calculations can be found in Appendix E. The costs break down associated with travel, perdiem, and minimum work crew can be found under the Cost Analysis section on page 25.

Total labour time required for work crew of four: 43.4 hrs
Added labour due to pipe location and space restrictions: $43.4 \times 25\% = 10.8$ hrs
Labour time for work crew to remove old piping: $54.2 \times 15\% = 8.2$ hrs
Total labour time required to complete job = 62.4 hrs

In order to complete this job within the two week scheduled outage all work has to be done within 64.0 hours, leaving 16.0 hours for travel. The supervisor is usually over seeing two or three jobs while on site; therefore only 1/3 of the supervisors wage will be allocated to this particular job. For this cost estimate the supervisor will stay in the nearest hotel.

Labour: 4 (workers) x 78.4 hrs (62.4 installation + 16.0 driving) x \$21.56 = \$6,761.22
1 (supervisor) x 26.1 hrs ($\frac{1}{3} \times 78.4$ hrs) x \$23.72 ($\$21.56 \times 10\%$) = \$619.10

Total Over Head Costs: $\$7,380.32 \times 1.63 = \$12,029.92$

Perdiem: 5 (work crew) x 2 weeks x \$183 = \$1,830
(Monday \$34, Tuesday to Thursday \$129, Friday \$20)

Hotel (1 supervisor) = 8 (nights) x \$80 = \$640

Gas: 4 Trips (2 vehicles) x 2 weeks x \$70 = \$560

Total Cost: \$15,059.92

Upper Generator Bearing Cooler Water Piping

The upper generator cooler water piping is currently carbon steel with flanges for all the connections. It is recommended to replace the carbon steel with stainless steel sch 10 inside the generator housing. The following table is a list of parts needed to replace the piping with stainless steel. The price quote is from EMCO Distribution Ltd.

Parts Table:

Item #	Part Description	Quantity	Price	Total
1	2" Pipe s.s sch 10	60	\$7.51	\$450.60
2	2" Elbow s.s vic 90 degrees	16	\$70.15	\$1,122.40
3	2" Coupling c.s vic style 77 E gasket	28	\$11.50	\$322.00
4	2" Vic-Flange Adapters style 741 c.s	2	\$36.30	\$72.60

The total cost for parts is \$1,967.60

Cost Analysis to Replace Upper Generator Bearing Cooler Water Piping

The labour time required for a crew to replace the piping was calculated using RS Means Mechanical Cost Data 2000. An additional 25% labour time was added to the RS Means calculation for pipe location and restrictions. An additional 15% labour time was added to the RS Means calculation for removal of old piping system. RS Means calculations can be found in Appendix E. The costs break down associated with travel, per diem, and minimum work crew can be found under the Cost Analysis section on page 25.

Labour time for work crew of two: 18.1 hrs

Added labour due to pipe location and space restrictions: $18.1 \times 25\% = 4.5$ hrs

Labour time for work crew to remove old piping: $22.6 \times 15\% = 3.4$ hrs

Total labour time required to complete job = 26.0 hrs

In order to complete this job within the one week scheduled outage all work has to be done within 32.0 hours, leaving 8.0 hours for travel. The supervisor is usually over seeing two or three jobs while on site; therefore only 1/3 of the supervisors wage will be allocated to this particular job.

It will take the work crew up until 2:00 o'clock Thursday afternoon before this job is complete. The work crew will remain on site for Thursday night and drive back to Bay D'Espoir Friday morning.

Labour: 2 (workers) \times 34.0 hrs (26.0 installation + 8.0 driving) \times \$21.56 = \$1,466.08

1 (supervisor) \times 11.3 hrs ($\frac{1}{3} \times 34.0$ hrs) \times \$23.72 (\$21.56 \times 10%) = \$268.04

Total Over Head Costs: $\$1,734.12 \times 1.63 = \$2,826.61$

Per diem: 3 (work crew) \times \$183 = \$549.00

(Monday \$34, Tuesday to Thursday \$129, Friday \$20)

Gas: 4 Trips (2 vehicles) \times \$70 = \$280

Total Cost: \$3,655.61

Lower Generator Bearing Cooler Water Piping

The lower generator cooler water piping is currently curved carbon steel with flanges for all the connections. It is recommended to replace the carbon steel with stainless steel sch 10 inside the generator housing. All curved piping can be substituted with straight pipe using 30 degree and 22 ¼ degree elbows. An AutoCAD drawing can be found in Appendix F showing the new piping arrangement.

The following table is a list of parts needed to replace the piping with stainless steel. The price quote is from EMCO Distribution Ltd.

Parts Table:

Item #	Part Description	Quantity	Price	Total
1	2" Pipe s.s sch 10	40	\$7.51	\$300.40
2	2 1/2" Pipe s.s sch 10	80	\$10.53	\$842.40
3	3" Pipe s.s sch 10	20	\$11.41	\$228.20
4	2 1/2" 90 Long Radius Elbow s.s Vic	4	\$115.00	\$460.00
5	2 1/2" 30 Long Radius 6D Elbow s.s Vic	16	\$206.47	\$3,303.52
6	2 1/2" 22.5 Long Radius 6D Elbow s.s Vic	4	\$249.64	\$998.56
7	2 1/2" x 2" Reducer s.s Vic	4	\$112.45	\$449.80
8	2 1/2" x 2 1/2" x 2" Reducer Tee s.s Vic	8	\$241.00	\$1,928.00
9	2 1/2" x 2 1/2" x 2 1/2" Tee s.s Vic	2	\$234.29	\$468.58
10	3" x 2 1/2" Reducer s.s Vic	2	\$72.88	\$145.76
11	2" 90 Long Radius Elbow s.s Vic	24	\$70.15	\$1,683.60
12	2" Butterfly valve c.s Vic-300	12	\$163.99	\$1,967.88
13	2" Vic Flange Adapter Style 741	12	\$36.30	\$435.60
14	3" Vic Flange Adapter Style 741	2	\$41.13	\$82.26
15	2" Coupling c.s Vic-77 with E-Gasket	80	\$11.50	\$920.00
16	2 1/2" Coupling c.s Vic-77 with E-Gasket	70	\$14.93	\$1,045.10
17	3" Coupling c.s Vic-77 with E-Gasket	2	\$16.86	\$33.72

The total cost for parts is \$15,293.38

Cost Analysis to Replace Lower Generator Bearing Cooler Water Piping

The labour time required for a work crew to replace the piping was calculated using RS Means Mechanical Cost Data 2000. An additional 25% labour time was added to the RS Means calculation due to pipe location and space restrictions. An additional 15% labour time was added to the RS Means calculation for removal of old piping system. Two additional workers will be placed on this job, shortening the labour time by 50%. RS Means calculations can be found in Appendix E. The costs break down associated with travel, per diem, and minimum work crew can be found under the Cost Analysis section on page 25.

Total labour time required for a work crew of four: 32.6 hrs

Added labour due to pipe location and space restrictions, $32.6 \times 25\% = 8.2$ hrs

Added labour required to remove old piping: $40.8 \times 15\% = 6.1$ hrs

Total labour time required to complete job = 46.9 hrs

In order to complete this job within the two week scheduled outage all work has to be done within 64.0 hours, leaving 16.0 hours for travel. The supervisor is usually over seeing two or three jobs while on site; therefore only 1/3 of the supervisors wage will be allocated to this particular job. For this cost estimate the supervisor will stay in the nearest hotel.

Labour: 4 (workers) x 62.9 hrs (46.9 installation + 16.0 driving) x \$21.56 = \$5,424.50

1 (supervisor) x 21.0 hrs (1/3 x 62.9 hrs) x \$23.72 (\$21.56 x 10%) = \$498.12

Total Over Head Costs: \$5,922.62 x 1.63 = \$9,653.87

Per diem: 5 (work crew) x \$183 = \$915

(Monday \$34, Tuesday to Thursday \$129, Friday \$20)

5 (work crew) x \$97 = \$485

(Monday \$34, Tuesday \$43, Wednesday \$20)

Hotel (1 supervisor) = 8 (nights) x \$80 = \$640

Gas: 4 Trips (2 vehicles) x 2 weeks x \$70 = \$560

Total Cost: \$12,253.87

Replace Piping Outside of Generator Housing

Polyvinyl chloride (PVC) is recommended as the ideal piping material to be used outside of the generator housing due to its corrosion resistance, mechanical properties, thermal properties, and cost. The inlet header and discharge piping should be replaced with PVC.

Inlet Header Piping

The inlet header piping branches off from the main supply header and ascends from the pump floor up the wall to the ceiling where it then runs along the walls into the generator housing. Damage caused by accidental impact should not be of any concern due to this piping arrangement. The inlet header piping will be replaced starting from the discharge side of the cooling water pump and continue to the entrance of the generator housing. The following table is the list of parts needed to replace the inlet piping with PVC. The price quote is from EMCO Distribution Ltd.

Parts table:

Item #	Part Description	Quantity	Price	Total
1	6" Pipe PVC Sch 80	50	\$7.80	\$390.00
2	6" Elbows 90 PVC Socket Sch 80	7	\$26.96	\$188.72
3	6" Flange PVC Socket Sch 80	2	\$48.10	\$96.20
4	6"x5" Reducer PVC Socket Sch 80	1	\$58.20	\$58.20
5	6"x6"x6" Tee PVC Socket Sch 80	1	\$46.31	\$46.31
6	6"x6"x3" Reducing Tee PVC Socket S80	5	\$36.30	\$181.50
7	3"x1 1/2" Reducer Bushing Socket Sch 80	2	\$9.51	\$19.02
8	6" Elbows 45 PVC Socket Sch 80	1	\$34.84	\$34.84
9	6" Butterfly Valve PVC Flanged	2	\$362.01	\$724.02
10	6" Check Valve Wafer PVC Flanged	1	\$646.45	\$646.45
11	5" Flange PVC Socket Sch 80	1	\$25.43	\$25.43
12	3" Pipe PVC Sch 80	20	\$2.86	\$57.20
13	3" Elbows 90 PVC Socket Sch 80	3	\$6.38	\$19.14
14	3" Elbows 45 PVC Socket Sch 80	2	\$14.60	\$29.20
15	3" Butterfly Valve PVC Flanged	1	\$204.33	\$204.33
16	3" Flange PVC Socket Sch 80	4	\$10.57	\$42.28
17	2" Pipe PVC Sch 80	10	\$1.32	\$13.20
18	2" Elbows 90 PVC Socket Sch 80	3	\$2.54	\$7.62
19	2" Butterfly Valve PVC Flanged	1	\$184.85	\$184.85
20	2" Flange PVC Socket Sch 80	2	\$6.07	\$12.14
21	1 1/2" Pipe PVC Sch 80	30	\$1.00	\$30.00
22	1 1/2" Elbows 90 PVC Socket Sch 80	13	\$2.00	\$26.00
23	1 1/2" Elbows 45 PVC Socket Sch 80	1	\$4.42	\$4.42
24	1 1/2" Ball Valve PVC Flanged	5	\$98.53	\$492.65
25	1 1/2" Flange PVC Socket Sch 80	9	\$4.66	\$41.94
26	1.5"x1.5"x1.5" Tee PVC Socket Sch 80	3	\$6.89	\$20.67
27	1 1/2" Pressure Tap Orifice Flanges s.s (1set)	2	\$288.25	\$576.50

The total cost for parts is \$4,172.83

Cost Analysis to Replace Inlet Header Piping

The labour time required for a crew to replace the piping was calculated using RS Means Mechanical Cost Data 2000. An additional 25% labour time was added to the RS Means calculation for pipe location and space restrictions. Also an additional 15% labour time was added to the RS Means calculation for removal of old piping system. One additional worker will be placed on this job, shortening the labour time by 25%. RS Means calculations can be found in Appendix E. The costs break down associated with travel, per diem, and minimum work crew can be found under the Cost Analysis section on page 25.

Total labour time required for work crew of three: 41.0 hrs
Added labour due to pipe location and space restrictions: $41.0 \times 25\% = 10.2$ hrs
Labour time for work crew to remove old piping: $51.2 \times 15\% = 7.7$ hrs
Total labour time required to complete job = 58.9 hrs

In order to complete this job within the two week scheduled outage all work has to be done within 64.0 hours, leaving 16.0 hours for travel. The supervisor is usually over seeing two or three jobs while on site; therefore only 1/3 of the supervisors wage will be allocated to this particular job.

Labour: 3 (workers) \times 74.9 hrs (58.9 installation + 16.0 driving) \times \$21.56 = \$4,844.53
1 (supervisor) \times 25.0 hrs ($1/3 \times 74.9$ hrs) \times \$23.72 (\$21.56 \times 10%) = \$593.00

Total Over Head Costs: \$5,437.53 \times 1.63 = \$8,863.17

Per diem: 4 (work crew) \times 2 weeks \times \$183 = \$1,464.00
(Monday \$34, Tuesday to Thursday \$129, Friday \$20)

Gas: 4 Trips (2 vehicles) \times 2 weeks \times \$70 = \$560

Total Cost: \$10,887.17

Discharge Header Piping

The discharge piping descends down the outside of the scroll case wall to the floor. Damage caused by accidental impact should not be of any concern due to the location of the piping on the concrete wall. The discharge piping will be replaced from where the stainless steel exits the generator housing and will continue until it meets the piping embedded in the floor. The following table is the list of parts needed to replace the piping with PVC. The price quote is from EMCO Distribution Ltd.

Parts Table:

Item #	Part Description	Quantity	Price	Total
1	6" Pipe PVC Sch 80	20	\$7.80	\$156.00
2	6" Elbows 90 PVC Socket Sch 80	4	\$26.96	\$107.84
3	6" Flange PVC Socket Sch 80	5	\$48.10	\$240.50
4	6"x4" Reducer Coupling PVC Socket Sch 80	1	\$52.14	\$52.14
5	6"x6"x4" Reducing Tee PVC Socket Sch 80	1	\$50.72	\$50.72
6	6" Butterfly Valve PVC Flanged	1	\$362.01	\$362.01
7	6" Check Valve PVC Flanged	1	\$646.45	\$646.45
8	4" Pipe PVC Sch 80	40	\$4.17	\$166.80
9	4" Elbows 90 PVC Socket Sch 80	8	\$9.47	\$75.76
10	4" Check Valve PVC Flanged	1	\$549.28	\$549.28
11	4" Butterfly Valve PVC Flanged	3	\$204.33	\$612.99
12	4" Flange PVC Socket Sch 80	9	\$13.36	\$120.24
13	4"x4"x4" Tee PVC Socket Sch 80	1	\$14.27	\$14.27
14	4" Pressure Tap Orifice Flanges s.s (2set)	2	\$689.74	\$1,379.48
15	3" Pipe PVC Sch 80	10	\$2.86	\$28.60
16	3" Elbows 90 PVC Socket Sch 80	1	\$6.38	\$6.38
17	3" Butterfly Valve PVC Flanged	1	\$204.33	\$204.33
18	3" Flange PVC Socket Sch 80	2	\$11.12	\$22.24
19	4"x3" Reducer Coupling PVC Socket Sch 80	1	\$25.56	\$25.56
20	3" Pressure Tap Orifice Flanges s.s (1set)	1	\$501.54	\$501.54
21	2" Pipe PVC Sch 80	20	\$1.32	\$26.40
22	2" Elbows 90 PVC Socket Sch 80	1	\$2.54	\$2.54
23	2" Butterfly Valve PVC Flanged	1	\$184.85	\$184.85
24	2" Flange PVC Socket Sch 80	1	\$6.07	\$6.07
25	4"x2" Reducer Coupling PVC Socket Sch 80	2	\$28.99	\$57.98
26	2" Pressure Tap Orifice Flanges s.s (1set)	1	\$479.75	\$479.75
27	1 1/2" Pipe PVC Sch 80	10	\$1.00	\$10.00
28	1 1/2" Elbows 90 PVC Socket Sch 80	2	\$2.00	\$4.00
29	1 1/2" Ball Valve PVC Flanged	1	\$98.53	\$98.53
30	1 1/2" Flange PVC Socket Sch 80	2	\$4.66	\$9.32
31	2"x1 1/2" Reducer PVC Socket Sch 80	1	\$3.45	\$3.45

The total cost for parts is \$6,206.02

Total cost with reusing existing pressure tap orifice flanges is \$3,845.25

Cost Analysis to Replace Discharge Header Piping

The labour time required for a crew to replace the piping was calculated using RS Means Mechanical Cost Data 2000. An additional 25% labour time was added to the RS Means calculation for pipe location and space restrictions. Also an additional 15% labour time was added to the RS Means calculation for removal of old piping system. One additional worker will be placed on this job, shortening the labour time by 25%. RS Means calculations can be found in Appendix E. The costs break down associated with travel, per diem, and minimum work crew can be found under the Cost Analysis section on page 25.

Total labour time required for work crew of three: 36.0 hrs

Added labour due to pipe location and space restrictions: $36.0 \times 25\% = 9.0$ hrs

Labour time for work crew to remove old piping: $45.0 \times 15\% = 6.8$ hrs

Total labour time required to complete job = 51.8 hrs

In order to complete this job within the two week scheduled outage all work has to be done within 64.0 hours, leaving 16.0 hours for travel. The supervisor is usually over seeing two or three jobs while on site; therefore only 1/3 of the supervisors wage will be allocated to this particular job.

Labour: 3 (workers) x 67.8 hrs (51.8 installation + 16.0 driving) x \$21.56 = \$4,385.31

1 (supervisor) x 22.6 hrs (1/3 x 67.8 hrs) x \$23.72 (\$21.56 x 10%) = \$536.07

Total Over Head Costs: \$4,921.38 x 1.63 = \$8,021.85

Per diem: 4 (work crew) x \$183 = \$732

(Monday \$34, Tuesday to Thursday \$129, Friday \$20)

4 (work crew) x \$140 = \$560

(Monday \$34, Tuesday to Wednesday \$86, Thursday \$20)


Gas: 4 Trips (2 vehicles) x 2 weeks x \$70 = \$560

Total Cost: \$9,873.85

NPW Analysis

Below is the NPW analysis of the replace piping solution. There are capital expenditures with this solution along with operating expenditures. The capital is for replacing the existing SAC, generator bearing cooler piping inside the generator housing with stainless steel and replace the inlet and discharge header piping outside of the generator housing with PVC.

Graph 15 is the NPW analyse of replacing the pipe solution:



Graph 15

Table 8 shows the costs associated with this solution:

Capital Cost	
SAC Piping (Parts & Installation)	\$27,491
Gen U Brg Piping (Parts & Installation)	\$5,623
Gen L Brg Piping (Parts & Installation)	\$27,547
Inlet Piping (Parts & Installation)	\$15,060
Discharge Piping (Parts & Installation)	\$16,079
Total	\$91,800

Operating Cost	
Pump consumption (49 weeks)	\$11,936

Table 8

The NPW is calculated over the life span of the piping, which is 20 years. The inflation rate used is 2%, the power rate used for the pump is \$0.05 kWh, and the rate of return for Hydro is 8.5%.

The total NPW of this solution is \$218,064.

The spreadsheet for the NPW graph showing the yearly increases can be found in Appendix D.

Closed System Operation

Heat Exchanger Selection

The style of heat exchanger that needed to be selected would have to meet the following criteria:

1. Compact design
2. Easy to maintain and clean
3. Will not clog
4. Capacity of 530 Usgpm

It was determined that a plate and frame heat exchanger would meet all of these requirements. Due to it's construction the exchanger can be expanded to meet future cooling requirements by adding more plates and this design also allows for easy access for cleaning.

Tom Furlong of Maynard Reece was contacted for a price estimate on this type of heat exchanger. A quoted price of \$17,500 per unit was established for this cost feasibility study.

Pump Selection

In order to select a pump for this system the pressure drop across the entire cooling water system including the new heat exchanger would have to be known. Using Design Flow Solutions one can enter the entire cooling water system into the program and determine the pressure drop at the desired flow rate.


It was determined that the pressure drop for Hinds Lake at 530 Usgpm was 21 psia. A print out of the calculation can be found in Appendix G. Attached is a disk with the system worked through in the Design Flow Solutions program.

The pump selected for this application is a Goulds centrifugal pump 3196 (3 x 4 - 10H, 9" impeller). This pump is capable of 530 Usgpm @ 67 ft head using water as the medium. The pumps specification sheet can be found in Appendix H.

NPW Analysis

The closed loop solution has capital and operating expenditures associated with it. The capital expenditure is for purchasing the heat exchanger, recirculation pump, and associated piping and hardware for the installation. This solution will require 100% capacity back up so two heat exchangers and recirculation pumps will have to be purchased.

Graph 16 is the NPW analyse for the closed loop solution:



Graph 16

Table 9 shows the costs associated with this solution:

Capital Cost	
Pump	\$5,345
Heat Exchanger	\$17,500
Installation Piping & Hardware	\$8,000
Total	\$30,845

Operating Cost	
Pump consumption (49 weeks)	\$11,936
Recir Pump Consumption (49 weeks)	\$4,610

Table 9

The NPW is calculated over the life span of the piping, which is 20 years. The inflation rate used is 2%, the power rate used for the pump is \$0.05 kWh, and the rate of return for Hydro is 8.5%.

The total NPW of this solution is \$213,427.

The spreadsheet for the NPW graph showing the yearly increases can be found in Appendix D.


Chemical Injection

The chemical injection solution is based on injecting a chemical known as FLOGARD POT6101 into the cooling water system. This chemical has both cathodic and anodic inhibitors that react with the water to prevent corrosion of the piping and organic build up within the piping. The concentrations are very low 4 ppm and the impact on the environment would be very low considering the chemical is being discharged into the tailrace with the rest of the discharged water.

NPW Analysis

This solution has both capital and operating expenditures. The operating expenditures are very high due to the continuous replacement of the FLOGARD POT6101 chemical.

Graph 17 is the NPW analyse of the chemical injection solution:



Graph 17

Table 10 shows the costs associated with this solution:

Capital Cost	
Injection System	\$5,000
Test Coupon Rack	\$515
Total	\$5,515

Operating Cost	
Pump consumption (49 weeks)	\$11,936
Chemical (49 weeks)	\$30,000

Table 10

The NPW is calculated over the life span of the piping, which is 20 years. The inflation rate used is 2%, the power rate used for the pump is \$0.05 kWh, and the rate of return for Hydro is 8.5%.

The total NPW of this solution is \$473,956.

The spreadsheet for the NPW graph showing the yearly increases can be found in Appendix D.

CONCULSIONS AND RECOMMENDATIONS

From the material presented there were four different solutions that could be taken to resolve the problem. To recap the four alternative solutions were to continue to operate as we have “do nothing approach”, replace the piping with corrosion resistant material, inject chemical into the service water for treatment, or install a closed loop system with treated water to cool the units. Each solution has it's benefits and draw backs.

The NPW analysis calculated the following dollar figures for each solution;

Do Nothing	\$152,494
Replace the Piping with s.s & PVC	\$218,064
Closed Loop System	\$213,427
Chemical Injection	\$473,956

Table 11

The “continue to operate as we have” will mean scheduled outages for cooler and pipe cleaning. There is an uncertainty with this solution when it comes to forced outages due to cooling problems during the summer months. If a maintenance program for cleaning and maintaining the cooling water system is not implemented forced outages due to cooling problems during the summer months, in the height of the maintenance season, will occur. In order to prevent this a fouling monitoring program for the cooling water system has to be put in place.

The service water system currently has all of its original piping that was installed when the plant was first came on-line in 1980. This life expectancy of this pipe is near its end. The cooling water pipe will have to be replaced in the near future. A quick calculation of the labour cost associated with replacing that piping is \$52,000 this figure does not include the pipe.

The other alternative of replacing the piping with corrosion resistant pipe has an initial capital investment with a low operating cost associated with it. The labour cost of replacing the pipe in the cooling water system is going to be the same regardless of what type of pipe you use to replace it.

One of the benefits of having the corrosion resistant pipe like stainless steel and PVC is lower maintenance. Unit outages for cleaning service water piping will be less frequent, hence will free up more manpower for other tasks during the maintenance season.

Another benefit to corrosion resistant piping is the reduced likely hood of the pipe becoming clogged with debris. Since the pipe is resistant to corrosion from the service water it is not likely that enough organic material will be able to adhere to the pipe wall to impend flow to the point of stagnation. It is believed that only a small layer of organics will adhere to the inner pipe wall and once that layer is in place the rest of the organics will be washed through the system. Cleaning of the coolers and piping will still have to be done to optimize the efficiency of the system but the frequency of cleanings will be drastically reduced from the current operation.

Another benefit to the replace piping with corrosion resistant pipe solution is that no new equipment or design changes have to be made to the existing system, just replace the existing pipe.

As can be seen from the NPW analysis replacing the piping with corrosion resistant pipe has a NPW of \$218,064 and the other solution of continuing to operate like we have in the past has a NPW of \$152,494. The NPW of the solution to continue to operate as we have has a lower NPW. This NPW figure doesn't include replacing the existing piping with the same mild steel sch 40 pipe. The cost of labour to replace this pipe not including the pipe is \$52,000. If this figure was included into the NPW analysis these two solution would be very close.

The closed loop system has a NPW of \$213,427 making this solution on par with the other alternative solution of replacing the piping with corrosion resistant pipe. The problem with this solution is that it is add on to the existing cooling water system. Seeing that the service water piping is almost at its life expectancy the cost of replacing that piping has to also be considered. A quick calculation of labour costs just to replace the piping not including the pipe is around \$52,000.

With the closed loop solution the piping inside of the generator housing can be mild steel sch 40 pipe and the piping outside of the generator housing can be PVC to help reduce costs. This solution will use treated water for recirculating through the unit and use the existing service water to cool the heat exchangers.

The closed loop solution will have more components with the extra two recirculating pumps and heat exchangers. This increases the chances of more problems within the system. Also Hinds lake power house does not have much room to accommodate such a system.

The maintenance of the unit's coolers and piping will be non-existent but the outside heat exchanger will have to be cleaned. The frequency of this clean will have to be determined from operating the system. These outside heat exchangers should be positioned for easy cleaning.

The chemical injection solution has a NPW of \$473,956 which makes this solution not feasible compared to the other alternative solutions. Also any solution that doesn't impact the environment is always a better alternative.

It is recommended that we go with the solution of “replacing the piping with corrosion resistant pipe” for Hinds Lake. The pipe’s life expectancy within the service water system is coming to an end and will need to be replaced in the near future. With this alternative we still have the ability of replacing sections of the existing system year by year until it is all changed over, reducing the over all capital expenditure for that year. Also this solution will result in lower maintenance costs for the system. Another benefit is that no new design work has to be done in order for this solution to be implemented.

APPENDIX A

APPENDIX B

HLK

**BetzDearborn****WATER ANALYSIS REPORT**

4000018855
NEWFOUNDLAND & LABRADOR HYDRO
HOLYROOD GENERATING STATION
Holyrood, NF
Canada A0A 2-R0

Sampled: 21-AUG-2001
Reported: 04-SEP-2001
Field Rep: Finn, Edward
91000078

JMO/HLK

L0823125

pH	6.9
Specific Conductance, at 25°C, μmhos	25
Alkalinity, "P" as CaCO_3 , ppm	0
Alkalinity, "M" as CaCO_3 , ppm	7.1
Sulfur, Total, as SO_4 , ppm	< 5
Chloride, as Cl, ppm	3.4
Hardness, Total, as CaCO_3 , ppm	6.5
Calcium Hardness, Total, as CaCO_3 , ppm	4.6
Magnesium Hardness, Total, as CaCO_3 , ppm	1.9
Copper, Total, as Cu, ppm	0.05
Iron, Total, as Fe, ppm	4.3
Sodium, as Na, ppm	2.0
Phosphate, Total Inorganic, as PO_4 , ppm	< 0.2
Phosphate, Ortho-, as PO_4 , ppm	I
Phosphate, Filtered Ortho-, as PO_4 , ppm	< 0.2
Silica, Total, as SiO_2 , ppm	1.2

HLK



BetzDearborn

WATER ANALYSIS REPORT

4000018855
NEWFOUNDLAND & LABRADOR HYDRO
HOLYROOD GENERATING STATION
Holyrood, NF
Canada A0A 2-R0

Sampled: 21-AUG-2001
Reported: 04-SEP-2001
Field Rep: Finn, Edward
91000078

JMO/HLK

L0823125

Carbon, Total Organic, 2.4
as C, ppm

Color, Apparent, 140
Color Units (APHA)

HLK



BetzDearborn

WATER ANALYSIS REPORT

4000018855
NEWFOUNDLAND & LABRADOR HYDRO
HOLYROOD GENERATING STATION
Holyrood, NF
Canada A0A 2-R0

Sampled: 21-AUG-2001
Reported: 04-SEP-2001
Field Rep: Finn, Edward
91000078

Result Legend

I - A chemical or physical interference prevented the labs ability to perform this test.

APPENDIX C

**Corrosion Inhibitor Program
FLOGARD POT6101**

***Newfoundland Hydro
St. John's, Newfoundland***

October 10, 2001

Edward Finn
District Representative

BetzDearborn Canada Inc.
P.O. Box 1048
Carbonear, Newfoundland
A1Y 1C5
Tel: 709-596-3100
Fax: 709-596-1332

October 18, 2001

Newfoundland Hydro
P.O. Box 12400
St. Johns, NF
A1B 4K7

Attention: John Mallam

SUBJECT : Cooling Water Inhibitor Proposal

John,

Please find below our proposal to treat the once-thru cooling water systems in your Hydroelectric Station with our corrosion inhibitor – **Flogard POT6101**.

In short, we propose that you install a chemical injection and monitoring system to dose the system with 4 ppm of Flogard POT6101.

The annual cost of the chemical treatment, based on continuous operation, would be \$30,000.

We suggest, you monitor the effectiveness of the program by using corrosion coupons that simulate the corrosion in the system and are analyzed in our lab.

THEORY:

The recent set of water samples, taken by yourselves, were tested by our analytical lab in the USA. A short table comparing the important parameters in these tests is below. These have been communicated to you previously, but we show them here for completeness.

As well, we have calculated the Langelier index, which is calculated by a nomograph and is used in the water treatment industry as an overall indication of the scaling or corrosion tendency of any particular water.

Your waters all had a Langelier's index below -5.0 , so these waters would be described as "Very Corrosive". Therefore, the problems you have been experiencing with rust and corrosion are predictable and understandable. Fortunately, they are also preventable with proper chemical treatment.


TABLE 1

	HINDS LAKE	CAT ARM	UPPER SALMON	BAIE D'ESPOIR
Date	08/21/2001	08/04/2000	08/2001	08/2001
pH	5.9	5.1	5.1	6.2
Conductivity (mmhos)	25	91	24	13.7
'M' alkalinity (ppm)	0.7	< 2	< 2	2.1
Total Hardness (ppm)	6.5	6.5	3.4	3.8
Copper (ppm)	0.05	0.05	0.06	< 0.05
Iron (ppm)	4.3	0.79	0.17	0.08
TOC (ppm)	2.4	--	5.1	4.7
Langelier Index	- 5.1	- 5	- 5.3	- 5.5

The deposits that we analysed were also reported to you by e-mail. These deposits proved to be high in iron and manganese. The iron is from the rusted piping, while the manganese is chemically associated with the organic matter in the surface water supply. This manganese is noteworthy because it is found in deposits where the surface water is high in organics like these. Manganese does foul piping by depositing on the pipe wall rather than corrode. Fortunately, it is a problem that can be treated chemically.

In its simplest terms, corrosion is a reaction like the reactions that occur in a conventional lead - acid battery.

The Cathodic reaction is:



This reaction occurs in a low pH – acidic environment because of the relative abundance of H^+ .

The Anodic reaction is:



This reaction results in the loss of metal from the piping.

If you can stop these reactions from occurring, by stopping the flow of electrons, then the corrosion is stopped .

Chemical corrosion inhibitors basically fall into two broad classes: Anodic and Cathodic, depending on how they act. The product we propose, Flogard POT6101, contains both a Cathodic and an Anodic inhibitor. The phosphate in the product acts as a weak anodic inhibitor, by forming a loosely adhered film of iron phosphate - FePO_4 . The Cathodic inhibitor is zinc - Zn. As well, the zinc will sequester the manganese, which is currently causing fouling problems, so the problems with the manganese deposition will be significantly reduced.

PRODUCT:

Please see the Product Bulletin attached for the Inhibitor, which describes the inhibitor in detail. The product is available in both drums and 1136 kg semi - bulk tanks. I suggest, you obtain the product in these semi-bulk tanks. We have also attached product facts and its MSDS for your review.

PRICING:

The dosage is 4 ppm, based on the flow of the water. At an estimated flow rate of 600 imperial gallons per minute for 24 hrs per-day, 365 days per year, the consumption of the Flogard POT6101 is 7970 kgs per year.

The price of the Flogard POT6101 in these semi-bulk tanks is \$3.85/ kg FOB Pointe Claire, QC. Freight and taxes extra. Therefore, the annual cost of the chemical would be \$30,685. If the facility is run less than 100% of the time, then the consumption will be less - directly proportional to operating hours.

REFERENCES:

BetzDearborn currently treats many similar applications to yours in Atlantic Canada. References include:

Contacts:

Mr. Bob Cass
Manager of Water and Wastewater
City of Port Hawkesbury
Phone: 902-435-1494

Mr. Herve Richard
Chief Engineer
Noranda Inc.
Brunswick Mines
Phone: 506-546-6671

Mr. Pat Bellemare
Senior Operator
City of Dartmouth
Phone: 902-435-8300

WORK PLAN / SERVICE:

You should have on-site help from your chemical supplier to implement and monitor this chemical program, particularly since the references above needed to have the chemical introduced at a low concentration, which was gradually increased over several months.

As part of this proposal, we are offering as part of our service, 2-3 days of on-site service during start-up, followed by monthly visits for the first six months of the program and then twice yearly visits thereafter. This service is important. If the program is to succeed, operators need to be familiarized with testing procedures, corrosion coupon installation / changeout, the associated piping racks, chemical dosing pumps and chemical injection procedures and drawdowns. Site visits will be followed up by a written service report by BetzDearborn.

CHEMICAL FEED EQUIPMENT:

We have identified a chemical injection system, with a remote start / stop that would be suitable for this application (see the diagram attached). Prominant Fluid Controls can supply a dual metering pump skid, which can be automized to operate according to our needs. Options include:

- Duty and standby injection pumps.
- Flow switch to provide alarm if there is loss of chemical injection.
- Automatic switch over to stand-by pump in the event of duty pump failure.

The attached literature describes the Prominent options and provides a discussion matrix to select the chemical injection system to meet your application needs. We would be pleased to assist in selecting this system with Prominent. Budgetary cost for such a system would be \$5000.

CHEMICAL TESTING:

We suggest, you obtain a simple chemical test so that the operators can check the chemical concentration of PO_4 injected into the water. These chemical tests are straight forward and easy to use. Hach sells a simple PO_4 test (catalogue No. 2248-00), they are available from Atlantic Purification systems at 902-469-2806 and cost \$141.33 for a kit with 100 tests.

We will provide any instructions necessary for the operators to run this test. By using this test, we will ensure that the correct concentration of inhibitor is injected into the water.

CORROSION COUPONS:

As you are probably aware, corrosion coupons offer a method to quantitatively measure any reduction in the rate of corrosion over time. Coupons consist of a small strip of metal (either copper or mild steel) that measures approximately 50 x 10 x 5 mm and is inserted directly into the cooling water and left there for some time - typically 100 days. The coupons are then replaced and sent to the lab, where surface corrosion is noted. The weights before and after the in-service period are used to calculate a rate of corrosion in mil/year or g/ft² removed per year. Thus, the effectiveness of any corrosion reduction program can be evaluated quantitatively.

To ensure the results are reliable, the coupons must be installed properly and exposed to the correct flow rate. We recommend installation of a 1" diameter, iron corrosion rack, with flow control valve, Part No. 2029978. The cost of this unit is \$515.

Do not hesitate to contact me at 709-596-3100, if you would like to discuss our proposal.


Yours truly,
BetzDearborn



Edward Finn
District Representative

Cc: Shane White
Phil Millard
Yves Lefebvre

Enc.



Product Facts

FLOGARD™ POT6101 Potable Water Treatment

- NSF Approved for potable water
- Single-product liquid treatment
- Highly effective inhibitor

DESCRIPTION AND USE

FLOGARD™ POT6101 is a liquid blend of phosphate and zinc designed to inhibit corrosion of mild steel in mill supply water systems and once-through cooling systems. Corrosion control is accomplished by two mechanisms. At typical use levels, the major protection is due to the formation of a zinc-phosphate barrier film at the cathodic site of the corrosion cell. Phosphate also provides some additional corrosion protection by promoting the formation of a protective film at the anodic sites.

TREATMENT AND FEEDING REQUIREMENTS

The optimum dosage of FLOGARD POT6101 is a function of the corrosivity of the water to be treated and other conditions particular to a given installation. For best performance, this product should be fed continuously. While the typical feedrate is 4 - 20 ppm, this product is to be used in accordance with control procedures BetzDearborn establishes for a specific application and local potable water guidelines.

FLOGARD POT6101 may be fed directly from the shipping container or diluted to any convenient strength.

Tanks, pumps, piping and valves may be made of 316 stainless steel or most common plastics. Avoid the use of mild steel and copper alloys.

GENERAL PROPERTIES

Physical properties of FLOGARD POT6101 are shown on the Material Safety Data Sheet, a copy of which is available upon request.

PACKAGING INFORMATION

FLOGARD POT6101 is a liquid blend available in a variety of containers and delivery methods. Contact your BetzDearborn representative for details.


STORAGE

Protect from freezing. If this product is frozen during shipment or storage, slight mixing may be required to ensure homogeneity.

SAFETY PRECAUTIONS

A Material Safety Data Sheet containing detailed information about this product is available upon request.





ISSUE DATE: 16-JAN-2001

MATERIAL SAFETY DATA SHEET

BetzDearborn Canada, Inc.*
3451 Erindale Station Road
Mississauga, ON L5C 2S9
Business telephone: (905) 279-2222

EMERGENCY TELEPHONE (HEALTH/ACCIDENT)
(800) 963-5222 (Canada)

HMIS RATINGS
(See Section 16 for
additional information)
HEALTH: 3
FLAMMABILITY: 0
REACTIVITY: 0

*Hercules Canada, Inc. and BetzDearborn Canada, Inc. carrying on business as Hercules Canada

1 PRODUCT IDENTIFICATION

PRODUCT NAME:

FLOGARD POT6101

PRODUCT APPLICATION AREA:

CORROSION INHIBITOR.

2 COMPOSITION / INFORMATION ON INGREDIENTS

Information for specific product ingredients as required by the WHMIS Regulations is listed. Refer to additional sections of this MSDS for our assessment of the potential hazards of this formulation.

HAZARDOUS INGREDIENTS:

Cas#	Chemical Name	Range (w/w%)
7664-38-2	PHOSPHORIC ACID Corrosive ORAL LD50-RAT: 1,530 MG/KG DERMAL LD50-RABBIT: 2,740 MG/KG INHL. LC50: NO DATA.	15-40
7733-02-0	ZINC SULFATE Severe irritant; potential reproductive toxin ORAL LD50-RAT: 2,949 MG/KG DERMAL LD50: NO DATA. INHL. LC50: NO DATA.	15-40

No component is considered to be a carcinogen by the U.S. National Toxicology Program (NTP), the International Agency for Research on Cancer (IARC) or under WHMIS.

3 HAZARDS IDENTIFICATION

EMERGENCY OVERVIEW

Severe irritant to the skin. Corrosive to the eyes. Mists/aerosols cause irritation to the upper respiratory tract.

Odor: None; Appearance: Colorless, Liquid

Fire fighters should wear positive pressure self-contained breathing apparatus (full face-piece type). Proper fire-extinguishing media: dry chemical, carbon dioxide, foam or water

POTENTIAL HEALTH EFFECTS

ACUTE SKIN EFFECTS:

Primary route of exposure; Severe irritant to the skin.

ACUTE EYE EFFECTS:

Corrosive to the eyes.

ACUTE RESPIRATORY EFFECTS:

Primary route of exposure; Mists/aerosols cause irritation to the upper respiratory tract.

INGESTION EFFECTS:

May cause severe gastrointestinal irritation.

TARGET ORGANS:

Prolonged or repeated exposures may cause tissue necrosis. Product or product component may cause reproductive toxicity at maternal toxic levels (based on animal testing).

MEDICAL CONDITIONS AGGRAVATED:

Not known.

SYMPTOMS OF EXPOSURE:

Inhalation of vapors/mists/aerosols may cause eye, nose, throat and lung irritation. Skin contact may cause severe irritation or burns.

4 FIRST AID MEASURES

SKIN CONTACT:

Wash thoroughly with soap and water. Remove contaminated clothing. Thoroughly wash clothing before reuse. Get medical attention if irritation develops or persists.

EYE CONTACT:

URGENT! Immediately flush eyes with plenty of low-pressure water for at least 20 minutes while removing contact lenses. Hold eyelids apart. Get immediate medical attention.

INHALATION:

Remove to fresh air. If breathing is difficult, give oxygen. If breathing has stopped, give artificial respiration. Get immediate

medical attention.

INGESTION:

Do not feed anything by mouth to an unconscious or convulsive victim. Do not induce vomiting. Immediately contact physician. Dilute contents of stomach using 3-4 glasses milk or water.

NOTES TO PHYSICIANS:

No special instructions

5 FIRE FIGHTING MEASURES

FIRE FIGHTING INSTRUCTIONS:

Fire fighters should wear positive pressure self-contained breathing apparatus (full face-piece type).

EXTINGUISHING MEDIA:

dry chemical, carbon dioxide, foam or water

HAZARDOUS DECOMPOSITION PRODUCTS:

Thermal decomposition (destructive fires) yields elemental oxides.

FLASH POINT:

> 200F > 93C P-M(CC)

6 ACCIDENTAL RELEASE MEASURES

PROTECTION AND SPILL CONTAINMENT:

Ventilate area. Use specified protective equipment. Contain and absorb on absorbent material. Place in waste disposal container. Flush area with water. Wet area may be slippery. Spread sand/grit.

DISPOSAL INSTRUCTIONS:

The waste characteristics of the absorbed material, or any contaminated soil, should be determined in accordance with provincial regulations. Water contaminated with this product may be sent to a sanitary sewer treatment facility, in accordance with any local agreement or discharged under provincial regulations. Incinerate or land dispose in an approved landfill.

7 HANDLING & STORAGE

HANDLING:

Acidic. Corrosive(Metal). Do not mix with alkaline material.

STORAGE:

Keep containers closed when not in use. Use approved containers only. Store in cool, well-vented area. Contact with metals may release flammable hydrogen gas.

8 EXPOSURE CONTROLS / PERSONAL PROTECTION

EXPOSURE LIMITS

Consult local authorities for acceptable provincial values.

CHEMICAL NAME

PHOSPHORIC ACID

PEL (OSHA): 1 MG/M3

TLV (ACGIH): 1 MG/M3

ZINC SULFATE

PEL (OSHA): NOT DETERMINED

TLV (ACGIH): NOT DETERMINED

ENGINEERING CONTROLS:

Adequate ventilation to maintain air contaminants below exposure limits.

RESPIRATORY PROTECTION:

If air-purifying respirator use is appropriate, use a respirator with dust/mist filters.

SKIN PROTECTION:

rubber gloves-- Wash off after each use. Replace as necessary.

EYE PROTECTION:

splash proof chemical goggles

9 PHYSICAL & CHEMICAL PROPERTIES

Specific Grav. (70F, 21C)	1.398	Vapor Pressure (mmHG)	~ 18.0
Freeze Point (F)	-13	Vapor Density (air=1)	< 1.00
Freeze Point (C)	-25		
Viscosity(cps 70F, 21C)	10	% Solubility (water)	100.0

Odor	None
Appearance	Colorless
Physical State	Liquid
Flash Point	P-M(CC) > 200F > 93C
pH As Is (approx.)	1.4
Evaporation Rate (Ether=1)	< 1.00

NA = not applicable ND = not determined

10 STABILITY & REACTIVITY

STABILITY:

Stable under normal storage conditions.

HAZARDOUS POLYMERIZATION:

Will not occur.

INCOMPATIBILITIES:

May react with strong oxidizers.

DECOMPOSITION PRODUCTS:

Thermal decomposition (destructive fires) yields elemental oxides.

BETZDEARBORN INTERNAL PUMPOUT/CLEANOUT CATEGORIES:

"B"

11 TOXICOLOGICAL INFORMATION

Oral LD50 RAT: >2,000 mg/kg

NOTE - Estimated value

Dermal LD50 RABBIT: >2,000 mg/kg

NOTE - Estimated value

12 ECOLOGICAL INFORMATION

AQUATIC TOXICOLOGY

Rainbow Trout 96 Hour Static Acute Bioassay

LC50: 21.3 mg/L

No Effect Level: 15.5 mg/L

Daphnia magna 48 Hour Static Acute Bioassay *phyto gl. elon*

LC50: 3.8 mg/L

No Effect Level: 3.2 mg/L

Fathead Minnow 96 Hour Acute Toxicity

Product toxicity determined from bioassays conducted on individual components.

LC50: 16 mg/L

No Effect Level: 6.3 mg/L

BIODEGRADATION

No Data Available.

13 DISPOSAL CONSIDERATIONS

Incinerate or bury in approved landfill. Please be advised that there may be additional local or provincial requirements relating to the disposal of waste. Consult provincial and local regulations regarding the proper disposal of this material.

14 TRANSPORT INFORMATION

Transportation of Dangerous Goods:

Proper Shipping Name: Corrosive Liquids, n.o.s.
(Phosphoric Acid)

PIN: UN1760; Classification: 8(9.2); Packing Group: III

15 REGULATORY INFORMATION

This product has been classified in accordance with the hazard criteria of the CPR and the MSDS contains all the information required by the CPR.

CEPA:

All components of this product comply with substance notification requirements under CEPA.

WHMIS CLASSIFICATION:

D2A D2B E

FOOD AND DRUG ADMINISTRATION:

The ingredients in this product are Generally Recognized As Safe by FDA for direct addition to human food.

16 OTHER INFORMATION

NFPA/HMIS		CODE TRANSLATION
Health	3	Serious Hazard
Fire	0	Minimal Hazard
Reactivity	0	Minimal Hazard
Special	CORR	DOT corrosive
(1) Protective Equipment	B	Goggles, Gloves

(1) refer to section 8 of MSDS for additional protective equipment recommendations.

CHANGE LOG

	EFFECTIVE DATE -----	REVISIONS TO SECTION: -----	SUPERCEDES -----
MSDS status:	22-MAY-1998		** NEW **
	09-DEC-1998	15	22-MAY-1998
	23-MAR-2000	15	09-DEC-1998
	07-APR-2000	4	23-MAR-2000
	14-JUL-2000	15	07-APR-2000
	16-JAN-2001	14	14-JUL-2000

Prepared by the Regulatory Affairs Group, BetzDearborn Canada, Inc.
Telephone: 1(905)279-2222 Date of preparation: 16-JAN-2001

Corrosion Test Coupon Racks

BetzDearborn Corrosion Test Coupon Racks provide a convenient means of monitoring the progress of corrosion in systems such as boilers, condensate lines, open recirculating cooling water, closed circulating hot or chilled water systems, etc. The corrosion test rack creates a side stream off the main system in which corrosion test coupons can be exposed to system water under controlled and reproducible conditions.

The corrosion coupons can be periodically removed and either visually examined or returned to the laboratory for determination of weight loss, corrosion rate, and pitting severity.

BLACK IRON CORROSION RACK

The Black Iron Corrosion Rack is recommended for corrosion monitoring in high temperature and/or high-pressure installations such as steam condensate, high temperature water, hydronic heating, recirculating process systems, etc. The Black Iron Rack is constructed of 1" threaded black iron pipe. It is supplied with four 1" MNPT steel mounting plugs, and one 10 gpm Dole™ flow control valve. Caution: Maximum pressure & temperature are limited by the Dole flow control valve.

Maximum Pressure: 200 psig (13.8 bar)

Maximum Temperature: 160° F (71° C)

PVC CORROSION RACK

The PVC Corrosion Rack is recommended for corrosion monitoring in low temperature systems such as open recirculating cooling water systems, chilled




Figure 1

water, process water systems, etc. The PVC Rack is constructed of 1" threaded Sched. 80 PVC pipe. It is supplied with four 1" PVC mounting plugs and an 8 gpm Dole™ flow control valve. Two designs are available. One is constructed of all gray, opaque PVC. The other features transparent pipe sections for viewing the test coupons in place. See Figures 1 & 2. To discourage algae growth in the transparent sections, opaque snap-on pipe covering is supplied with this corrosion rack.

FLOW RATE	VELOCITY	
	1" PVC Rack	1" Black Iron Rack
5 gpm	2.2 ft/sec (0.67 m/sec)	1.9 ft/sec (0.58 m/sec)
8 gpm	3.6 ft/sec (1.1 m/sec)	3.0 ft/sec (0.91 m/sec)
10 gpm	4.5 ft/sec (1.4 m/sec)	3.7 ft/sec (1.3 m/sec)
12 gpm	5.4 ft/sec (1.6 m/sec)	4.4 ft/sec (1.4 m/sec)


Equipment Facts

MODULAR DOSING SYSTEM...

Function by Design

Offering industry a new standard in convenience, safety, and reliability. ProMinent's new modular design concept allows custom-tailored arrangements to suit your immediate needs. Matched with our exceptional line of chemical metering pumps - the functionality, flexibility, and performance you demand is yours today - all this at an industry-valued price.

ProMinent



Integrated Safe-Fill
Feature

Interconnect
Multiple Units

Easy Electrical
Tie-in

Convenient Venting to
Tank or Atmosphere

Drawdown Cylinder
for Accuracy

Convenient Mounting
Arrangements

Integrated Pressure
Safety Relief

Easy Pump
Removal

Single or Dual
(Back-up) Pump
Ready

Integrated Drain/
Flush Connection

MODULAR SELECTION... As Easy as 1-2-3

STEP ONE: Select Pump

Using Prominent's comprehensive catalog determine the pump capacity and pressure you require. Up to 2 pumps may be incorporated into a single package - dual pumps offer redundant function and convenience for continuous dosing. You may choose any of ProMinent's line of compact Solenoid-driven metering pumps - Concept, Beta, Gamma, Gala in most sizes and materials.

STEP TWO: Select Modules

Two modules are currently available. The Suction Module includes provision for up to 2 pumps - 1 primary, the other a backup. A calibration column for setting the pump for optimum performance, and all manual control valves required to isolate and service the system easily. The Discharge Module comes standard with integrated safety relief valve, our "Safe-Fill" feature, dual function Priming/Bleed valve and all necessary isolation valves. Just add any or all of the options below for added functionality and performance...

STEP THREE Select Options and Accessories

Select from a handful of safety and performance enhancements like...

- Pressure Gauge/Seal to accurately tune your system for the best results.
- Pulsation Dampener to improve flow characteristics and repeatability.
- Back Pressure Valve for better pump performance under variable conditions.
- Flow Monitor for flow confirmation.
- Convenient junction box for all system wiring.
- Mounting arrangement - wall-mount is standard, or you may choose floor stands or tote mount hanging brackets.

MOD A B C - D E F - G H I - J K L - M

A I/O Connection Size / Type	
1	1/2" FNPT

B Material Of Construction	
1	Schedule 80 PVC

C Elastomer	
1	EPDM
2	FPM (Viton)

D Suction Module	
1	Wall-mount Module with Back Panel includes Pump Shelf (1), Calibration Column (1), Ball Valves (3), and Pipe & Fittings

G Discharge Module	
0	Not Applicable
1	Wall-mount Module with Back Panel and "Safe-Fill" feature includes PRV (1), Ball Valves (3), and Pipe & Fittings

K Flow Monitor Option	
0	Not Applicable
1	Type 1 or 2 Flow Monitor (1), and Pipe & Fittings
2	Type 3 Flow Monitor (1) with Bypass includes Ball Valve (1) and Pipe & Fittings

E Calibration Column	
1	100 mL
2	500 mL
Multiply Pump Strokes per Minute by Pump mL per Second for 60 sec. drawdown	

H Pressure Gauge & Seal Kit	
0	Not Applicable
1	Kit includes Pressure Gauge with integral Seal (1), and Pipe & Fittings

L Back Panel Mount Option	
0	Not Applicable
1	Corrosion-resistant, Plastic Floor Mount
2	Corrosion-resistant, Stainless Steel Tote Mount

F Backup Pump Mount Kit	
0	Not Applicable
1	Kit includes Pump Shelf (1), Ball Valve (1), and Pipe & Fittings

I Pulsation Dampener Kit	
0	Not Applicable
1	Kit includes Pulsation Dampener (1), and Pipe & Fittings

M Junction Box Option	
0	Not Applicable
1	Option includes Prewired JB (1) for Single Pump
2	Option includes Prewired JB (1) for Dual Pump

J Back Pressure Valve Kit	
0	Not Applicable
1	Kit includes BPV (1), and Pipe & Fittings

Circle each number that applies to your configuration and enter above each letter location.

Viton® is a registered trademark of Dupont Dow Elastomers

Maximum Pressure: 200 psi at 70° F (13.8 bar at 21° C)
 120 psi at 120° F (6.9 bar at 49° C)
 70 psi at 140° F (4.8 bar at 60° C)

FLOW VS VELOCITY CHART

Velocities in **BOLD** indicate standard flow controller supplied with that rack. For other available Dole flow control valves, see Equipment Fact Sheet EF15-07.

OPTIONS

A Corratel™ probe may be installed in the corrosion rack to provide instantaneous corrosion readings to supplement the data provided by the weight loss corrosion coupons.

CORROSION TEST RACK INSTALLATION

1. The Corrosion Test Rack may be assembled for vertical mounting as shown in Figure 1, or a horizontal position, Figure 2. Items shown in single line schematic are not furnished.
2. Attach the corrosion rack to a wall or column. **DO NOT** suspend it from the supply and return piping alone.
3. To avoid air binding, pipe the corrosion rack so that water will flow upward through it, and in such a way that it will remain full of water at all times and not backdrain when the main recirculating system shuts down.
4. Install gate or ball-type isolation valves of both sides of the rack.
5. **DO NOT** use this bypass loop for any other purpose such as chemical injection, or mounting of conductivity or pH sensors.

6. For measurement of corrosion at points of highest temperature in the circulating system, the water supply to the corrosion rack should be from the exit of the heat exchanger(s). Average corrosion rate measurements may be obtained by supplying the corrosion rack with water from the main cooling tower riser, etc.
7. Return water may be piped to the recirculating pump suction header, cooling tower basin, or other suitable point with sufficiently low pressure to insure flow through the rack.
8. Flow velocities should not be variable. Avoid extremely high or low velocity conditions. A Dole™ or other suitable flow control valve is recommended to insure constant velocity.
9. For PVC Test Racks with transparent viewing sections, install the slotted polyfoam pipe insulation over the transparent sections to discourage algae growth.

CORROSION TEST COUPON INSTALLATION

1. Keep the metal test coupon in the special treated envelope **BEFORE AND AFTER** exposure.
2. **DO NOT** leave fingerprints on the coupon. They will cause false corrosion readings.
3. Attach the coupon to the mounting stud using the special nut and bolt provided.




Figure 2

4. Corrosion coupons should always be installed so the water flow first over the plastic mounting rod and then over the coupon. Water flowing directly onto the coupon may cause erosion-corrosion and lead to false weight loss measurements.
5. Use **ONLY** Teflon™ thread sealing tape on mounting plug threads. **DO NOT** use pipe dope.
6. The witness slot on the coupon mounting plug should be parallel with the flat surface of the corrosion test coupon. Install the mounting plug in the tee and align the witness slot (and coupon) in the **VERTICAL** position as shown in Figure 1.
7. Note the date of installation on back of the white Tyvek™ Coupon Return Envelope (ENG 322) and retain both the Coupon Return Envelope and the treated brown envelope.
8. When removing, each test coupon should be carefully dismantled from the holder and immediately dried with a blast of hot air or blotted with a paper towel or clean rag. **DO NOT CLEAN.** Reinsert the coupon in the treated brown envelope in which it was received.
9. Complete the back of the white Coupon Return Envelope, insert the treated brown envelopes with coupons inside, and return the envelope with the coupons to the Woodlands laboratory.

Part Numbers

2013971 Corrosion Rack, PVC, 1" NPT, w/ 4 coupon holders & 8 gpm flow control valve.

2042205 Corrosion Rack, PVC, 1" NPT w/ 4 coupon holders, 8 gpm valve and 4 TRANSPARENT viewing sections.


2029978 Corrosion Rack, Black Iron, 1" NPT, w/ 4 coupon holders & 10 gpm flow control valve.


2032806 Corrosion Rack, 304 SS, 1" NPT, w/ 4 coupon holders.

2015850 Replacement Coupon Holder, 1" PVC w/ 6" stem.

2041977 Replacement Coupon Holder, 1" Black Iron w/ 6" Teflon™ Stem and Teflon nut & Screw

Corrosion test coupons and mounting screws are not supplied with the corrosion rack and must be ordered separately from the BetzDearborn Woodlands, TX laboratory.





APPENDIX D


DO NOTHING

Capital Cost	
Total	0

Operating Cost	
Pump consumption (49 weeks)	\$11,936
Clean SAC (10 yr)	\$5,743
Clean SAC Piping (10 yr)	\$4,627
Clean L Gen Brg Coolers (5 yr)	\$6,759
Clean L Gen Brg Cooler Piping (10)	\$3,508
Clean U Gen Brg Cooler Piping (10)	\$3,508

	Year	Cash Flow	NPW
0	2002	\$11,936	\$11,936
1	2003	\$12,175	\$21,344
2	2004	\$12,419	\$31,066
3	2005	\$12,667	\$40,206
4	2006	\$12,920	\$48,799
5	2007	\$20,641	\$61,451
6	2008	\$13,442	\$69,045
7	2009	\$13,711	\$76,184
8	2010	\$13,985	\$82,895
9	2011	\$14,265	\$89,204
10	2012	\$43,983	\$107,133
11	2013	\$14,841	\$112,709
12	2014	\$15,138	\$117,951
13	2015	\$15,441	\$122,879
14	2016	\$15,750	\$127,512
15	2017	\$25,161	\$134,333
16	2018	\$16,386	\$138,427
17	2019	\$16,714	\$142,276
18	2020	\$17,048	\$145,894
19	2021	\$17,389	\$149,296
20	2022	\$17,737	\$152,494

Net Present Worth




REPLACE PIPING

Capital Cost	
SAC Piping (Parts & Installation)	\$27,491
Gen U Brg Piping (Parts & Installation)	\$5,623
Gen L Brg Piping (Parts & Installation)	\$27,547
Inlet Piping (Parts & Installation)	\$15,060
Discharge Piping (Parts & Installation)	\$16,079
Total	\$91,800

Operating Cost	
Pump consumption (49 weeks)	\$11,936

	Year	Cash Flow	NPW
0	2002	\$103,737	\$103,737
1	2003	\$12,175	\$105,952
2	2004	\$12,419	\$115,675
3	2005	\$12,667	\$124,815
4	2006	\$12,920	\$133,407
5	2007	\$13,179	\$141,485
6	2008	\$13,442	\$149,079
7	2009	\$13,711	\$156,218
8	2010	\$13,985	\$162,930
9	2011	\$14,265	\$169,239
10	2012	\$14,550	\$175,170
11	2013	\$14,841	\$180,746
12	2014	\$15,138	\$185,988
13	2015	\$15,441	\$190,916
14	2016	\$15,750	\$195,548
15	2017	\$16,065	\$199,904
16	2018	\$16,386	\$203,998
17	2019	\$16,714	\$207,847
18	2020	\$17,048	\$211,465
19	2021	\$17,389	\$214,867
20	2022	\$17,737	\$218,064

Net Present Worth




CLOSED LOOP SYSTEM

Capital Cost	
Pump	\$5,345
Heat Exchanger	\$17,500
Installation Piping & Hardware	\$8,000
Total	\$30,845

Operating Cost	
Pump consumption (49 weeks)	\$11,936
Recir Pump Consumption (49 weeks)	\$4,610

	Year	Cash Flow	NPW
0	2002	\$47,391	\$47,391
1	2003	\$16,877	\$58,015
2	2004	\$17,215	\$71,493
3	2005	\$17,559	\$84,163
4	2006	\$17,910	\$96,074
5	2007	\$18,269	\$107,272
6	2008	\$18,634	\$117,799
7	2009	\$19,007	\$127,695
8	2010	\$19,387	\$136,998
9	2011	\$19,774	\$145,744
10	2012	\$20,170	\$153,966
11	2013	\$20,573	\$161,696
12	2014	\$20,985	\$168,962
13	2015	\$21,405	\$175,793
14	2016	\$21,833	\$182,215
15	2017	\$22,269	\$188,252
16	2018	\$22,715	\$193,928
17	2019	\$23,169	\$199,263
18	2020	\$23,632	\$204,279
19	2021	\$24,105	\$208,994
20	2022	\$24,587	\$213,427

Net Present Worth




CHEMICAL INJECTION

Capital Cost	
Injection System	\$5,000
Test Coupon Rack	\$515
Total	\$5,515

Operating Cost	
Pump consumption (49 weeks)	\$11,936
Chemical (49 weeks)	\$30,000

	Year	Cash Flow	NPW
0	2002	\$47,451	\$47,451
1	2003	\$42,775	\$80,070
2	2004	\$43,631	\$114,228
3	2005	\$44,503	\$146,341
4	2006	\$45,393	\$176,529
5	2007	\$46,301	\$204,909
6	2008	\$47,227	\$231,589
7	2009	\$48,172	\$256,671
8	2010	\$49,135	\$280,250
9	2011	\$50,118	\$302,416
10	2012	\$51,120	\$323,255
11	2013	\$52,143	\$342,845
12	2014	\$53,185	\$361,261
13	2015	\$54,249	\$378,574
14	2016	\$55,334	\$394,850
15	2017	\$56,441	\$410,151
16	2018	\$57,570	\$424,536
17	2019	\$58,721	\$438,058
18	2020	\$59,896	\$450,771
19	2021	\$61,093	\$462,722
20	2022	\$62,315	\$473,956

Net Present Worth



APPENDIX E

Labour Costs, H4k

Upper Gen Piping (2")

Estimate	Actual	
	<u>crew</u>	<u>days</u>
Sch 10, black, 2"	1 PLUM	43'
90 & 45° Elbows, 2"	1 PLUM	25
Coupling, 2"	1 PLUM	50
Flange, 2"	1 PLUM	23
Wall Grove, 2"	Q1	116

Time required for 1 PLUM = 2.69 days

Add Additional Labour reduces time by 25%, $2.69 \times 0.75 = \overset{2.02}{\cancel{2.02}}$ days

Time required for Q1 crew = 0.24 days

Total time for 2 Labours = 2.26 days (18.1 hrs)

~~Additional time required to remove old piping $2.26 \times 1.25 = 0.34$ days~~

~~Total time for job = 2.6 days~~

~~Additional time due to pipe location & space restrictions $2.6 \times 1.25 = 3.25$ days~~
~~(28 hrs)~~

Labour Costs, Hk

$$(Q_1 = 1 \text{ Plm.} + 1 \text{ App.})$$

Lower Gen Piping (3", 2½", & 2")

Estimate

Actual


	Crew	days	Quantity	Days
Sub 10, black, 3"	Q ₁	55'	20'	0.36
Sub 10, black, 2½"	Q ₁	61'	80'	1.31
Sub 10, black, 2"	1 Plm.	43'	40'	0.93
10' 22½" Elbow, 2½"	Q ₁	40	24	0.60
1' Elbow 2"	1 Plm.	25	24	0.96
2 2½"	Q ₁	27	2	0.07
2 2½" x 2"	Q ₁	28	8	0.29
pliny 3"	Q ₁	67	2	0.03
2 2½"	Q ₁	80	70	0.875
pliny 2"	1 Plm.	50	80	1.6
10' 2½" x 2"	Q ₁	82	4	0.05
10' 3" x 2½"	Q ₁	74	2	0.03
10' 3"	Q ₁	31	2	0.06
10' 2"	1 Plm.	23	12	0.52
10' 2"	1 Plm.	38	12	0.32
10' 3"	Q ₁	100	4	0.04
10' 2½"	Q ₁	110	84	0.76
10' 2"	Q ₁	116	48	0.41

Time Required for 1 Plm. = 4.33 days

Add Additional Labour reduces time by 25% ∴ $4.33 \times 0.75 = 3.25$ days

Time Required for 1 Q crew = 4.89 days

Total Time for 2 Labourers = $4.89 + 3.25 = 8.14$ days (65.1 hrs)



Inlet

Total Pipe

$$\begin{aligned}
 1.0 \times 4 &= 4.0' \\
 1.2 \times 8 &= 9.6' \\
 3.5 \times 1 &= 3.5' \\
 5.0 \times 2 &= 10.0' \\
 5.7 \times 2 &= 11.4'
 \end{aligned}$$

38.5'

USE 60 Long Radius Elbows.

Flexible Coupling Style 77 39

2" 4
2 1/2" 35



EL 28.287

SUPPLIED BY CONTRACTOR

SUPPLIED BY MECHANICAL CONTRACTOR

UPSTREAM SIDE

HIGH PRESSURE
VALVE
(BY HITACHI)

STEP

HIGH PRESSURE
M. EQUIPMENT
(BY HITACHI)

AIR COOLER #1

DUCT 18

SPACE AND JACK

AIR COOLER #2

AIR COOLER #3

SPACE HEATER #6

EL 27.707

H.G.R. CUBICLE

OIL LEVEL GAUGE
AND SWITCH
(BY HITACHI)

AIR RELEASE


CONNECTING
PIPING

ML BOLT

VECTING
ING

BTHRS

CONCRETE



Labour Costs, HLC

SAC Piping (4" & 3")

Q1 crew = 1 Plumber & 1 Apprentice

Estimate			Actual	
Description	Crew	Day	Quantity	Day
Sch 10, black, 3"	Q1	55'	40'	0.73
Sch 10, black, 4"	Q1	49'	240'	4.90
90° & 45° Elbows, 4"	Q1	25	13	0.52
90° & 45° Elbows, 3"	Q1	33	22	0.67
Tee, 4"	Q1	17	1	0.06
Tee, 4" x 3"	Q1	18	4	0.22
Coupling Flee, 3"	Q1	67	64	0.96
Coupling Flee, 4"	Q1	50	64	1.28
Flange, 3"	Q1	31	8	0.26
Flange, 4"	Q1	23	3	0.13
Valve, 3"	Q1	50	8	0.16
Roll Grooving, 3"	Q1	100	34	0.34
Roll Grooving, 4"	Q1	86	53	0.62

Total Time required for Q1 crew. 3

= 10.85 days (86.8 hrs)

15100 | Building Services Piping

15107 | Metal Pipe & Fittings

		CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL. O&P
						MAT.	LABOR	EQUIP.	TOTAL	
9342	4" to 8" pipe, 6" stem	1 Plum	14	.571	Ea.	38.50	19		57.50	71
9343	8" pipe and larger, 6" stem	"	13	.615	"	38.50	20.50		59	73.50
9400	Mechanical joint ends for plain end pipe									
9410	Malleable iron, black									
9420	90° Elbows, 1-1/4"	Q-1	29	.552	Ea.	9.30	16.50		25.80	35.50
9430	1-1/2"	↓	27	.593	↓	10.20	17.75		27.95	38
9440	2"	↓	24	.667	↓	12.05	19.95		32	43.50
9490	Tee, reducing outlet									
9510	1-1/4" x 1/2"	Q-1	18	.889	Ea.	7.45	26.50		33.95	48.50
9520	1-1/4" x 3/4"	↓	18	.889	↓	7.45	26.50		33.95	48.50
9530	1-1/4" x 1"	↓	18	.889	↓	7.45	26.50		33.95	48.50
9540	1-1/2" x 1/2"	↓	17	.941	↓	7.90	28		35.90	51
9550	1-1/2" x 3/4"	↓	17	.941	↓	7.90	28		35.90	51
9560	1-1/2" x 1"	↓	17	.941	↓	7.90	28		35.90	51
9570	2" x 1/2"	↓	15	1.067	↓	9.65	32		41.65	59
9580	2" x 3/4"	↓	15	1.067	↓	9.65	32		41.65	59
9590	2" x 1"	↓	15	1.067	↓	9.65	32		41.65	59
9640	Tee, reducing run and outlet									
9660	1-1/4" x 1" x 1/2"	Q-1	18	.889	Ea.	7.95	26.50		34.45	49.50
9670	1-1/4" x 1" x 3/4"	↓	18	.889	↓	7.95	26.50		34.45	49.50
9680	1-1/4" x 1" x 1"	↓	18	.889	↓	7.95	26.50		34.45	49.50
9690	1-1/2" x 1-1/4" x 1/2"	↓	17	.941	↓	8.45	28		36.45	52
9700	1-1/2" x 1-1/4" x 3/4"	↓	17	.941	↓	8.45	28		36.45	52
9710	1-1/2" x 1-1/4" x 1"	↓	17	.941	↓	8.45	28		36.45	52
9720	2" x 1-1/2" x 1/2"	↓	15	1.067	↓	10.25	32		42.25	60
9730	2" x 1-1/2" x 3/4"	↓	15	1.067	↓	10.25	32		42.25	60
9740	2" x 1-1/2" x 1"	↓	15	1.067	↓	10.25	32		42.25	60
9790	Tee, outlet									
9810	3" x 1-1/4"	Q-1	29	.552	Ea.	18.05	16.50		34.55	45
9820	3" x 1-1/2"	↓	28	.571	↓	18.05	17.10		35.15	46
9830	3" x 2"	↓	26	.615	↓	20	18.40		38.40	50
9840	4" x 1-1/4"	↓	28	.571	↓	22.50	17.10		39.60	50.50
9850	4" x 1-1/2"	↓	26	.615	↓	23.50	18.40		41.90	54
9860	4" x 2"	↓	24	.667	↓	23.50	19.95		43.45	56
9940	For galvanized fittings for plain end pipe, add					20%				
690	0010 PIPE, GROOVED-JOINT STEEL FITTINGS & VALVES									
0020	Pipe includes coupling & clevis type hanger 10' O.C.									
0500	Schedule 10, black									
0550	2" diameter	1 Plum	43	.186	L.F.	3.02	6.20		9.22	12.65
0560	2-1/2" diameter	Q-1	61	.262		3.65	7.85		11.50	15.90
0570	3" diameter	↓	55	.291		4.18	8.70		12.88	17.75
0580	3-1/2" diameter	↓	53	.302		5.35	9.05		14.40	19.55
0590	4" diameter	↓	49	.327		5.65	9.75		15.40	21
0600	5" diameter	↓	40	.400	↓	8.95	11.95		20.90	28
0610	6" diameter	Q-2	46	.522	↓	9.60	16.20		25.80	35
0620	8" diameter	"	41	.585	↓	18.45	18.15		36.60	48
0700	To delete couplings & hangers, subtract									
0710	2" diam. to 5" diam.					25%	20%			
0720	6" diam. to 8" diam.					27%	15%			
1000	Schedule 40, black									
1040	3/4" diameter	1 Plum	71	.113	L.F.	2.04	3.75		5.79	7.90
1050	1" diameter	↓	63	.127	↓	2.17	4.22		6.39	8.80
1060	1-1/4" diameter	↓	58	.138	↓	2.64	4.59		7.23	9.85
1070	1-1/2" diameter	↓	51	.157	↓	2.97	5.20		8.17	11.15
1080	2" diameter	↓	40	.200	↓	3.46	6.65		10.11	13.85

15100 | Building Services Piping

15107 Metal Pipe & Fittings		CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
1090	2-1/2" diameter	Q-1	57	.281	L.F.	4.68	8.40		13.08	17.85
1100	3" diameter	↓	50	.320	↓	5.70	9.60		15.30	21
1110	4" diameter		45	.356		8.05	10.65		18.70	25
1120	5" diameter	↓	37	.432		12.40	12.95		25.35	33
1130	6" diameter	Q-2	42	.571		15.90	17.75		33.65	44.50
1140	8" diameter		37	.649		23.50	20		43.50	56.50
1150	10" diameter		31	.774		36	24		60	76
1160	12" diameter		27	.889		47.50	27.50		75	93.50
1170	14" diameter		20	1.200		56	37		93	118
1180	16" diameter		17	1.412		79.50	44		123.50	154
1190	18" diameter		14	1.714		142	53		195	237
1200	20" diameter		12	2		108	62		170	213
1210	24" diameter	↓	10	2.400	↓	128	74.50		202.50	254
1740	To delete coupling & hanger, subtract									
1750	3/4" diam. to 2" diam.						35%	27%		
1760	2-1/2" diam. to 5" diam.						18%	18%		
1770	6" diam. to 12" diam.						14%	13%		
1800	Galvanized									
1840	3/4" diameter	1 Plum	71	.113	L.F.	2.27	3.75		6.02	8.15
1850	1" diameter	↓	63	.127	↓	2.34	4.22		6.56	9
1860	1-1/4" diameter		58	.138		2.85	4.59		7.44	10.10
1870	1-1/2" diameter		51	.157		3.23	5.20		8.43	11.45
1880	2" diameter	↓	40	.200		3.81	6.65		10.46	14.25
1890	2-1/2" diameter	Q-1	57	.281		5.25	8.40		13.65	18.45
1900	3" diameter		50	.320		6.40	9.60		16	21.50
1910	4" diameter		45	.356		9.10	10.65		19.75	26
1920	5" diameter	↓	37	.432		15.25	12.95		28.20	36.50
1930	6" diameter	Q-2	42	.571		19.80	17.75		37.55	49
1940	8" diameter		37	.649		29.50	20		49.50	63
1950	10" diameter		31	.774		44	24		68	85
1960	12" diameter	↓	27	.889	↓	58	27.50		85.50	106
2540	To delete coupling & hanger, subtract									
2550	3/4" diam. to 2" diam.						36%	27%		
2560	2-1/2" diam. to 5" diam.						19%	18%		
2570	6" diam. to 12" diam.						14%	13%		
2600	Schedule 80, black									
2610	3/4" diameter	1 Plum	65	.123	L.F.	2.31	4.09		6.40	8.75
2650	1" diameter	↓	61	.131	↓	2.50	4.36		6.86	9.35
2660	1-1/4" diameter		55	.145		3.12	4.84		7.96	10.75
2670	1-1/2" diameter		49	.163		3.57	5.45		9.02	12.15
2680	2" diameter	↓	38	.211		4.35	7		11.35	15.40
2690	2-1/2" diameter	Q-1	54	.296		5.95	8.85		14.80	19.90
2700	3" diameter		48	.333		7.45	10		17.45	23.50
2710	4" diameter		44	.364		10.75	10.90		21.65	28.50
2720	5" diameter	↓	35	.457		12.55	13.70		26.25	34.50
2730	6" diameter	Q-2	40	.600		20.50	18.60		39.10	50.50
2740	8" diameter		35	.686		47.50	21.50		69	84.50
2750	10" diameter		29	.828		75.50	25.50		101	122
2760	12" diameter	↓	24	1	↓	83.50	31		114.50	139
3240	To delete coupling & hanger, subtract									
3250	3/4" diam. to 2" diam.						30%	25%		
3260	2-1/2" diam. to 5" diam.						14%	17%		
3270	6" diam. to 12" diam.						12%	12%		
3300	Galvanized									
3310	3/4" diameter	1 Plum	65	.123	L.F.	2.01	4.09		6.10	8.40
3350	1" diameter	↓	61	.131	↓	2.06	4.36		6.42	8.85



MECHANICAL 15

15100 | Building Services Piping

15107 Metal Pipe & Fittings		CREW	DAILY OUTPUT	LABOR-HOURS	UNIT	2000 BARE COSTS				TOTAL INCL. O&P
						MAT.	LABOR	EQUIP.	TOTAL	
3360	1-1/4" diameter	1 Plum	55	.145	L.F.	2.51	4.84		7.35	10.05
3370	1-1/2" diameter	↓	46	.174		2.83	5.80		8.63	11.85
3380	2" diameter	↓	38	.211		3.26	7		10.26	14.20
3390	2-1/2" diameter	Q-1	54	.296		4.25	8.85		13.10	18.05
3400	3" diameter	↓	48	.333		5.25	10		15.25	21
3410	4" diameter	↓	44	.364		7.55	10.90		18.45	25
3420	5" diameter	↓	35	.457		15.45	13.70		29.15	37.50
3430	6" diameter	Q-2	40	.600		26.50	18.60		45.10	57.50
3440	8" diameter	↓	35	.686		46	21.50		67.50	82.50
3450	10" diameter	↓	29	.828		73	25.50		98.50	120
3460	12" diameter	↓	24	1	↓	81	31		112	136
3920	To delete coupling & hanger, subtract									
3930	3/4" diam. to 2" diam.					30%	25%			
3940	2-1/2" diam. to 5" diam.					15%	17%			
3950	6" diam. to 12" diam.					11%	12%			
3990	Fittings: cplg. & labor required at joints not incl. in fitting									
3994	price. Add 1 per joint for installed price.									
4000	Elbow, 90° or 45°, painted									
4030	3/4" diameter	1 Plum	50	.160	Ea.	12.10	5.30		17.40	21.50
4040	1" diameter	↓	50	.160		12.10	5.30		17.40	21.50
4050	1-1/4" diameter	↓	40	.200		12.10	6.65		18.75	23.50
4060	1-1/2" diameter	↓	33	.242		12.10	8.05		20.15	25.50
4070	2" diameter	↓	25	.320		12.10	10.65		22.75	29.50
4080	2-1/2" diameter	Q-1	40	.400		12.10	11.95		24.05	31.50
4090	3" diameter	↓	33	.485		21.50	14.50		36	45.50
4100	4" diameter	↓	25	.640		23.50	19.15		42.65	55
4110	5" diameter	↓	20	.800		56.50	24		80.50	98.50
4120	6" diameter	Q-2	25	.960		66.50	30		96.50	118
4130	8" diameter	↓	21	1.143		139	35.50		174.50	207
4140	10" diameter	↓	18	1.333		254	41.50		295.50	340
4150	12" diameter	↓	15	1.600		405	49.50		454.50	520
4170	14" diameter	↓	12	2		725	62		787	895
4180	16" diameter	↓	11	2.182		945	67.50		1,012.50	1,150
4190	18" diameter	Q-3	15	2.133		1,200	67.50		1,267.50	1,425
4200	20" diameter	↓	13	2.462		1,575	78		1,653	1,875
4210	24" diameter	↓	11	2.909		2,300	92.50		2,392.50	2,675
4250	For galvanized elbows, add									
4690	Tee, painted									
4700	3/4" diameter	1 Plum	38	.211	Ea.	18.65	7		25.65	31
4740	1" diameter	↓	33	.242		18.65	8.05		26.70	32.50
4750	1-1/4" diameter	↓	27	.296		18.65	9.85		28.50	35.50
4760	1-1/2" diameter	↓	22	.364		18.65	12.10		30.75	39
4770	2" diameter	↓	17	.471		18.65	15.65		34.30	44
4780	2-1/2" diameter	Q-1	27	.593		18.65	17.75		36.40	47.50
4790	3" diameter	↓	22	.727		26	22		48	62
4800	4" diameter	↓	17	.941		40	28		68	86.50
4810	5" diameter	↓	13	1.231		93.50	37		130.50	159
4820	6" diameter	Q-2	17	1.412		108	44		152	186
4830	8" diameter	↓	14	1.714		238	53		291	345
4840	10" diameter	↓	12	2		495	62		557	640
4850	12" diameter	↓	10	2.400		690	74.50		764.50	875
4851	14" diameter	↓	9	2.667		730	83		813	930
4852	16" diameter	↓	8	3		825	93		918	1,050
4853	18" diameter	Q-3	11	2.909		1,025	92.50		1,117.50	1,275
4854	20" diameter	↓	10	3.200		1,475	101		1,576	1,775
4855	24" diameter	↓	8	4	↓	2,250	127		2,377	2,675

15107 | Metal Pipe & Fittings

		CREW	DAILY OUTPUT	LABOR-HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
4900	For galvanized tees, add				Ea.	24%				690
4906	Couplings, rigid style, painted									
4908	1" diameter	1 Plum	100	.080	Ea.	8.80	2.66		11.46	13.65
4909	1-1/4" diameter	↓	100	.080		8.80	2.66		11.46	13.65
4910	1-1/2" diameter		67	.119		8.80	3.97		12.77	15.65
4912	2" diameter	↓	50	.160		9	5.30		14.30	17.95
4914	2-1/2" diameter	Q-1	80	.200		10.40	6		16.40	20.50
4916	3" diameter	↓	67	.239		12.15	7.15		19.30	24
4918	4" diameter		50	.320		17.20	9.60		26.80	33.50
4920	5" diameter	↓	40	.400		22.50	11.95		34.45	42.50
4922	6" diameter	Q-2	50	.480		30	14.90		44.90	55.50
4924	8" diameter	↓	42	.571		47	17.75		64.75	78.50
4926	10" diameter		35	.686		84	21.50		105.50	125
4928	12" diameter	↓	32	.750		94.50	23.50		118	139
4930	14" diameter		24	1		123	31		154	182
4931	16" diameter		20	1.200		161	37		198	234
4932	18" diameter	↓	18	1.333		186	41.50		227.50	267
4933	20" diameter	↓	16	1.500		221	46.50		267.50	315
4934	24" diameter	Q-9	13	1.231	↓	325	36		361	415
4940	Flexible, standard, painted									
4950	3/4" diameter	1 Plum	100	.080	Ea.	6.30	2.66		8.96	10.95
4960	1" diameter	↓	100	.080		6.30	2.66		8.96	10.95
4970	1-1/4" diameter		80	.100		8.40	3.33		11.73	14.30
4980	1-1/2" diameter	↓	67	.119		9.20	3.97		13.17	16.10
4990	2" diameter	Q-1	50	.160		9.70	5.30		15	18.70
5000	2-1/2" diameter	↓	80	.200		11.60	6		17.60	22
5010	3" diameter		67	.239		12.80	7.15		19.95	25
5020	3-1/2" diameter	↓	57	.281		18.70	8.40		27.10	33
5030	4" diameter		50	.320		18.70	9.60		28.30	35
5040	5" diameter	↓	40	.400		28.50	11.95		40.45	49.50
5050	6" diameter	Q-2	50	.480		34	14.90		48.90	60
5070	8" diameter	↓	42	.571		55.50	17.75		73.25	88
5090	10" diameter		35	.686		92	21.50		113.50	133
5110	12" diameter	↓	32	.750		105	23.50		128.50	150
5120	14" diameter		24	1		127	31		158	187
5130	16" diameter	↓	20	1.200		167	37		204	240
5140	18" diameter		18	1.333		195	41.50		236.50	278
5150	20" diameter	↓	16	1.500		305	46.50		351.50	410
5160	24" diameter	↓	13	1.846	↓	335	57.50		392.50	455
5176	Lightweight style, painted									
5178	1-1/2" diameter	1 Plum	67	.119	Ea.	8	3.97		11.97	14.80
5180	2" diameter	"	50	.160		8.20	5.30		13.50	17.05
5182	2-1/2" diameter	Q-1	80	.200		9.50	6		15.50	19.50
5184	3" diameter	↓	67	.239		11.05	7.15		18.20	23
5186	3-1/2" diameter		57	.281		15.65	8.40		24.05	30
5188	4" diameter	↓	50	.320		15.65	9.60		25.25	31.50
5190	5" diameter	Q-2	40	.400		22.50	11.95		34.45	43
5192	6" diameter	↓	50	.480		27	14.90		41.90	52.50
5194	8" diameter		42	.571		42.50	17.75		60.25	74
5196	10" diameter	↓	35	.686		115	21.50		136.50	158
5198	12" diameter	↓	32	.750	↓	128	23.50		151.50	176
5200	For galvanized couplings, add				↓	33%				
5220	Tee, reducing, painted									
5225	2" x 1-1/2" diameter	Q-1	38	.421	Ea.	40.50	12.60		53.10	63.50
5226	2-1/2" x 2" diameter	↓	28	.571	↓	40.50	17.10		57.60	70.50
5227	3" x 2-1/2" diameter	↓	23	.696	↓	35.50	21		56.50	70.50



15100 | Building Services Piping

15107 Metal Pipe & Fittings			CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
							MAT.	LABOR	EQUIP.	TOTAL	
590	5228	4" x 3" diameter	Q-1	18	.889	Ea.	48	26.50		74.50	93.50
	5229	5" x 4" diameter	↓	15	1.067		103	32		135	163
	5230	6" x 4" diameter	Q-2	18	1.333		114	41.50		155.50	188
	5231	8" x 6" diameter	↓	15	1.600		238	49.50		287.50	335
	5232	10" x 8" diameter	↓	13	1.846		310	57.50		367.50	430
	5233	12" x 10" diameter	↓	11	2.182		475	67.50		542.50	625
	5234	14" x 12" diameter	↓	10	2.400		530	74.50		604.50	700
	5235	16" x 12" diameter	↓	9	2.667		660	83		743	850
	5236	18" x 12" diameter	Q-3	12	2.667		790	84.50		874.50	1,000
	5237	18" x 16" diameter	↓	11	2.909		1,000	92.50		1,092.50	1,250
	5238	20" x 16" diameter	↓	10	3.200		1,300	101		1,401	1,575
	5239	24" x 20" diameter	↓	9	3.556	↓	2,050	113		2,163	2,450
	5240	Reducer, concentric, painted									
	5241	2-1/2" x 2" diameter	Q-1	43	.372	Ea.	14.10	11.15		25.25	32.50
	5242	3" x 2-1/2" diameter	↓	35	.457		17.05	13.70		30.75	39.50
	5243	4" x 3" diameter	↓	29	.552		20.50	16.50		37	47.50
	5244	5" x 4" diameter	↓	22	.727		29	22		51	64.50
	5245	6" x 4" diameter	Q-2	26	.923		33.50	28.50		62	80
	5246	8" x 6" diameter	↓	23	1.043		87.50	32.50		120	145
	5247	10" x 8" diameter	↓	20	1.200		178	37		215	253
	5248	12" x 10" diameter	↓	16	1.500	↓	320	46.50		366.50	420
	5255	Eccentric, painted									
	5256	2-1/2" x 2" diameter	Q-1	42	.381	Ea.	30	11.40		41.40	50.50
	5257	3" x 2-1/2" diameter	↓	34	.471		34	14.10		48.10	59
	5258	4" x 3" diameter	↓	28	.571		42	17.10		59.10	72
	5259	5" x 4" diameter	↓	21	.762		57	23		80	97
	5260	6" x 4" diameter	Q-2	25	.960		66.50	30		96.50	118
	5261	8" x 6" diameter	↓	22	1.091		135	34		169	199
	5262	10" x 8" diameter	↓	19	1.263		370	39		409	470
	5263	12" x 10" diameter	↓	15	1.600	↓	510	49.50		559.50	635
	5270	Coupling, reducing, painted									
	5272	2" x 1-1/2" diameter	1 Plum	52	.154	Ea.	14.20	5.10		19.30	23.50
	5274	2-1/2" x 2" diameter	Q-1	82	.195		18.55	5.85		24.40	29.50
	5276	3" x 2" diameter	↓	69	.232		21	6.95		27.95	34
	5278	4" x 2" diameter	↓	52	.308		34	9.20		43.20	51.50
	5280	5" x 4" diameter	↓	42	.381		38.50	11.40		49.90	59.50
	5282	6" x 4" diameter	Q-2	52	.462		58	14.30		72.30	85.50
	5284	8" x 6" diameter	"	44	.545	↓	87	16.95		103.95	122
	5290	Outlet coupling, painted									
	5294	1-1/2" x 1" pipe size	1 Plum	65	.123	Ea.	17.70	4.09		21.79	25.50
	5296	2" x 1" pipe size	"	48	.167		18.20	5.55		23.75	28.50
	5298	2-1/2" x 1" pipe size	Q-1	78	.205		28	6.15		34.15	40.50
	5300	2-1/2" x 1" pipe size	1 Plum	70	.114		32	3.80		35.80	41
	5302	3" x 1" pipe size	Q-1	65	.246		27	7.35		34.35	41
	5304	4" x 3/4" pipe size	↓	48	.333		40	10		50	59
	5306	4" x 1-1/2" pipe size	↓	46	.348		57	10.40		67.40	79
	5308	6" x 1-1/2" pipe size	Q-2	44	.545	↓	81	16.95		97.95	115
	5750	Flange, w/groove gasket, black steel (see 15107-660-0620, bolt sets)									
	5760	ANSI class 125 and 150, painted									
	5780	2" pipe size	1 Plum	23	.348	Ea.	41.50	11.55		53.05	63
	5790	2-1/2" pipe size	Q-1	37	.432		50	12.95		62.95	74.50
	5800	3" pipe size	↓	31	.516		54	15.45		69.45	83
	5820	4" pipe size	↓	23	.696		72.50	21		93.50	111
	5830	5" pipe size	↓	19	.842		84	25		109	131
	5840	6" pipe size	Q-2	23	1.043		92	32.50		124.50	150
	5850	8" pipe size	↓	17	1.412	↓	104	44		148	181

15100 | Building Services Piping

15107 Metal Pipe & Fittings		CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
5860	10" pipe size	Q-2	14	1.714	Ea.	164	53		217	262
5870	12" pipe size		12	2		215	62		277	330
5880	14" pipe size		10	2.400		495	74.50		569.50	660
5890	16" pipe size		9	2.667		575	83		658	755
5900	18" pipe size		6	4		705	124		829	965
5910	20" pipe size		5	4.800		850	149		999	1,150
5920	24" pipe size	↓	4.50	5.333	↓	1,075	165		1,240	1,450
5940	ANSI class 350, painted									
5946	2" pipe size	1 Plum	23	.348	Ea.	50.50	11.55		62.05	73
5948	2-1/2" pipe size	Q-1	37	.432		58.50	12.95		71.45	84
5950	3" pipe size		31	.516		80	15.45		95.45	112
5952	4" pipe size		23	.696		107	21		128	150
5954	5" pipe size	↓	19	.842		121	25		146	172
5956	6" pipe size	Q-2	23	1.043		141	32.50		173.50	205
5958	8" pipe size		17	1.412		162	44		206	246
5960	10" pipe size	↓	14	1.714		259	53		312	365
5962	12" pipe size	1 Plum	12	.667	↓	276	22		298	340
6100	Coupling, for PVC plastic pipe									
6110	2" diameter	1 Plum	50	.160	Ea.	10.80	5.30		16.10	19.95
6112	2-1/2" diameter	Q-1	80	.200		15.20	6		21.20	26
6114	3" diameter		67	.239		18.45	7.15		25.60	31.50
6116	4" diameter	↓	50	.320		24	9.60		33.60	41
6118	6" diameter	Q-2	50	.480		40	14.90		54.90	66.50
6120	8" diameter		42	.571		65.50	17.75		83.25	99
6122	10" diameter		35	.686		108	21.50		129.50	150
6124	12" diameter	↓	32	.750	↓	136	23.50		159.50	185
7400	Suction diffuser									
7402	Grooved-end-inlet x flanged outlet									
7410	3" x 3"	Q-1	50	.320	Ea.	425	9.60		434.60	485
7412	4" x 4"	↓	38	.421		620	12.60		632.60	705
7414	5" x 5"	↓	30	.533		675	15.95		690.95	765
7416	6" x 6"	Q-2	38	.632		850	19.60		869.60	965
7418	8" x 8"		27	.889		1,575	27.50		1,602.50	1,800
7420	10" x 10"		20	1.200		2,150	37		2,187	2,425
7422	12" x 12"		16	1.500		3,550	46.50		3,596.50	3,975
7424	14" x 14"		15	1.600		4,475	49.50		4,524.50	5,000
7426	16" x 14"	↓	14	1.714	↓	4,600	53		4,653	5,150
7500	Strainer, tee type, painted									
7506	2" pipe size	1 Plum	38	.211	Ea.	265	7		272	300
7508	2-1/2" pipe size	Q-1	62	.258		278	7.70		285.70	315
7510	3" pipe size		50	.320		315	9.60		324.60	360
7512	4" pipe size		38	.421		355	12.60		367.60	410
7514	5" pipe size	↓	30	.533		515	15.95		530.95	590
7516	6" pipe size	Q-2	38	.632		555	19.60		574.60	640
7518	8" pipe size		27	.889		855	27.50		882.50	980
7520	10" pipe size		20	1.200		1,250	37		1,287	1,425
7522	12" pipe size		16	1.500		1,625	46.50		1,671.50	1,850
7524	14" pipe size		15	1.600		5,750	49.50		5,799.50	6,400
7526	16" pipe size	↓	14	1.714	↓	7,150	53		7,203	7,925
7570	Expansion joint, max. 3" travel									
7572	2" diameter	1 Plum	38	.211	Ea.	218	7		225	250
7574	3" diameter	Q-1	50	.320		255	9.60		264.60	296
7576	4" diameter	"	38	.421		320	12.60		332.60	370
7578	6" diameter	Q-2	38	.632	↓	555	19.60		574.60	645
7800	Ball valve w/handle, carbon steel trim									
7810	1-1/2" pipe size	1 Plum	50	.160	Ea.	64.50	5.30		69.80	79

MECHANICAL 15

15100 | Building Services Piping

15107 Metal Pipe & Fittings		CREW	DAILY OUTPUT	LABOR-HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
7812	2" pipe size	1 Plum	38	.211	Ea.	89	7		96	109
7814	2-1/2" pipe size	Q-1	62	.258		184	7.70		191.70	214
7816	3" pipe size		50	.320		290	9.60		299.60	335
7818	4" pipe size		38	.421		445	12.60		457.60	510
7820	6" pipe size	Q-2	30	.800		1,300	25		1,325	1,500
7830	With gear operator									
7834	2-1/2" pipe size	Q-1	62	.258	Ea.	325	7.70		332.70	365
7836	3" pipe size		50	.320		430	9.60		439.60	485
7838	4" pipe size		38	.421		575	12.60		587.60	655
7840	6" pipe size	Q-2	30	.800		1,475	25		1,500	1,675
7870	Check valve									
7874	2-1/2" pipe size	Q-1	62	.258	Ea.	116	7.70		123.70	140
7876	3" pipe size		50	.320		137	9.60		146.60	166
7878	4" pipe size		38	.421		145	12.60		157.60	178
7880	5" pipe size		30	.533		241	15.95		256.95	289
7882	6" pipe size	Q-2	38	.632		286	19.60		305.60	345
7884	8" pipe size		27	.889		390	27.50		417.50	470
7886	10" pipe size		20	1.200		1,125	37		1,162	1,300
7888	12" pipe size		16	1.500		1,350	46.50		1,396.50	1,550
7900	Plug valve, balancing, w/lever operator									
7906	3" pipe size	Q-1	50	.320	Ea.	238	9.60		247.60	277
7908	4" pipe size		38	.421		262	12.60		274.60	305
7909	6" pipe size	Q-2	30	.800		470	25		495	555
7916	With gear operator									
7920	3" pipe size	Q-1	50	.320	Ea.	430	9.60		439.60	490
7922	4" pipe size		38	.421		455	12.60		467.60	520
7924	6" pipe size	Q-2	38	.632		660	19.60		679.60	760
7926	8" pipe size		27	.889		885	27.50		912.50	1,025
7928	10" pipe size		20	1.200		1,400	37		1,437	1,575
7930	12" pipe size		16	1.500		2,025	46.50		2,071.50	2,300
8000	Butterfly valve, 2 position handle, with standard trim									
8010	1-1/2" pipe size	1 Plum	50	.160	Ea.	103	5.30		108.30	121
8020	2" pipe size		38	.211		103	7		110	124
8030	3" pipe size	Q-1	50	.320		147	9.60		156.60	177
8050	4" pipe size		38	.421		162	12.60		174.60	197
8070	6" pipe size	Q-2	38	.632		355	19.60		374.60	420
8080	8" pipe size		27	.889		540	27.50		567.50	635
8090	10" pipe size		20	1.200		775	37		812	910
8200	With stainless steel trim									
8240	1-1/2" pipe size	1 Plum	50	.160	Ea.	130	5.30		135.30	151
8250	2" pipe size		38	.211		130	7		137	154
8270	3" pipe size	Q-1	50	.320		175	9.60		184.60	207
8280	4" pipe size		38	.421		190	12.60		202.60	228
8300	6" pipe size	Q-2	38	.632		355	19.60		374.60	420
8310	8" pipe size		27	.889		605	27.50		632.50	705
8320	10" pipe size		20	1.200		960	37		997	1,100
8322	12" pipe size		16	1.500		1,225	46.50		1,271.50	1,425
8324	14" pipe size		15	1.600		1,600	49.50		1,649.50	1,850
8326	16" pipe size		14	1.714		2,200	53		2,253	2,500
8328	18" pipe size	Q-3	12	2.667		2,700	84.50		2,784.50	3,100
8330	20" pipe size		11	2.909		3,675	92.50		3,767.50	4,175
8332	24" pipe size		10	3.200		4,675	101		4,776	5,275
8336	Note: sizes 12" up w/manual gear operator									
9000	Cut one groove, labor									
9010	3/4" pipe size	Q-1	152	.105	Ea.		3.15		3.15	4.77
9020	1" pipe size		140	.114			3.42		3.42	5.15

15100 | Building Services Piping

15107 Metal Pipe & Fittings		CREW	DAILY OUTPUT	LABOR-HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
9030	1-1/4" pipe size	Q-1	124	.129	Ea.		3.86		3.86	5.85
9040	1-1/2" pipe size		114	.140			4.20		4.20	6.35
9050	2" pipe size		104	.154			4.60		4.60	6.95
9060	2-1/2" pipe size		96	.167			4.99		4.99	7.55
9070	3" pipe size		88	.182			5.45		5.45	8.25
9080	3-1/2" pipe size		83	.193			5.75		5.75	8.75
9090	4" pipe size		78	.205			6.15		6.15	9.30
9100	5" pipe size		72	.222			6.65		6.65	10.05
9110	6" pipe size		70	.229			6.85		6.85	10.35
9120	8" pipe size		54	.296			8.85		8.85	13.40
9130	10" pipe size		38	.421			12.60		12.60	19.05
9140	12" pipe size		30	.533			15.95		15.95	24
9150	14" pipe size		20	.800			24		24	36
9160	16" pipe size		19	.842			25		25	38
9170	18" pipe size		18	.889			26.50		26.50	40.50
9180	20" pipe size		17	.941			28		28	42.50
9190	24" pipe size	↓	15	1.067	↓		32		32	48.50
9210	Roll one groove									
9220	3/4" pipe size	Q-1	266	.060	Ea.		1.80		1.80	2.72
9230	1" pipe size		228	.070			2.10		2.10	3.18
9240	1-1/4" pipe size		200	.080			2.39		2.39	3.62
9250	1-1/2" pipe size		178	.090			2.69		2.69	4.07
9260	2" pipe size		116	.138			4.13		4.13	6.25
9270	2-1/2" pipe size		110	.145			4.35		4.35	6.60
9280	3" pipe size		100	.160			4.79		4.79	7.25
9290	3-1/2" pipe size		94	.170			5.10		5.10	7.70
9300	4" pipe size		86	.186			5.55		5.55	8.40
9310	5" pipe size		84	.190			5.70		5.70	8.60
9320	6" pipe size		80	.200			6		6	9.05
9330	8" pipe size		66	.242			7.25		7.25	11
9340	10" pipe size		58	.276			8.25		8.25	12.50
9350	12" pipe size		46	.348			10.40		10.40	15.75
9360	14" pipe size		30	.533			15.95		15.95	24
9370	16" pipe size		28	.571			17.10		17.10	26
9380	18" pipe size		27	.593			17.75		17.75	27
9390	20" pipe size		25	.640			19.15		19.15	29
9400	24" pipe size	↓	23	.696	↓		21		21	31.50
920	0010 PIPE, STAINLESS STEEL									920
0020	Welded, with clevis type hangers 10' O.C.									
0500	Schedule 5, type 304									
0540	1/2" diameter	Q-15	128	.125	L.F.	3.91	3.74	.38	8.03	10.35
0550	3/4" diameter		116	.138		4.46	4.13	.42	9.01	11.60
0560	1" diameter		103	.155		5.35	4.65	.47	10.47	13.40
0570	1-1/4" diameter		93	.172		6.05	5.15	.52	11.72	15.10
0580	1-1/2" diameter		85	.188		6.95	5.65	.57	13.17	16.80
0590	2" diameter		69	.232		8.30	6.95	.71	15.96	20.50
0600	2-1/2" diameter		53	.302		11.40	9.05	.92	21.37	27
0610	3" diameter		48	.333		13.70	10	1.02	24.72	31.50
0620	4" diameter		44	.364		17.45	10.90	1.11	29.46	37
0630	5" diameter	↓	36	.444		35	13.30	1.36	49.66	60
0640	6" diameter	Q-16	42	.571		32	17.75	1.16	50.91	64
0650	8" diameter		34	.706		49	22	1.43	72.43	88.50
0660	10" diameter		26	.923		69	28.50	1.87	99.37	122
0670	12" diameter	↓	21	1.143	↓	90.50	35.50	2.32	128.32	156
0700	To delete hangers, subtract									

Labour Costs, HK

Inlet Piping (6", 3", 2", 1 1/2")

Estimate			Actual		
	Crew	days	Quantity	Days	
1C Sch 80 6"	Q ₁	38'	50'	1.32	1.9
1C Sch 80 3"	Q ₁	50'	20'	0.40	
1VC Sch 80 2"	Q ₁	55'	10'	0.18	
1C Sch 80 1 1/2"	1 PLUM	34'	30'	0.88	
4 45° Elbows 6"	Q ₁	8	8	1.0	3.73
4 45° Elbows 3"	Q ₁	16	5	0.31	
4 Elbows 2"	Q ₁	23	3	0.13	
5 Elbows 1 1/2"	Q ₁	27	14	0.52	
6"	Q ₁	5	1	0.20	
1 1/2"	Q ₁	20	3	0.15	
1 large 6"	Q ₁	16	2	0.125	
1 large 5"	Q ₁	21	1	0.05	
1 large 3"	Q ₁	32	4	0.125	
1 large 2"	Q ₁	48	2	0.04	
1 large 1 1/2"	Q ₁	51	9+2	0.22	0.293
1 reducer 6" x 5"	Q ₁	15	1	0.07	
1 reducer 3" x 1 1/2"	Q ₁	24	2	0.08	
1 Tee 6" x 3"	Q ₁	7	5	0.71	
1 ball 1 1/2"	1 1 PLUM	20	5	0.25	0.293
1 valve 2"	1 PLUM	17	1	0.06	
1 valve 3"	Q ₁	24	1	0.04	
1 valve 6"	Q ₁	12	2	0.17	
1 valve 6"	Q ₁	12	1	0.083	

Labour Costs, HK

Inlet Piping

Time Required for 1 PLUM = 1.19 days

Add additional labour reduces time by 25%, $\therefore 1.19 \times 0.75 = 0.90$ days

Time Required for 1 Q crew = 5.92 days

Total Time for 2 Labours = $5.92 + 0.90 = 6.82$ days (54.6 ^{hrs} ~~hrs~~)

~~Add additional labour reduces time by 25%, $\therefore 8.82 \times 0.75 = 5.12$ days~~

~~Time required to remove old piping = $5.12 \times 1.5 = 0.77$ days~~

~~Total Time required to complete job = 5.9 days~~

~~Additional time required due to pipe location, $5.9 \times 1.25 = 7.4$ days (59.2 ^{hrs} ~~hrs~~)~~

5100 | Building Services Piping

5107 Metal Pipe & Fittings	CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
					MAT.	LABOR	EQUIP.	TOTAL		
2" For couplings and unions use 3000 lb., type 316	Q-1	9	1.778	Ea.	133	53		186	227	960
3000 lb., type 304										
Coupling										
1/8"	1 Plum	19	.421	Ea.	2.41	14		16.41	23.50	
1/4"		19	.421		2.53	14		16.53	24	
3/8"		19	.421		3.04	14		17.04	24.50	
1/2"		19	.421		4.84	14		18.84	26.50	
3/4"		18	.444		7.30	14.80		22.10	30.50	
1"		15	.533		12.40	17.75		30.15	40.50	
1-1/4"	Q-1	26	.615		28	18.40		46.40	58.50	
1-1/2"		24	.667		32	19.95		51.95	65.50	
2"		21	.762		46	23		69	85.50	
Union										
1/8"	1 Plum	12	.667	Ea.	25.50	22		47.50	61.50	
1/4"		12	.667		25.50	22		47.50	61.50	
3/8"		12	.667		27.50	22		49.50	63.50	
1/2"		11	.727		27.50	24		51.50	66.50	
3/4"		10	.800		33.50	26.50		60	77	
1"		9	.889		56	29.50		85.50	106	
1-1/4"	Q-1	16	1		78.50	30		108.50	132	
1-1/2"		15	1.067		88	32		120	146	
2"		13	1.231		123	37		160	192	
3000 lb., type 316										
Coupling										
1/8"	1 Plum	19	.421	Ea.	2.95	14		16.95	24.50	
1/4"		19	.421		3.25	14		17.25	24.50	
3/8"		19	.421		3.46	14		17.46	25	
1/2"		19	.421		5.60	14		19.60	27	
3/4"		18	.444		8.25	14.80		23.05	31.50	
1"		15	.533		13.95	17.75		31.70	42.50	
1-1/4"	Q-1	26	.615		32	18.40		50.40	63.50	
1-1/2"		24	.667		36.50	19.95		56.45	70	
2"		21	.762		53	23		76	93	
Union										
1/8"	1 Plum	12	.667	Ea.	26	22		48	62.50	
1/4"		12	.667		26	22		48	62.50	
3/8"		12	.667		32	22		54	69	
1/2"		11	.727		32	24		56	72	
3/4"		10	.800		36.50	26.50		63	80	
1"		9	.889		63	29.50		92.50	114	
1-1/4"	Q-1	16	1		94	30		124	149	
1-1/2"		15	1.067		118	32		150	178	
2"		13	1.231		154	37		191	225	
5108 Plastic Pipe & Fittings										
PIPE, PLASTIC										
Fiberglass reinforced, couplings 10' O.C., hangers 3 per 10'										520
General service										
2" diameter	Q-1	59	.271	L.F.	9.65	8.10		17.75	23	
3" diameter		52	.308		13	9.20		22.20	28.50	
4" diameter		48	.333		15.85	10		25.85	32.50	
6" diameter		39	.410		23	12.30		35.30	43.50	
8" diameter	Q-2	49	.490		36.50	15.20		51.70	63	
10" diameter		41	.585		53.50	18.15		71.65	86.50	
12" diameter		36	.667		65.50	20.50		86	104	

15100 | Building Services Piping

15108 Plastic Pipe & Fittings		CREW	DAILY OUTPUT	LABOR-HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
520	0200 High strength									
	0240 2" diameter	Q-1	58	.276	L.F.	10.75	8.25		19	24.50
	0260 3" diameter		51	.314		14.65	9.40		24.05	30
	0280 4" diameter		47	.340		17.65	10.20		27.85	35
	0300 6" diameter		38	.421		26	12.60		38.60	47.50
	0320 8" diameter	Q-2	48	.500		41	15.50		56.50	68.50
	0340 10" diameter		40	.600		60	18.60		78.60	94
	0360 12" diameter		36	.667		73.50	20.50		94	113
	0550 To delete coupling & hangers, subtract									
	0560 2" diam. to 6" diam.					33%	56%			
	0570 8" diam. to 12" diam.					31%	52%			
	0600 PVC, high impact/pressure, cplgs. 10' O.C., hangers 3 per 10'									
	1020 Schedule 80									
	1040 1/4" diameter	1 Plum	58	.138	L.F.	2.17	4.59		6.76	9.35
	1060 3/8" diameter		55	.145		2.26	4.84		7.10	9.80
	1070 1/2" diameter		50	.160		2	5.30		7.30	10.25
	1080 3/4" diameter		47	.170		2.20	5.65		7.85	10.95
	1090 1" diameter		43	.186		2.68	6.20		8.88	12.30
	1100 1-1/4" diameter		39	.205		2.80	6.80		9.60	13.40
	1110 1-1/2" diameter		34	.235		3.01	7.80		10.81	15.15
	1120 2" diameter	Q-1	55	.291		3.19	8.70		11.89	16.65
	1130 2-1/2" diameter		52	.308		3.30	9.20		12.50	17.55
	1140 3" diameter		50	.320		4.56	9.60		14.16	19.50
	1150 4" diameter		46	.348		6.05	10.40		16.45	22.50
	1160 5" diameter		42	.381		10.35	11.40		21.75	28.50
	1170 6" diameter		38	.421		9.30	12.60		21.90	29.50
	1180 8" diameter	Q-2	47	.511		14.95	15.85		30.80	40.50
	1190 10" diameter		42	.571		23.50	17.75		41.25	53
	1200 12" diameter		38	.632		30	19.60		49.60	62
	1730 To delete coupling & hangers, subtract									
	1740 1/4" diam. to 1/2" diam.					62%	80%			
	1750 3/4" diam. to 1-1/4" diam.					58%	73%			
	1760 1-1/2" diam. to 6" diam.					40%	57%			
	1770 8" diam. to 12" diam.					34%	50%			
	1800 PVC, couplings 10' O.C., hangers 3 per 10'									
	1820 Schedule 40									
	1860 1/2" diameter	1 Plum	54	.148	L.F.	1.90	4.93		6.83	9.55
	1870 3/4" diameter		51	.157		2.06	5.20		7.26	10.15
	1880 1" diameter		46	.174		2.57	5.80		8.37	11.60
	1890 1-1/4" diameter		42	.190		2.61	6.35		8.96	12.45
	1900 1-1/2" diameter		36	.222		2.81	7.40		10.21	14.30
	1910 2" diameter	Q-1	59	.271		2.83	8.10		10.93	15.40
	1920 2-1/2" diameter		56	.286		3.52	8.55		12.07	16.80
	1930 3" diameter		53	.302		4.05	9.05		13.10	18.10
	1940 4" diameter		48	.333		5.50	10		15.50	21
	1950 5" diameter		43	.372		7.50	11.15		18.65	25
	1960 6" diameter		39	.410		8.30	12.30		20.60	27.50
	1970 8" diameter	Q-2	48	.500		13.15	15.50		28.65	38
	1980 10" diameter		43	.558		27.50	17.30		44.80	56.50
	1990 12" diameter		42	.571		35	17.75		52.75	65.50
	2000 14" diameter		31	.774		108	24		132	156
	2010 16" diameter		23	1.043		136	32.50		168.50	198
	2340 To delete coupling & hangers, subtract									
	2360 1/2" diam. to 1-1/4" diam.					65%	74%			
	2370 1-1/2" diam. to 6" diam.					44%	57%			
	2380 8" diam. to 12" diam.					41%	53%			

TS MECHANICAL

15100 | Building Services Piping

1 103 | Plastic Pipe & Fittings

	CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
					MAT.	LABOR	EQUIP.	TOTAL	
391 14" diam. to 16" diam.					48%	45%			520
420 Schedule 80									
4 1/4" diameter	1 Plum	58	.138	L.F.	1.91	4.59		6.50	9.05
4 3/8" diameter		55	.145		1.91	4.84		6.75	9.40
460 1/2" diameter		50	.160		2.08	5.30		7.38	10.35
4 3/4" diameter		47	.170		2.31	5.65		7.96	11.10
4 1" diameter		43	.186		2.84	6.20		9.04	12.50
490 1-1/4" diameter		39	.205		3.02	6.80		9.82	13.60
500 1-1/2" diameter	Q-1	34	.235		3.27	7.80		11.07	15.45
5 2" diameter		55	.291		3.57	8.70		12.27	17.10
520 2-1/2" diameter		52	.308		3.86	9.20		13.06	18.20
530 3" diameter		50	.320		5.30	9.60		14.90	20.50
4 4" diameter		46	.348		7.15	10.40		17.55	23.50
5 5" diameter		42	.381		9.75	11.40		21.15	28
560 6" diameter	Q-2	38	.421		11.35	12.60		23.95	31.50
5 8" diameter		47	.511		18.10	15.85		33.95	44
5 10" diameter		42	.571		28	17.75		45.75	57.50
590 12" diameter		38	.632		36	19.60		55.60	69
830 To delete coupling & hangers, subtract									
1/4" diam. to 1/2" diam.					66%	80%			
3/4" diam. to 1-1/4" diam.					61%	73%			
860 1-1/2" diam. to 6" diam.					41%	57%			
8" diam. to 12" diam.					31%	50%			
8 Schedule 120									
910 1/2" diameter	1 Plum	50	.160	L.F.	2.63	5.30		7.93	10.95
950 3/4" diameter		47	.170		3.03	5.65		8.68	11.90
9 1" diameter		43	.186		3.89	6.20		10.09	13.65
9 1-1/4" diameter		39	.205		4.50	6.80		11.30	15.25
980 1-1/2" diameter	Q-1	33	.242		5.05	8.05		13.10	17.75
9 2" diameter		54	.296		6.10	8.85		14.95	20
9 2-1/2" diameter		52	.308		8.30	9.20		17.50	23
1010 3" diameter		49	.327		10.45	9.75		20.20	26.50
9 4" diameter		45	.356		15.70	10.65		26.35	33.50
9 6" diameter		37	.432		27.50	12.95		40.45	50
920 To delete coupling & hangers, subtract									
1/2" diam. to 1-1/4" diam.					52%	74%			
1-1/2" diam. to 4" diam.					30%	57%			
6" diam.					17%	50%			
1300 PVC, pressure, couplings 10' O.C., hangers 3 per 10'									
SDR 26, 160 psi									
1350 1-1/4" diameter	1 Plum	42	.190	L.F.	2.44	6.35		8.79	12.30
1350 1-1/2" diameter		36	.222		2.62	7.40		10.02	14.10
1370 2" diameter	Q-1	59	.271		2.80	8.10		10.90	15.40
13 2-1/2" diameter		56	.286		3.15	8.55		11.70	16.40
13 3" diameter		53	.302		3.65	9.05		12.70	17.65
1400 4" diameter		48	.333		5.10	10		15.10	20.50
13 6" diameter	Q-2	39	.410		8.05	12.30		20.35	27.50
13 8" diameter		48	.500		13.15	15.50		28.65	38
1660 To delete coupling & hangers, subtract									
1-1/4" diam.					63%	68%			
1-1/2" diam. to 4" diam.					48%	57%			
6" diam. to 8" diam.					60%	54%			
1720 SDR 21, 200 psi, 1/2" diameter	1 Plum	54	.148	L.F.	2.01	4.93		6.94	9.65
3/4" diameter		51	.157		2.18	5.20		7.38	10.30
17 1" diameter		46	.174		2.63	5.80		8.43	11.65
1760 1-1/4" diameter		42	.190		2.75	6.35		9.10	12.60

15100 | Building Services Piping

520	15108 Plastic Pipe & Fittings	CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL. OF
						MAT.	LABOR	EQUIP.	TOTAL	
3770	1-1/2" diameter	1 Plum	36	.222	L.F.	2.96	7.40		10.36	11.1
3780	2" diameter	Q-1	59	.271		3.17	8.10		11.27	11.8
3790	2-1/2" diameter		56	.286		4.15	8.55		12.70	13.3
3800	3" diameter		53	.302		4.58	9.05		13.63	14.2
3810	4" diameter		48	.333		6.25	10		16.25	16.8
3830	6" diameter		39	.410		10.05	12.30		22.35	23.0
3840	8" diameter	Q-2	48	.500		16.70	15.50		32.20	33.0
4000	To delete coupling & hangers, subtract									
4010	1/2" diam. to 3/4" diam.					71%	77%			
4020	1" diam. to 1-1/4" diam.					63%	70%			
4030	1-1/2" diam. to 6" diam.					44%	57%			
4040	8" diam.					46%	54%			
4100	DWV type, schedule 40, couplings 10' O.C., hangers 3 per 10'									
4120	ABS									
4140	1-1/4" diameter	1 Plum	42	.190	L.F.	2.58	6.35		8.93	9.4
4150	1-1/2" diameter	"	36	.222		2.56	7.40		9.96	10.5
4160	2" diameter	Q-1	59	.271		2.66	8.10		10.76	11.3
4170	3" diameter		53	.302		3.28	9.05		12.33	12.9
4180	4" diameter		48	.333		4.44	10		14.44	15.0
4190	6" diameter		39	.410		7.10	12.30		19.40	20.0
4360	To delete coupling & hangers, subtract									
4370	1-1/4" diam.					64%	68%			
4380	1-1/2" diam. to 6" diam.					54%	57%			
4400	PVC									
4410	1-1/4" diameter	1 Plum	42	.190	L.F.	2.66	6.35		9.01	9.5
4420	1-1/2" diameter	"	36	.222		2.73	7.40		10.13	10.6
4460	2" diameter	Q-1	59	.271		2.91	8.10		11.01	11.5
4470	3" diameter		53	.302		3.79	9.05		12.84	13.3
4480	4" diameter		48	.333		5.10	10		15.10	15.6
4490	6" diameter		39	.410		7.40	12.30		19.70	20.2
4500	8" diameter	Q-2	48	.500		16.35	15.50		31.85	32.5
4750	To delete coupling & hangers, subtract									
4760	1-1/4" diam. to 1-1/2" diam.					71%	64%			
4770	2" diam. to 8" diam.					60%	57%			
4800	PVC, clear pipe, cplgs. 10' O.C., hangers 3 per 10', Sched. 40									
4840	1/4" diameter	1 Plum	59	.136	L.F.	2.32	4.51		6.83	7.2
4850	3/8" diameter		56	.143		2.51	4.75		7.26	7.6
4860	1/2" diameter		54	.148		2.87	4.93		7.80	8.2
4870	3/4" diameter		51	.157		3.36	5.20		8.56	8.9
4880	1" diameter		46	.174		4.51	5.80		10.31	10.7
4890	1-1/4" diameter		42	.190		5.25	6.35		11.60	12.0
4900	1-1/2" diameter		36	.222		5.95	7.40		13.35	13.7
4910	2" diameter	Q-1	59	.271		7.25	8.10		15.35	15.7
4920	2-1/2" diameter		56	.286		10.20	8.55		18.75	19.1
4930	3" diameter		53	.302		12.75	9.05		21.80	22.2
4940	3-1/2" diameter		50	.320		15.65	9.60		25.25	25.6
4950	4" diameter		48	.333		16.40	10		26.40	26.8
5250	To delete coupling & hangers, subtract									
5260	1/4" diam. to 3/8" diam.					60%	81%			
5270	1/2" diam. to 3/4" diam.					41%	77%			
5280	1" diam. to 1-1/2" diam.					26%	67%			
5290	2" diam. to 4" diam.					16%	58%			
5360	CPVC, couplings 10' O.C., hangers 3 per 10'									
5380	Schedule 40									
5460	1/2" diameter	1 Plum	54	.148	L.F.	2.63	4.93		7.56	7.9
5470	3/4" diameter		51	.157		3.04	5.20		8.24	8.6

5100 | Building Services Piping

03 | Plastic Pipe & Fittings

		CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
						MAT.	LABOR	EQUIP.	TOTAL		
30	1" diameter	1 Plum	46	.174	L.F.	3.98	5.80		9.78	13.15	520
3	1-1/4" diameter	↓	42	.190		4.57	6.35		10.92	14.65	
5	1-1/2" diameter	↓	36	.222		5.20	7.40		12.60	16.90	
10	2" diameter	Q-1	59	.271		6.05	8.10		14.15	19	
20	2-1/2" diameter	↓	56	.286		8.85	8.55		17.40	22.50	
3	3" diameter	↓	53	.302		10.55	9.05		19.60	25.50	
4	4" diameter	↓	48	.333		14.50	10		24.50	31	
50	6" diameter	↓	43	.372	↓	26	11.15		37.15	45.50	
	To delete coupling & hangers, subtract										
	1/2" diam. to 3/4" diam.					37%	77%				
50	1" diam. to 1-1/4" diam.					27%	70%				
10	1-1/2" diam. to 3" diam.					21%	57%				
7	4" diam. to 6" diam.					16%	57%				
300	Schedule 80										
360	1/2" diameter	1 Plum	50	.160	L.F.	2.74	5.30		8.04	11.05	
3	3/4" diameter	↓	47	.170		3.22	5.65		8.87	12.10	
3	1" diameter	↓	43	.186		4.24	6.20		10.44	14	
890	1-1/4" diameter	↓	39	.205		4.96	6.80		11.76	15.75	
9	1-1/2" diameter	↓	34	.235		5.70	7.80		13.50	18.15	
5	2" diameter	Q-1	55	.291		6.85	8.70		15.55	20.50	
920	2-1/2" diameter	↓	52	.308		9.90	9.20		19.10	25	
930	3" diameter	↓	50	.320		12.10	9.60		21.70	28	
6	4" diameter	↓	46	.348		17	10.40		27.40	34.50	
6	6" diameter	↓	38	.421		31.50	12.60		44.10	53.50	
960	8" diameter	Q-2	47	.511	↓	68.50	15.85		84.35	99.50	
	To delete couplings & hangers, subtract										
	1/2" diam. to 3/4" diam.					44%	77%				
1080	1" diam. to 1-1/4" diam.					32%	71%				
5	1-1/2" diam. to 4" diam.					25%	58%				
5	6" diam. to 8" diam.					20%	53%				
5250	CTS, 1/2" diameter	1 Plum	54	.148	L.F.	2.08	4.93		7.01	9.75	
5250	3/4" diameter	↓	51	.157		2.80	5.20		8	11	
6	1" diameter	↓	46	.174		3.58	5.80		9.38	12.70	
6	1 1/4"	↓	42	.190		4.22	6.35		10.57	14.25	
6280	1 1/2" diameter	↓	36	.222		5.05	7.40		12.45	16.75	
6	2" diameter	Q-1	59	.271	↓	7.10	8.10		15.20	20	
	To delete coupling & hangers, subtract										
6300	1/2" diam.					51%	79%				
6300	3/4" diam.					40%	76%				
6	1" thru 2" diam.					72%	68%				
	Polyethylene, flexible, no couplings or hangers										
7282	Note: For labor costs add 25% to the couplings and fittings labor total.										
	SDR 15, 100 psi										
	3/4" diameter				L.F.	.17			.17	.19	
7350	1" diameter				↓	.22			.22	.24	
7350	1-1/4" diameter					.40			.40	.44	
	1-1/2" diameter					.50			.50	.55	
7350	2" diameter				↓	.80			.80	.88	
7700	SIDR 9, 160 psi										
	1/2" diameter				L.F.	.23			.23	.25	
	3/4" diameter				↓	.23			.23	.25	
7700	1" diameter					.36			.36	.40	
	1-1/4" diameter					.60			.60	.66	
	1-1/2" diameter					.84			.84	.92	
7700	2" diameter				↓	1.38			1.38	1.52	
7700	SDR 9, 200 psi										

15100 | Building Services Piping

520	15108 Plastic Pipe & Fittings			CREW	DAILY OUTPUT	LABOR-HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
								MAT.	LABOR	EQUIP.	TOTAL	
8150	3/4" diameter						L.F.	.20			.20	.22
8160	1" diameter						↓	.33			.33	
8170	1-1/4" diameter						↓	.49			.49	
8420	SDR 7, 250 psi											
8440	3/4" diameter						L.F.	.29			.29	.32
8450	1" diameter						↓	.46			.46	.51
8460	1-1/4" diameter						↓	.79			.79	.87
8800	PVC, type PSP, drain & sewer, belled end gasket jnt., no hngr.											
8840	3" diameter						L.F.	.32			.32	.35
8850	4" diameter						↓	.40			.40	.44
8860	6" diameter						↓	.89			.89	.98
9000	Perforated											
9040	4" diameter						L.F.	.42			.42	.46
560	PIPE, PLASTIC, FITTINGS											
0030	Epoxy resin, fiberglass reinforced, general service											
0090	Elbow, 90°, 2"	2.5" 19		Q-1	23	.696	Ea.	45.50	21		66.50	81.50
0100	3"			↓	16	1	↓	64.50	30		94.50	116
0110	4"			↓	13	1.231	↓	104	37		141	170
0120	6"			↓	8	2	↓	156	60		216	263
0130	8"			Q-2	9	2.667	↓	260	83		343	410
0140	10"			↓	7	3.429	↓	360	106		466	555
0150	12"			↓	5	4.800	↓	500	149		649	775
0160	45° Elbow, same as 90°											
0170	Elbow, 90°, flanged											
0172	2"			Q-1	23	.696	Ea.	91	21		112	132
0173	3"			↓	16	1	↓	105	30		135	162
0174	4"			↓	13	1.231	↓	138	37		175	207
0176	6"			↓	8	2	↓	249	60		309	365
0177	8"			Q-2	9	2.667	↓	450	83		533	620
0178	10"			↓	7	3.429	↓	615	106		721	835
0179	12"			↓	5	4.800	↓	835	149		984	1,150
0186	Elbow, 45°, flanged											
0188	2"			Q-1	23	.696	Ea.	91.50	21		112.50	133
0189	3"			↓	16	1	↓	105	30		135	162
0190	4"			↓	13	1.231	↓	137	37		174	207
0192	6"			↓	8	2	↓	251	60		311	365
0193	8"			Q-2	9	2.667	↓	450	83		533	620
0194	10"			↓	7	3.429	↓	615	106		721	835
0195	12"			↓	5	4.800	↓	835	149		984	1,150
0290	Tee, 2"	2.5" 13		Q-1	17	.941	↓	61	28		89	110
0300	3"			↓	10	1.600	↓	71.50	48		119.50	151
0310	4"			↓	8	2	↓	85	60		145	184
0320	6"			↓	5	3.200	↓	228	96		324	395
0330	8"			Q-2	6	4	↓	263	124		387	475
0340	10"			↓	5	4.800	↓	420	149		569	685
0350	12"			↓	4	6	↓	510	186		696	840
0352	Tee, flanged											
0354	2"			Q-1	17	.941	Ea.	124	28		152	179
0355	3"			↓	10	1.600	↓	166	48		214	256
0356	4"			↓	8	2	↓	185	60		245	294
0358	6"			↓	5	3.200	↓	365	96		461	545
0359	8"			Q-2	6	4	↓	625	124		749	875
0360	10"			↓	5	4.800	↓	905	149		1,054	1,199
0361	12"			↓	4	6	↓	1,150	186		1,336	1,500
0365	Wye, flanged											

5100 | Building Services Piping

108 Plastic Pipe & Fittings		CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
						MAT.	LABOR	EQUIP.	TOTAL		
167	2"	Q-1	17	.941	Ea.	320	28		348	395	560
168	3"	↓	10	1.600	↓	355	48		403	465	
	4"	↓	8	2	↓	440	60		500	575	
	6"	↓	5	3.200	↓	530	96		626	725	
172	8"	Q-2	6	4	↓	690	124		814	945	
	10"	↓	5	4.800	↓	1,175	149		1,324	1,500	
	12"	↓	4	6	↓	1,425	186		1,611	1,825	
180	Couplings										
	2"	Q-1	28	.571	Ea.	10.90	17.10		28	38	
	3"	↓	20	.800	↓	18.85	24		42.85	56.50	
130	4"	↓	17	.941	↓	20	28		48	64.50	
140	6"	↓	12	1.333	↓	38	40		78	103	
	8"	Q-2	15	1.600	↓	58	49.50		107.50	139	
	10"	↓	11	2.182	↓	87.50	67.50		155	198	
170	12"	↓	10	2.400	↓	117	74.50		191.50	242	
	High corrosion resistant couplings, add					30%					
	Reducer, concentric, flanged										
175	2" x 1-1/2"	Q-1	30	.533	Ea.	132	15.95		147.95	169	
182	3" x 2"	↓	24	.667	↓	150	19.95		169.95	195	
	4" x 3"	↓	19	.842	↓	158	25		183	212	
	6" x 4"	↓	15	1.067	↓	206	32		238	276	
180	8" x 6"	Q-2	16	1.500	↓	289	46.50		335.50	390	
	10" x 8"	↓	13	1.846	↓	385	57.50		442.50	510	
	12" x 10"	↓	11	2.182	↓	555	67.50		622.50	710	
186	Adapter, bell x male or female										
	2"	Q-1	28	.571	Ea.	19.65	17.10		36.75	47.50	
	3"	↓	20	.800	↓	25	24		49	63.50	
	4"	↓	17	.941	↓	34.50	28		62.50	80.50	
192	6"	↓	12	1.333	↓	68.50	40		108.50	136	
	8"	Q-2	15	1.600	↓	95.50	49.50		145	180	
	10"	↓	11	2.182	↓	168	67.50		235.50	287	
228	Flange										
	2"	Q-1	46	.348	Ea.	17.40	10.40		27.80	35	
	3"	↓	32	.500	↓	21	14.95		35.95	46	
234	4"	↓	26	.615	↓	29.50	18.40		47.90	60.50	
242	6"	↓	16	1	↓	50	30		80	101	
	8"	Q-2	18	1.333	↓	82	41.50		123.50	153	
	10"	↓	14	1.714	↓	114	53		167	207	
252	12"	↓	10	2.400	↓	161	74.50		235.50	290	
	PVC schedule 80										
	90° elbow, 1/2"	1 Plum	18	.444	Ea.	.89	14.80		15.69	23.50	
260	3/4"	↓	17	.471	↓	1.14	15.65		16.79	25	
	1"	↓	15	.533	↓	1.83	17.75		19.58	29	
	1-1/4"	↓	14	.571	↓	2.44	19		21.44	31	
	1-1/2"	↓	13	.615	↓	2.62	20.50		23.12	34	
270	2"	Q-1	22	.727	↓	3.16	22		25.16	36.50	
	3"	↓	14	1.143	↓	8.30	34		42.30	61	
	4"	↓	12	1.333	↓	12.65	40		52.65	74.50	
280	6"	↓	7	2.286	↓	42.50	68.50		111	151	
	8"	Q-2	8	3	↓	117	93		210	270	
	45° elbow, 1/2"	1 Plum	18	.444	↓	1.68	14.80		16.48	24.50	
270	3/4"	↓	17	.471	↓	2.54	15.65		18.19	26.50	
	1"	↓	15	.533	↓	3.84	17.75		21.59	31	
	1-1/4"	↓	14	.571	↓	4.87	19		23.87	34	
	1-1/2"	↓	13	.615	↓	5.75	20.50		26.25	37.50	
280	2"	Q-1	22	.727	↓	7.45	22		29.45	41	

15100 | Building Services Piping

15108 | Plastic Pipe & Fittings

			CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
							MAT.	LABOR	EQUIP.	TOTAL	
560	2320	3"	Q-1	14	1.143	Ea.	19.05	34		53.05	73
	2330	4"		12	1.333		34.50	40		74.50	98
	2340	6"	Q-2	7	2.286		43	68.50		111.50	152
	2350	8"		8	3		83	93		176	232
	2400	Tee, 1/2"	1 Plum	12	.667		2.50	22		24.50	36.50
	2420	3/4"		11	.727		2.62	24		26.62	39.50
	2430	1"		10	.800		3.27	26.50		29.77	43.50
	2440	1-1/4"		9	.889		9	29.50		38.50	54.50
	2450	1-1/2"	Q-1	8	1		9	33.50		42.50	60.50
	2460	2"		14	1.143		11.25	34		45.25	64.50
	2470	3"		9	1.778		15.30	53		68.30	97.50
	2480	4"		8	2		17.70	60		77.70	110
	2490	6"	Q-2	5	3.200		60.50	96		156.50	212
	2500	8"		6	4		85.50	124		209.50	282
	2510	Flange, socket, 150 lb., 1/2"	1 Plum	34	.235		4.84	7.80		12.64	17.15
	2514	3/4"		32	.250		5.20	8.30		13.50	18.25
	2518	1"		28	.286		5.80	9.50		15.30	20.50
	2522	1-1/2"	Q-1	24	.333		6.10	11.10		17.20	23.50
	2526	2"		42	.381		8.10	11.40		19.50	26
	2530	4"		30	.533		17.45	15.95		33.40	43
	2534	6"	Q-2	22	.727		27.50	22		49.50	63
	2538	8"		26	.923		50	28.50		78.50	98.50
	2550	Coupling, 1/2"	1 Plum	18	.444		1.61	14.80		16.41	24.50
	2570	3/4"		17	.471		2.17	15.65		17.82	26
	2580	1"		15	.533		2.23	17.75		19.98	29.50
	2590	1-1/4"		14	.571		3.39	19		22.39	32
	2600	1-1/2"	Q-1	13	.615		3.66	20.50		24.16	35
	2610	2"		22	.727		3.92	22		25.92	37.50
	2620	3"		19	.842		11.10	25		36.10	50
	2630	4"		16	1		13.90	30		43.90	61
	2640	6"	Q-2	12	1.333		30	40		70	93.50
	2650	8"		14	1.714		54	53		107	140
	2660	10"		13	1.846		84	57.50		141.50	179
	2670	12"		12	2		112	62		174	217
	2700	PVC (white), schedule 40, socket joints	1 Plum	22	.364	Ea.	.23	12.10		12.33	18.55
	2760	90° elbow, 1/2"		21	.381		.25	12.65		12.90	19.45
	2770	3/4"		18	.444		.45	14.80		15.25	23
	2780	1"		17	.471		.80	15.65		16.45	24.50
	2790	1-1/4"		16	.500		.85	16.65		17.50	26
	2810	2"	Q-1	28	.571		1.34	17.10		18.44	27.50
	2820	2-1/2"		22	.727		4.06	22		26.06	37.50
	2830	3"		17	.941		4.86	28		32.86	48
	2840	4"		14	1.143		8.70	34		42.70	61.50
	2850	5"		12	1.333		22.50	40		62.50	85
	2860	6"	Q-2	8	2		27.50	60		87.50	121
	2870	8"	1 Plum	10	2.400		77	74.50		151.50	198
	2980	45° elbow, 1/2"		22	.364		.37	12.10		12.47	18.70
	2990	3/4"		21	.381		.57	12.65		13.22	19.80
	3000	1"		18	.444		.68	14.80		15.48	23.50
	3010	1-1/4"		17	.471		.96	15.65		16.61	24.50
	3020	1-1/2"	Q-1	16	.500		1.20	16.65		17.85	26.50
	3030	2"		28	.571		1.57	17.10		18.67	27.50
	3040	2-1/2"		22	.727		4.07	22		26.07	37
	3050	3"		17	.941		6.30	28		34.30	49.50
	3060	4"		14	1.143		11.35	34		45.35	64.50

5100 | Building Services Piping

08 | Plastic Pipe & Fittings

		CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
						MAT.	LABOR	EQUIP.	TOTAL		
10	5"	Q-1	12	1.333	Ea.	22.50	40		62.50	85	560
10	6"	↓	8	2		28	60		88	122	
20	8"	Q-2	10	2.400		93	74.50		167.50	215	
20	Tee, 1/2"	1 Plum	14	.571		.28	19		19.28	29	
30	3/4"	↓	13	.615		.32	20.50		20.82	31.50	
30	1"	↓	12	.667		.59	22		22.59	34	
40	1-1/4"	↓	11	.727		.94	24		24.94	37.50	
40	1-1/2"	↓	10	.800		1.13	26.50		27.63	41	
50	2"	Q-1	17	.941		1.65	28		29.65	44.50	
50	2-1/2"	↓	14	1.143		5.45	34		39.45	58	
60	3"	↓	11	1.455		7.15	43.50		50.65	74	
60	4"	↓	9	1.778		12.90	53		65.90	94.50	
70	5"	↓	8	2		31	60		91	125	
70	6"	↓	5	3.200		43.50	96		139.50	193	
80	8"	Q-2	6	4		53	124		177	246	
80	Coupling, 1/2"	1 Plum	22	.364		.18	12.10		12.28	18.50	
90	3/4"	↓	21	.381		.24	12.65		12.89	19.40	
90	1"	↓	18	.444		.41	14.80		15.21	23	
100	1-1/4"	↓	17	.471		.57	15.65		16.22	24	
100	1-1/2"	↓	16	.500		.61	16.65		17.26	25.50	
110	2"	Q-1	28	.571		.95	17.10		18.05	27	
110	2-1/2"	↓	20	.800		2.08	24		26.08	38.50	
120	3"	↓	19	.842		3.27	25		28.27	41.50	
120	4"	↓	16	1		4.72	30		34.72	50.50	
130	5"	↓	14	1.143		8.65	34		42.65	61.50	
130	6"	↓	12	1.333		14.90	40		54.90	77	
140	8"	Q-2	14	1.714	↓	28	53		81	111	
140	Reducing insert, schedule 40, socket weld										
150	3/4"	1 Plum	20	.400	Ea.	.70	13.30		14	21	
150	1"	↓	18	.444		1.19	14.80		15.99	24	
160	1-1/2"	↓	16	.500		1.25	16.65		17.90	26.50	
160	2"	Q-1	31	.516		1.59	15.45		17.04	25.50	
170	4"	↓	22	.727		7.05	22		29.05	41	
170	6"	↓	14	1.143		17.45	34		51.45	71	
180	8"	Q-2	18	1.333	↓	61	41.50		102.50	130	
180	Reducing insert, socket weld x female/male thread										
190	1/2"	1 Plum	24	.333	Ea.	1.41	11.10		12.51	18.30	
190	3/4"	↓	23	.348		.87	11.55		12.42	18.45	
200	1"	↓	20	.400		1.22	13.30		14.52	21.50	
200	1-1/2"	↓	16	.500		2.20	16.65		18.85	27.50	
210	2"	Q-1	26	.615		1.17	18.40		19.57	29.50	
210	4"	"	14	1.143	↓	4.61	34		38.61	57	
220	Male adapter, socket weld x male thread										
230	1/2"	1 Plum	24	.333	Ea.	.27	11.10		11.37	17.05	
230	3/4"	↓	23	.348		.30	11.55		11.85	17.85	
240	1"	↓	20	.400		.53	13.30		13.83	20.50	
240	1-1/2"	↓	16	.500		.87	16.65		17.52	26	
250	2"	Q-1	26	.615		1.14	18.40		19.54	29.50	
260	4"	"	14	1.143	↓	6.30	34		40.30	59	
260	Female adapter, socket weld x female thread										
270	1/2"	1 Plum	24	.333	Ea.	.33	11.10		11.43	17.10	
270	3/4"	↓	23	.348		.42	11.55		11.97	17.95	
280	1"	↓	20	.400		.49	13.30		13.79	20.50	
280	1-1/2"	↓	16	.500		.87	16.65		17.52	26	
290	2"	Q-1	26	.615		1.17	18.40		19.57	29.50	
290	4"	"	14	1.143	↓	6.60	34		40.60	59.50	

15100 | Building Services Piping

15108 | Plastic Pipe & Fittings

		CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
560	3800									
	3810									
	3812	1 Plum	23	.348	Ea.	.67	11.55		12.22	11
	3813	1"	20	.400		1.91	13.30		15.21	22
	3815	1-1/2"	16	.500		4.09	16.65		20.74	29.50
	3816	2"	28	.571		5.35	17.10		22.45	32
	3817	4"	16	1		22	30		52	70
	3818	6"	12	1.333		31	40		71	94.50
	3819	8"	14	1.714		22.50	53		75.50	106
	3830									
	3832	1 Plum	24	.333	Ea.	1.78	11.10		12.88	18.70
	3833	3/4"	23	.348		1.11	11.55		12.66	18.70
	3834	1"	20	.400		1.92	13.30		15.22	22
	3836	1-1/2"	16	.500		3.22	16.65		19.87	28.50
	3837	2"	28	.571		4.66	17.10		21.76	31
	3838	4"	16	1		41	30		71	91
	3844									
	3846	1 Plum	24	.333	Ea.	1.01	11.10		12.11	17.85
	3847	3/4"	23	.348		1.11	11.55		12.66	18.70
	3848	1"	20	.400		1.92	13.30		15.22	22
	3850	1-1/2"	16	.500		3.22	16.65		19.87	28.50
	3851	2"	28	.571		4.66	17.10		21.76	31
	3852	4"	16	1		10.45	30		40.45	57
	3860									
	3862	1 Plum	24	.333	Ea.	.81	11.10		11.91	17.65
	3863	3/4"	23	.348		2.88	11.55		14.43	20.50
	3864	1"	20	.400		4.25	13.30		17.55	24.50
	3866	1-1/2"	16	.500		8.45	16.65		25.10	32
	3867	2"	28	.571		14.75	17.10		31.85	41
	3868	4"	16	1		45	30		75	95
	3872									
	3874	1 Plum	19	.421	Ea.	4.25	14		18.25	25.50
	3875	3/4"	18	.444		5.40	14.80		20.20	28.50
	3876	1"	15	.533		6.15	17.75		23.90	34
	3878	1-1/2"	13	.615		13.85	20.50		34.35	46.50
	3879	2"	27	.593		18.80	17.75		36.55	47.50
	3888									
	3890	1 Plum	36	.222	Ea.	2.03	7.40		9.43	13.45
	3891	3/4"	34	.235		2.13	7.80		9.93	14.20
	3892	1"	30	.267		3.80	8.85		12.65	17.60
	3894	1-1/2"	26	.308		4.58	10.25		14.83	20.50
	3895	2"	44	.364		9.05	10.90		19.95	26.50
	3896	4"	32	.500		36.50	14.95		51.45	62.50
	3897	6"	24	.667		83	19.95		102.95	122
	3898	8"	28	.857		107	26.50		133.50	157
	4500									
	4540	1 Plum	17	.471	Ea.	.99	15.65		16.64	24.50
	4560	1-1/2"	16	.500		.53	16.65		17.18	25.50
	4570	2"	28	.571		.87	17.10		17.97	27
	4580	3"	17	.941		2.05	28		30.05	45
	4590	4"	14	1.143		3.57	34		37.57	56
	4600	6"	8	2		22.50	60		82.50	116
	4650									
	4800									
	4820	1 Plum	11	.727	Ea.	1.25	24		25.25	35
	4830	1-1/2"	10	.800		.77	26.50		27.27	41

5100 | Building Services Piping

08 | Plastic Pipe & Fittings

		CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
						MAT.	LABOR	EQUIP.	TOTAL		
10	2"	Q-1	17	.941	Ea.	1.10	28		29.10	43.50	560
30	3"		11	1.455		2.79	43.50		46.29	69	
6	4"		9	1.778		6.90	53		59.90	88	
62	Tee, sanitary, reducing, 2" x 1-1/2"		17	.941		1.63	28		29.63	44.50	
64	3" x 2"		11	1.455		2.36	43.50		45.86	68.50	
8	4" x 3"		10	1.600		7.70	48		55.70	81	
1	Combination Y and 1/8 bend										
372	1-1/2"	1 Plum	10	.800	Ea.	2.34	26.50		28.84	42.50	
3	2"	Q-1	17	.941		2.84	28		30.84	45.50	
3	3"		11	1.455		5	43.50		48.50	71.50	
878	4"		9	1.778		9.85	53		62.85	91.50	
800	3" x 1-1/2"		11	1.455		5.85	43.50		49.35	72.50	
3	4" x 3"		10	1.600		8.80	48		56.80	82	
1500	Wye, 1-1/4"	1 Plum	11	.727		1.44	24		25.44	38	
1902	1-1/2"	"	10	.800		1.47	26.50		27.97	41.50	
1	2"	Q-1	17	.941		1.51	28		29.51	44	
4908	3"		11	1.455		3.47	43.50		46.97	70	
4908	4"		9	1.778		8.20	53		61.20	89.50	
4	6"		5	3.200		31	96		127	180	
3	3" x 1-1/2"		11	1.455		3.43	43.50		46.93	70	
4920	4" x 3"		10	1.600		5.70	48		53.70	79	
4072	6" x 4"		6	2.667		25.50	80		105.50	150	
0	Double Wye, 1-1/2"	1 Plum	8	1		3.12	33.50		36.62	54	
2	2"	Q-1	12	1.333		4.01	40		44.01	65	
4934	3"		8	2		10.35	60		70.35	102	
	4"		6	2.667		21	80		101	144	
	2" x 1-1/2"		11	1.455		4.01	43.50		47.51	70.50	
4942	3" x 2"		8	2		7.70	60		67.70	99	
4944	4" x 3"		7	2.286		16.65	68.50		85.15	122	
46	6" x 4"		5	3.200		34.50	96		130.50	183	
50	Reducer bushing, 2" x 1-1/2"		30	.533		.51	15.95		16.46	24.50	
4952	3" x 1-1/2" (3" x 2" 22)		24	.667		1.85	19.95		21.80	32	
54	4" x 2"		20	.800		4.27	24		28.27	40.50	
56	6" x 4"		17	.941		11.40	28		39.40	55	
4960	Couplings, 1-1/2"	1 Plum	16	.500		.56	16.65		17.21	25.50	
4962	2"	Q-1	28	.571		.33	17.10		17.43	26.50	
4963	3"		22	.727		1.15	22		23.15	34.50	
4964	4"		17	.941		1.77	28		29.77	44.50	
4966	6"		12	1.333		11.85	40		51.85	73.50	
4970	2" x 1-1/2"		30	.533		.34	15.95		16.29	24.50	
4972	3" x 1-1/2"		24	.667		1.15	19.95		21.10	31.50	
4974	4" x 3"		19	.842		4.53	25		29.53	43	
4978	Closet flange, 4"	1 Plum	32	.250		4.69	8.30		12.99	17.70	
4980	4" x 3"	"	34	.235		4.02	7.80		11.82	16.25	
4980	DWV, PVC, schedule 40, socket joints										
4980	1/4 bend, 1-1/4"	1 Plum	17	.471	Ea.	.93	15.65		16.58	24.50	
4980	1-1/2"	"	16	.500		.41	16.65		17.06	25.50	
4980	2"	Q-1	28	.571		.63	17.10		17.73	26.50	
4980	3"		17	.941		1.57	28		29.57	44	
4980	4"		14	1.143		2.82	34		36.82	55	
4980	6"		8	2		17.15	60		77.15	109	
4980	8"	Q-2	10	2.400		34.50	74.50		109	151	
4980	10"	"	7	3.429		37.50	106		143.50	202	
4980	1/4 bend, long sweep, 1-1/2"	1 Plum	16	.500		1.28	16.65		17.93	26.50	
4980	2"	Q-1	28	.571		1.05	17.10		18.15	27	
4980	3"		17	.941		2.73	28		30.73	45.50	

15100 | Building Services Piping

560	15108 Plastic Pipe & Fittings	CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
5116	4"	Q-1	14	1.143	Ea.	5.40	34		39.40	58
5150	1/8 bend, 1-1/4"	1 Plum	17	.471		.82	15.65		16.47	24.50
5170	1-1/2"	"	16	.500		.46	16.65		17.11	25.50
5180	2"	Q-1	28	.571		.66	17.10		17.76	26.50
5190	3"		17	.941		1.35	28		29.35	44
5200	4"		14	1.143		2.25	34		36.25	54.50
5210	6"	↓	8	2		15.70	60		75.70	108
5215	8"	Q-2	10	2.400		41	74.50		115.50	158
5216	10"	↓	7	3.429		62	106		168	230
5217	12"	↓	6	4		99.50	124		223.50	297
5250	Tee, sanitary 1-1/4"	1 Plum	11	.727		1.45	24		25.45	38
5254	1-1/2"	"	10	.800		.61	26.50		27.11	40.50
5255	2"	Q-1	17	.941		.83	28		28.83	43.50
5256	3"	↓	11	1.455		2.29	43.50		45.79	68.50
5257	4"	↓	9	1.778		4.38	53		57.38	85.50
5259	6"	↓	5	3.200		25.50	96		121.50	173
5261	8"	Q-2	6	4		76	124		200	272
5264	2" x 1-1/2"	Q-1	17	.941		2.05	28		30.05	45
5266	3" x 1-1/2"	↓	12	1.333		1.76	40		41.76	62.50
5268	4" x 3"	↓	12	1.333		8.05	40		48.05	69.50
5271	6" x 4"	↓	8	2	↓	25	60		85	118
5276	Tee, sanitary, reducing									
5281	2" x 1-1/2" x 1-1/2"	Q-1	17	.941	Ea.	.87	28		28.87	43.50
5282	2" x 1-1/2" x 2"	↓	17	.941		1.63	28		29.63	44.50
5283	2" x 2" x 1-1/2"	↓	16	1		1.03	30		31.03	46.50
5284	3" x 3" x 1-1/2"	↓	12	1.333		2.13	40		42.13	63
5285	3" x 3" x 2"	↓	11	1.455		2.36	43.50		45.86	68.50
5286	4" x 4" x 1-1/2"	↓	11	1.455		6.15	43.50		49.65	73
5287	4" x 4" x 2"	↓	10	1.600		5.90	48		53.90	79
5288	4" x 4" x 3"	↓	9	1.778		8.05	53		61.05	89.50
5291	6" x 6" x 4" <i>6" x 3" 7</i>	↓	6	2.667	↓	24.50	80		104.50	148
5294	Tee, double sanitary									
5295	1-1/2"	1 Plum	8	1	Ea.	1.57	33.50		35.07	52
5296	2"	Q-1	12	1.333		2.66	40		42.66	63.50
5297	3"	↓	8	2	↓	7.45	60		67.45	99.50
5298	4"	↓	6	2.667	↓	12	80		92	134
5303	Wye, reducing									
5304	2" x 1-1/2" x 1-1/2"	Q-1	17	.941	Ea.	2.25	28		30.25	45
5305	2" x 2" x 1-1/2"	↓	15	1.067		2.13	32		34.13	51
5306	3" x 3" x 2"	↓	12	1.333		4.40	40		44.40	65.50
5307	4" x 4" x 2"	↓	11	1.455		4.10	43.50		47.60	70.50
5309	4" x 4" x 3"	↓	10	1.600		4.79	48		52.79	78
5314	Combination Y & 1/8 bend, 1-1/2"	1 Plum	10	.800		1.88	26.50		28.38	42
5315	2"	Q-1	17	.941		2.50	28		30.50	45.50
5317	3"	↓	11	1.455		4.12	43.50		47.62	70.50
5318	4"	↓	9	1.778		8.10	53		61.10	89.50
5319	6"	↓	5	3.200		62.50	96		158.50	214
5320	8"	Q-2	6	4	↓	100	124		224	298
5324	Combination Y & 1/8 bend, reducing									
5325	2" x 2" x 1-1/2"	Q-1	17	.941	Ea.	3.64	28		31.64	46.50
5327	3" x 3" x 1-1/2"	↓	13	1.231		4.80	37		41.80	61.50
5328	3" x 3" x 2"	↓	12	1.333		3.01	40		43.01	64
5329	4" x 4" x 2"	↓	11	1.455		6.70	43.50		50.20	73.50
5331	Wye, 1-1/4"	1 Plum	11	.727		1.39	24		25.39	38
5332	1-1/2"	"	10	.800	↓	1.21	26.50		27.71	41.50
5333	2"	Q-1	17	.941	↓	1.21	28		29.21	44

100 | Building Services Piping

108 | Plastic Pipe & Fittings

	CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
					MAT.	LABOR	EQUIP.	TOTAL	
335 3"	Q-1	11	1.455	Ea.	2.79	43.50		46.29	69
4"	↓	9	1.778		5.10	53		58.10	86
6"	↓	5	3.200		33	96		129	182
8"	Q-2	5	4.800		37.50	149		186.50	267
338 10"	↓	4	6		58.50	186		244.50	345
12"	↓	3	8		86.50	248		334.50	470
342 2" x 1-1/2"	Q-1	17	.941		2.13	28		30.13	45
3" x 1-1/2"	↓	12	1.333		2.82	40		42.82	63.50
343 4" x 3"	↓	10	1.600		4.79	48		52.79	78
6" x 4"	↓	6	2.667		18.80	80		98.80	142
8" x 6"	Q-2	8	3		45	93		138	191
347 Double wye, 1-1/2"	1 Plum	8	1		2.57	33.50		36.07	53.50
2"	Q-1	12	1.333		3.30	40		43.30	64
3"	↓	8	2		8.50	60		68.50	100
350 4"	↓	6	2.667		17.25	80		97.25	140
2" x 1-1/2"	↓	11	1.455		3.02	43.50		46.52	69.50
3" x 2"	↓	8	2		6.35	60		66.35	97.50
4" x 3"	↓	7	2.286		13.70	68.50		82.20	119
357 6" x 4"	↓	5	3.200		28.50	96		124.50	177
Coupling, 1-1/4"	1 Plum	17	.471		.78	15.65		16.43	24.50
1-1/2"	↓	16	.500		.26	16.65		16.91	25.50
378 2"	Q-1	28	.571		.27	17.10		17.37	26.50
3"	↓	22	.727		.78	22		22.78	34
4"	↓	17	.941		1.28	28		29.28	44
6"	↓	12	1.333		6.85	40		46.85	68
402 8"	Q-2	14	1.714		15.45	53		68.45	97.50
2" x 1-1/2"	Q-1	30	.533		.68	15.95		16.63	25
3" x 1-1/2"	↓	25	.640		2.15	19.15		21.30	31.50
4" x 3"	↓	18	.889		3.73	26.50		30.23	44.50
Reducer bushing, 2" x 1-1/4"	↓	31	.516		.46	15.45		15.91	24
2" x 1-1/2"	↓	30	.533		.46	15.95		16.41	24.50
412 3" x 1-1/2"	↓	25	.640		2.01	19.15		21.16	31
3" x 2"	↓	24	.667		.93	19.95		20.88	31
4" x 2"	↓	22	.727		3.51	22		25.51	37
4" x 3"	↓	20	.800		1.94	24		25.94	38
416 6" x 4"	↓	14	1.143		10.05	34		44.05	63
8" x 6"	Q-2	18	1.333		20	41.50		61.50	84.50
Closet flange 4"	Q-1	32	.500		4.73	14.95		19.68	27.50
26 4" x 3"	↓	34	.471	↓	3.55	14.10		17.65	25.50
Solvent cement for PVC, industrial grade, per quart				Qt.	10.80			10.80	11.90
CPVC, Schedule 80, threaded joints									
90° Elbow, 1/4"	1 Plum	20	.400	Ea.	5.35	13.30		18.65	26
1/2"	↓	18	.444		2.09	14.80		16.89	25
3/4"	↓	17	.471		2.67	15.65		18.32	26.50
1"	↓	15	.533		4.24	17.75		21.99	31.50
1-1/4"	↓	14	.571		9.20	19		28.20	38.50
1-1/2"	↓	13	.615		10.25	20.50		30.75	42.50
2"	Q-1	22	.727		12.40	22		34.40	46.50
2-1/2"	↓	18	.889		28.50	26.50		55	72
3"	↓	14	1.143		32	34		66	87.50
4"	↓	12	1.333		58	40		98	125
6"	↓	7	2.286	↓	117	68.50		185.50	232
45° Elbow same as 90° Elbow									
Tee, 1/4"	1 Plum	14	.571	Ea.	6.55	19		25.55	35.50
1/2"	↓	12	.667		6.55	22		28.55	40.50
3/4"	↓	11	.727	↓	6.65	24		30.65	44

15100 | Building Services Piping

TFS MECHANICAL

15108 Plastic Pipe & Fittings					2000 BARE COSTS				TOTAL
	CREW	DAILY OUTPUT	LABOR HOURS	UNIT	MAT.	LABOR	EQUIP.	TOTAL	INCL. O.P.
5890	1 Plum	10	.800	Ea.	8.15	26.50		34.65	49
5900		9	.889		12.90	29.50		42.40	58
5910		8	1		14.80	33.50		48.30	67
5920	Q-1	14	1.143		16.45	34		50.45	70
5930		12	1.333		42	40		82	107
5940		9	1.778		42	53		95	127
5950		8	2		56	60		116	152
5960		5	3.200		145	96		241	305
6000	1 Plum	20	.400		5.70	13.30		19	26
6020		18	.444		2.21	14.80		17.01	24
6030		17	.471		3.09	15.65		18.74	27
6040		15	.533		4.16	17.75		21.91	31
6050		14	.571		6.25	19		25.25	34
6060		13	.615		7.85	20.50		28.35	39
6070	Q-1	22	.727		9.15	22		31.15	43
6080		20	.800		20.50	24		44.50	54
6090		19	.842		22	25		47	62
6100		16	1		29	30		59	77
6110		12	1.333		68	40		108	136
6120	Q-2	14	1.714		126	53		179	220
6200	1 Plum	20	.400	Ea.	.07	13.30		13.37	20
6230		19	.421		.16	14		14.16	21
6250		16	.500		.52	16.65		17.17	25
6251		15	.533		.89	17.75		18.64	28
6252		14	.571		1.43	19		20.43	30
6253	Q-1	23	.696		3.08	21		24.08	35
6254	1 Plum	20	.400		.12	13.30		13.42	20
6260		19	.421		.18	14		14.18	21
6280		16	.500		.48	16.65		17.13	25
6281		15	.533		.94	17.75		18.69	28
6282		14	.571		1.49	19		20.49	30
6283	Q-1	23	.696		3.14	21		24.14	35
6284	1 Plum	13	.615		.10	20.50		20.60	31
6290		12	.667		.23	22		22.23	34
6310		11	.727		1.18	24		25.18	38
6311		10	.800		1.80	26.50		28.30	42
6312		10	.800		2.34	26.50		28.84	42
6313	Q-1	17	.941		3.80	28		31.80	46
6314	1 Plum	22	.364		.09	12.10		12.19	18
6320		21	.381		.10	12.65		12.75	19
6340		18	.444		.45	14.80		15.25	23
6341		17	.471		.56	15.65		16.21	24
6342		16	.500		.79	16.65		17.44	26
6343	Q-1	28	.571		1.58	17.10		18.68	27
6344				Qt.	7.30			7.30	8
6360	Solvent cement for CPVC, commercial grade, per quart								
7990	Polybutyl/polyethyl pipe, for copper fittings see 15107-460-7000								
8000	Compression type, PVC, 160 psi cold water								
8010	1 Plum	21	.381	Ea.	1.90	12.65		14.55	21
8020		18	.444		2.34	14.80		17.14	25
8030		17	.471		3.27	15.65		18.92	27
8040		16	.500		4.50	16.65		21.15	30
8050		15	.533		6.30	17.75		24.05	34
8060		23	.348		3.01	11.55		14.56	21
8070		21	.381		4.50	12.65		17.15	21
8080		20	.400		4.53	13.30		17.83	22








100 | Building Services Piping

3 | Plastic Pipe & Fittings

	CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
					MAT.	LABOR	EQUIP.	TOTAL		
1-1/4" FPT x 1-1/4" CTS	1 Plum	18	.444	Ea.	5.95	14.80		20.75	29	560
1-1/2" FPT x 1-1/2" CTS		16	.500		6.95	16.65		23.60	32.50	
2" FPT x 2" CTS		13	.615		10.30	20.50		30.80	42.50	
Male adapter, 3/4" MPT x 3/4" CTS		23	.348		2.71	11.55		14.26	20.50	
3/4" MPT x 1" CTS		21	.381		3.34	12.65		15.99	23	
1" MPT x 1" CTS		20	.400		3.42	13.30		16.72	24	
1-1/4" MPT x 1-1/4" CTS		18	.444		5.25	14.80		20.05	28.50	
1-1/2" MPT x 1-1/2" CTS		16	.500		6.05	16.65		22.70	31.50	
2" MPT x 2" CTS		13	.615		9.70	20.50		30.20	41.50	
Spigot adapter, 3/4" IPS x 3/4" CTS		23	.348		2.71	11.55		14.26	20.50	
3/4" IPS x 1" CTS		21	.381		2.71	12.65		15.36	22	
1" IPS x 1" CTS		20	.400		2.94	13.30		16.24	23	
1-1/4" IPS x 1-1/4" CTS		18	.444		5.25	14.80		20.05	28.50	
1-1/2" IPS x 1-1/2" CTS		16	.500		6.05	16.65		22.70	31.50	
2" IPS x 2" CTS		13	.615		9.70	20.50		30.20	41.50	
Price includes insert stiffeners										
250 psi is same price as 160 psi										
Insert type, nylon, 160 & 250 psi, cold water										
Clamp ring stainless steel, 3/4" IPS	1 Plum	115	.070	Ea.	.62	2.31		2.93	4.18	
1" IPS		107	.075		.63	2.49		3.12	4.45	
1-1/4" IPS		101	.079		.63	2.63		3.26	4.67	
1-1/2" IPS		95	.084		.64	2.80		3.44	4.94	
2" IPS		85	.094		.64	3.13		3.77	5.45	
Coupling, 3/4" IPS		22	.364		.56	12.10		12.66	18.90	
1-1/4" IPS		18	.444		1.34	14.80		16.14	24	
1-1/2" IPS		17	.471		1.74	15.65		17.39	25.50	
2" IPS		16	.500		2.09	16.65		18.74	27.50	
Elbow, 90°, 3/4" IPS		22	.364		.82	12.10		12.92	19.20	
1" IPS		19	.421		.90	14		14.90	22	
1-1/4" IPS		18	.444		1.01	14.80		15.81	23.50	
1-1/2" IPS		17	.471		1.19	15.65		16.84	25	
2" IPS		16	.500		1.67	16.65		18.32	27	
Male adapter, 3/4" IPS x 3/4" MPT		25	.320		.57	10.65		11.22	16.75	
1" IPS x 1" MPT		21	.381		.74	12.65		13.39	19.95	
1-1/4" IPS x 1-1/4" MPT		20	.400		1.23	13.30		14.53	21.50	
1-1/2" IPS x 1-1/2" MPT		18	.444		1.63	14.80		16.43	24.50	
2" IPS x 2" MPT		15	.533		2.09	17.75		19.84	29.50	
Tee, 3/4" IPS		14	.571		1.07	19		20.07	29.50	
1" IPS		13	.615		1.75	20.50		22.25	33	
1-1/4" IPS		12	.667		3.14	22		25.14	37	
1-1/2" IPS		11	.727		3.95	24		27.95	41	
2" IPS		10	.800		5.35	26.50		31.85	46	
Insert type, PVC, 100 psi @ 180°F, hot & cold water										
Coupler, male, 3/8" CTS x 3/8" MPT	1 Plum	29	.276	Ea.	.96	9.15		10.11	14.95	
3/8" CTS x 1/2" MPT		28	.286		.96	9.50		10.46	15.40	
1/2" CTS x 1/2" MPT		27	.296		.30	9.85		10.15	15.25	
1/2" CTS x 3/4" MPT		26	.308		.86	10.25		11.11	16.45	
3/4" CTS x 1/2" MPT		25	.320		.86	10.65		11.51	17.05	
3/4" CTS x 3/4" MPT		25	.320		4.11	10.65		14.76	20.50	
Coupling, 3/8" CTS x 1/2" CTS		25	.320		2.15	10.65		12.80	18.45	
1/2" CTS		23	.348		2.50	11.55		14.05	20.50	
1/2" CTS x stub		23	.348		1.96	11.55		13.51	19.65	
3/4" CTS		22	.364		3.96	12.10		16.06	22.50	
Elbow 90°, 3/8" CTS		25	.320		.65	10.65		11.30	16.80	
1/2" CTS		23	.348		.65	11.55		12.20	18.20	
3/4" CTS		22	.364		.82	12.10		12.92	19.20	

15100 | Building Services Piping

15108 | Plastic Pipe & Fittings

15108 Plastic Pipe & Fittings		CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
560	8800	1 Plum	120	.067	Ea.	.11	2.22		2.33	3.47
	8810		117	.068		.12	2.27		2.39	3.51
	8820		115	.070		.15	2.31		2.46	
	8850		17	.471		1.46	15.65		17.11	25
	8860		15	.533		1.25	17.75		19	28.50
	8870		14	.571		1.31	19		20.31	30
	8890		14	.571		1.24	19		20.24	30
	8900		14	.571		1.09	19		20.09	29.50
	8930		17	.471		1.05	15.65		16.70	24.50
	8940		15	.533		1.19	17.75		18.94	28.50
	8950		14	.571		1.29	19		20.29	30
	8960									
	9000									
	9010									
	9020									
	9030		24	.333	Ea.	2.14	11.10		13.24	19.00
	9040		22	.364		2.45	12.10		14.55	21
	9050		21	.381		3.61	12.65		16.26	23
	9060		18	.444		4.61	14.80		19.41	27.50
	9070		26	.308		2.38	10.25		12.63	18.00
	9080		24	.333		2.55	11.10		13.65	19.50
	9090		22	.364		3.01	12.10		15.11	21.00
	9100		21	.381		4.61	12.65		17.26	24
	9110		18	.444		5.80	14.80		20.60	29
	9120		15	.533		2.62	17.75		20.37	30
	9130		14	.571		3.44	19		22.44	32.50
	9140		13	.615		5.25	20.50		25.75	37
	9150		12	.667		7	22		29	41
	9550									
	9560									
590	0010	PIPE, HIGH DENSITY POLYETHYLENE PLASTIC (HDPE)								
	0020	Not incl. hangers, trenching, backfill, hoisting or digging equipment.								
	0030	Standard length is 40', add a weld for each joint.								
	0050	Straight								
	0054	1" diameter DR 11			L.F.	.28			.28	
	0058	1-1/2" diameter DR 11				.62			.62	
	0062	2" diameter DR 11				.79			.79	
	0066	3" diameter DR 11				1.72			1.72	
	0070	3" diameter DR 17				1.15			1.15	
	0074	4" diameter DR 11				2.84			2.84	
	0078	4" diameter DR 17				1.91			1.91	
	0082	6" diameter DR 11				6.15			6.15	
	0086	6" diameter DR 17				4.13			4.13	
	0090	8" diameter DR 11				10.40			10.40	
	0094	8" diameter DR 26				4.69			4.69	
	0098	10" diameter DR 11				16.20			16.20	
	0102	10" diameter DR 26				7.25			7.25	
	0106	12" diameter DR 11				23			23	
	0110	12" diameter DR 26				10.25			10.25	
	0114	16" diameter DR 11				34			34	
	0118	16" diameter DR 26				15.20			15.20	
	0122	18" diameter DR 11				43			43	
	0126	18" diameter DR 26				19.20			19.20	
	0130	20" diameter DR 11				53			53	
	0134	20" diameter DR 26				23.50			23.50	
	0138	22" diameter DR 11				64			64	
	0142	22" diameter DR 26				28.50			28.50	
	0146	24" diameter DR 11				76			76	

100 | Building Services Piping

10 | Valves

	CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
					MAT.	LABOR	EQUIP.	TOTAL		
1-1/2" size	1 Stpl	11	.727	Ea.	274	24.50		298.50	335	400
2" size	"	8	1	"	330	33.50		363.50	415	
2-1/2" size	Q-5	5	3.200	"	360	96.50		456.50	540	
3" size	"	4.50	3.556	↓	380	107		487	580	
Flanged										
3" size	Q-5	4.20	3.810	Ea.	415	115		530	630	
4" size	"	3	5.333	"	835	161		996	1,175	
5" size	Q-6	3.80	6.316	"	990	197		1,187	1,400	
6" size	"	3	8	"	1,200	250		1,450	1,700	
8" size	"	2.50	9.600	"	1,775	300		2,075	2,400	
10" size	"	2.20	10.909	"	2,525	340		2,865	3,300	
12" size	"	2.10	11.429	"	7,075	355		7,430	8,350	
14" size	↓	2	12	↓	10,100	375		10,475	11,700	

VALVES, PLASTIC

R15100
-090

Angle, PVC, threaded										500
1/4" size	1 Plum	26	.308	Ea.	47.50	10.25		57.75	67.50	
1/2" size	"	26	.308	"	47.50	10.25		57.75	67.50	
3/4" size	"	25	.320	"	55.50	10.65		66.15	77	
1" size	↓	23	.348	↓	66.50	11.55		78.05	90.50	
Ball, PVC, socket or threaded, single union										
1/4" size	1 Plum	26	.308	Ea.	22	10.25		32.25	39.50	
3/8" size	"	26	.308	"	22	10.25		32.25	39.50	
1/2" size	"	26	.308	"	22	10.25		32.25	39.50	
3/4" size	"	25	.320	"	26.50	10.65		37.15	45	
1" size	"	23	.348	"	31	11.55		42.55	51.50	
1-1/4" size	"	21	.381	"	41.50	12.65		54.15	65	
1-1/2" size	"	20	.400	"	52	13.30		65.30	77	
2" size	↓	17	.471	"	74.50	15.65		90.15	105	
2-1/2" size	Q-1	26	.615	"	185	18.40		203.40	232	
3" size	"	24	.667	"	185	19.95		204.95	234	
4" size	↓	20	.800	"	320	24		344	385	
For PVC, flanged, add					100%	15%				
Double union 1/2" size	1 Plum	26	.308	"	25	10.25		35.25	43	
3/4" size	"	25	.320	"	28	10.65		38.65	46.50	
1" size	"	23	.348	"	35	11.55		46.55	56	
1-1/4" size	"	21	.381	"	58	12.65		70.65	83	
1-1/2" size	"	20	.400	"	58	13.30		71.30	84	
2" size	↓	17	.471	↓	79.50	15.65		95.15	111	
CPVC, socket or threaded, single union										
1/2" size	1 Plum	26	.308	Ea.	36.50	10.25		46.75	55.50	
3/4" size	"	25	.320	"	43.50	10.65		54.15	63.50	
1" size	"	23	.348	"	51	11.55		62.55	73.50	
1-1/4" size	"	21	.381	"	88	12.65		100.65	116	
1-1/2" size	"	20	.400	"	88	13.30		101.30	117	
2" size	↓	17	.471	"	118	15.65		133.65	154	
3" size	Q-1	24	.667	"	248	19.95		267.95	305	
For CPVC, flanged, add					65%	15%				
For true union, socket or threaded, add				↓	50%	5%				
Polypropylene, threaded										
1/4" size	1 Plum	26	.308	Ea.	30	10.25		40.25	48.50	
3/8" size	"	26	.308	"	30	10.25		40.25	48.50	
1/2" size	"	26	.308	"	30	10.25		40.25	48.50	
3/4" size	"	25	.320	"	37.50	10.65		48.15	57	
1" size	"	23	.348	"	44.50	11.55		56.05	66.50	
1-1/4" size	"	21	.381	↓	64.50	12.65		77.15	90	

15100 | Building Services Piping

500	15110 Valves	CREW	DAILY OUTPUT	LABOR HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P
						MAT.	LABOR	EQUIP.	TOTAL	
2170	1-1/2" size	1 Plum	20	.400	Ea.	74	13.30		87.30	102
2180	2" size	↓	17	.471	↓	101	15.65		116.65	135
2190	3" size	Q-1	24	.667	↓	266	19.95		285.95	325
2200	4" size	"	20	.800	↓	445	24		469	525
2550	PVC, three way, socket or threaded									
2600	1/2" size	1 Plum	26	.308	Ea.	56.50	10.25		66.75	77.50
2640	3/4" size	↓	25	.320	↓	64	10.65		74.65	86.50
2650	1" size	↓	23	.348	↓	69.50	11.55		81.05	94
2660	1-1/2" size	↓	20	.400	↓	140	13.30		153.30	174
2670	2" size	↓	17	.471	↓	188	15.65		203.65	231
2680	3" size	Q-1	24	.667	↓	455	19.95		474.95	530
2740	For flanged, add				↓	60%	15%			
3150	Ball check, PVC, socket or threaded									
3200	1/4" size	1 Plum	26	.308	Ea.	25	10.25		35.25	43
3220	3/8" size	↓	26	.308	↓	25	10.25		35.25	43
3240	1/2" size	↓	26	.308	↓	25	10.25		35.25	43
3250	3/4" size	↓	25	.320	↓	28	10.65		38.65	46.50
3260	1" size	↓	23	.348	↓	35	11.55		46.55	56
3270	1-1/4" size	↓	21	.381	↓	58	12.65		70.65	83
3280	1-1/2" size	↓	20	.400	↓	58	13.30		71.30	84
3290	2" size	↓	17	.471	↓	79	15.65		94.65	111
3310	3" size	Q-1	24	.667	↓	183	19.95		202.95	231
3320	4" size	"	20	.800	↓	259	24		283	320
3360	For PVC, flanged, add				↓	50%	15%			
3750	CPVC, socket or threaded									
3800	1/2" size	1 Plum	26	.308	Ea.	36.50	10.25		46.75	55.50
3840	3/4" size	↓	25	.320	↓	43.50	10.65		54.15	63.50
3850	1" size	↓	23	.348	↓	51	11.55		62.55	73.5
3860	1-1/2" size	↓	20	.400	↓	88	13.30		101.30	117
3870	2" size	↓	17	.471	↓	118	15.65		133.65	154
3880	3" size	Q-1	24	.667	↓	249	19.95		268.95	305
3920	4" size	"	20	.800	↓	335	24		359	400
3930	For CPVC, flanged, add				↓	40%	15%			
4340	Polypropylene, threaded									
4360	1/2" size	1 Plum	26	.308	Ea.	25	10.25		35.25	43
4400	3/4" size	↓	25	.320	↓	29	10.65		39.65	48
4440	1" size	↓	23	.348	↓	37.50	11.55		49.05	58.50
4450	1-1/2" size	↓	20	.400	↓	72.50	13.30		85.80	100
4460	2" size	↓	17	.471	↓	91	15.65		106.65	124
4500	For polypropylene flanged, add				↓	200%	15%			
4850	Foot valve, PVC, socket or threaded									
4900	1/2" size	1 Plum	34	.235	Ea.	36.50	7.80		44.30	52
4930	3/4" size	↓	32	.250	↓	41.50	8.30		49.80	58
4940	1" size	↓	28	.286	↓	54	9.50		63.50	74
4950	1-1/4" size	↓	27	.296	↓	104	9.85		113.85	129
4960	1-1/2" size	↓	26	.308	↓	104	10.25		114.25	130
4970	2" size	↓	24	.333	↓	120	11.10		131.10	149
4980	3" size	↓	20	.400	↓	287	13.30		300.30	335
4990	4" size	↓	18	.444	↓	505	14.80		519.80	580
5000	For flanged, add				↓	25%	10%			
5050	CPVC, socket or threaded									
5060	1/2" size	1 Plum	34	.235	Ea.	64.50	7.80		72.30	83
5070	3/4" size	↓	32	.250	↓	78	8.30		86.30	98.50
5080	1" size	↓	28	.286	↓	92	9.50		101.50	115
5090	1-1/4" size	↓	27	.296	↓	129	9.85		138.85	157
5100	1-1/2" size	↓	26	.308	↓	150	10.25		160.25	181



MECHANICAL

15100 | Building Services Piping

15100 | Valves

		CREW	DAILY OUTPUT	LABOR- HOURS	UNIT	2000 BARE COSTS				TOTAL INCL O&P	
						MAT.	LABOR	EQUIP.	TOTAL		
10	2" size	1 Plum	24	.333	Ea.	193	11.10		204.10	230	500
120	3" size		20	.400		365	13.30		378.30	420	
130	4" size		18	.444		790	14.80		804.80	890	
40	For flanged, add					25%	10%				
80	Needle valve, PVC, threaded										
400	1/4" size	1 Plum	26	.308	Ea.	32	10.25		42.25	50.50	
40	3/8" size		26	.308		37	10.25		47.25	56	
460	1/2" size		26	.308		37	10.25		47.25	56	
480	For polypropylene, add					10%					
400	Y check, PVC, socket or threaded										
40	1/2" size	1 Plum	26	.308	Ea.	52.50	10.25		62.75	73	
440	3/4" size		25	.320		56.50	10.65		67.15	78	
440	1" size		23	.348		62	11.55		73.55	85.50	
460	1-1/4" size		21	.381		97	12.65		109.65	126	
470	1-1/2" size		20	.400		105	13.30		118.30	136	
490	2" size		17	.471		131	15.65		146.65	169	
490	2-1/2" size		15	.533		277	17.75		294.75	330	
490	3" size	Q-1	24	.667		260	19.95		279.95	315	
490	4" size	"	20	.800		455	24		479	535	
490	For PVC flanged, add					45%	15%				
490	Y sediment strainer, PVC, socket or threaded										
490	1/2" size	1 Plum	26	.308	Ea.	29.50	10.25		39.75	48	
490	3/4" size		24	.333		32	11.10		43.10	52.50	
490	1" size		23	.348		39	11.55		50.55	60.50	
490	1-1/4" size		21	.381		64.50	12.65		77.15	90	
490	1-1/2" size		20	.400		67.50	13.30		80.80	94.50	
490	2" size		17	.471		78.50	15.65		94.15	110	
490	2-1/2" size		15	.533		192	17.75		209.75	238	
490	3" size	Q-1	24	.667		192	19.95		211.95	241	
490	4" size	"	20	.800		320	24		344	385	
490	For PVC, flanged, add					55%	15%				
400	VALVES, SEMI-STEEL										600
	Lubricated plug valve, threaded, 200 psi										
	1/2" pipe size	1 Plum	18	.444	Ea.	61.50	14.80		76.30	90	
	3/4" pipe size		16	.500		61.50	16.65		78.15	92.50	
	1" pipe size		14	.571		79	19		98	116	
	1-1/4" pipe size		12	.667		95	22		117	139	
	1-1/2" pipe size		11	.727		102	24		126	149	
	2" pipe size		8	1		120	33.50		153.50	183	
	2-1/2" pipe size	Q-1	5	3.200		186	96		282	350	
	3" pipe size	"	4.50	3.556		228	106		334	410	
	Flanged, 200 psi										
	2" pipe size	1 Plum	8	1	Ea.	145	33.50		178.50	211	
	2-1/2" pipe size	Q-1	5	3.200		218	96		314	385	
	3" pipe size		4.50	3.556		264	106		370	450	
	4" pipe size		3	5.333		335	160		495	610	
	5" pipe size		2.50	6.400		500	192		692	840	
	6" pipe size	Q-2	3	8		655	248		903	1,100	
	8" pipe size		2.50	9.600		1,125	298		1,423	1,700	
	10" pipe size		2.20	10.909		1,725	340		2,065	2,400	
	12" pipe size		1.70	14.118		2,975	440		3,415	3,925	
400	VALVES, STEEL										700
	Check valve, swing type, 150 lb., flanged										
	2" size	1 Plum	8	1	Ea.	465	33.50		498.50	565	

APPENDIX F



NEWFOUNDLAND AND LABRADOR HYDRO

SCALE: N/A
 DRAWN: S. WHITE
 CHECKED:
 APPROVED:

HINDS LAKE
 LOWER GEN COOLER PIPING


DATE: 19/09/01
 W.O.#
 DWG#

REV.
 0

APPENDIX G


Pressure in PSIA

FINAL




APPENDIX H

HLK



[Previous Page](#)



50 Hz	60 Hz
1480 RPM	1780 RPM
<u>1X1.5-6-Alloy</u>	<u>1X1.5-6-Alloy</u>
<u>1x1.5-6-Iron</u>	<u>1X1.5-6-Iron</u>
<u>1.5X3-6</u>	<u>1.5X3-6</u>
<u>2x3-6-Alloy</u>	<u>2x3-6-Alloy</u>
<u>2x3-6-Iron</u>	<u>2x3-6-Iron</u>
<u>1x1.5-8-Alloy</u>	<u>1x1.5-8-Alloy</u>
<u>1x1.5-8-Iron</u>	<u>1X1.5-8-Iron</u>
<u>1.5X3-8-Alloy</u>	<u>1.5X3-8-Alloy</u>
<u>1.5X3-8-Iron</u>	<u>1.5X3-8-Iron</u>
<u>2X3-8-Alloy</u>	<u>2X3-8-Alloy</u>
<u>2X3-8-Iron</u>	<u>2X3-8-Iron</u>
<u>3x4-7</u>	<u>3x4-7</u>
<u>3X4-8</u>	<u>3X4-8</u>
<u>3X4-8G</u>	<u>3X4-8G</u>
<u>1X2-10-Alloy</u>	<u>1X2-10-Alloy</u>
<u>1X2-10-Iron</u>	<u>1X2-10-Iron</u>
<u>1.5X3-10-Alloy</u>	<u>1.5X3-10-Alloy</u>
<u>1.5X3-10-Iron</u>	<u>1.5X3-10-Iron</u>
<u>2X3-10</u>	<u>2X3-10</u>
<u>3x4-10</u>	<u>3X4-10</u>
<u>3X4-10H</u>	<u>3X4-10H</u>
<u>4X6-10</u>	<u>4X6-10</u>
<u>4X6-10H-Alloy</u>	<u>4x6-10H-Alloy</u>
<u>4x6-10H-Iron</u>	<u>4x6-10H-Iron</u>
<u>4X6-10G</u>	<u>4X6-10G</u>
<u>1.5x3-13-Alloy</u>	<u>1.5x3-13-Alloy</u>
<u>1.5x3-13-Iron</u>	<u>1.5x3-13-Iron</u>
<u>2X3-13</u>	<u>2X3-13</u>
<u>3x4-13</u>	<u>3x4-13</u>
<u>4X6-13</u>	<u>4X6-13</u>
<u>6X8-13</u>	<u>6X8-13</u>
<u>8x10-13</u>	<u>8x10-13</u>
<u>6X8-15</u>	<u>6X8-15</u>
<u>8X10-15</u>	<u>8X10-15G</u>
<u>8X10-15G</u>	<u>8x10-16H</u>

HLK

Goulds Pumps



ITT Industries

CENTRIFUGAL PUMP CHARACTERISTICS

RPM 1750 CDS 2929-5

Model: 3196

Size: 3X4-10H

Imp. Dwg. C00262A

Pattern 58009 / 58434

Eye Area 17.5 in²

