

1 **Re: Page B-117, Replace Diesel Units, \$334,400**

2 Q. How many of the 50 forced system outages over the past five years have
3 been caused by each of the gensets?

4

5

6 A. Unit 561 13 outages

7 Unit 562 11 outages

8 Unit 563 23 outages