

1 **Re: Page B-117, Replace Diesel Units, \$334,400**

2 Q. How many operating hours and overhauls has Unit 567 at Cartwright  
3 experienced?

4

5

6 A. Unit 567 has had only one overhaul to date. As of April, 2007 the unit had  
7 operated approximately 21,500 hours.