

1 **Re: Page B-117, Replace Diesel Units, \$334,400**

2 Q. Will Unit 567 be maintained and reused in the Hydro system after it is
3 replaced?

4

5

6 A. No, this unit would not be maintained and reused in the Hydro system after it
7 is replaced. With its history of unreliability and extended outages, this unit
8 cannot be relied upon to operate as is required in a prime power
9 environment.