PUB NLH 88.0 NLH 2008 Capital Budget

Page 1 of 1

- 1 Re: Page B-142, Replace Fire Alarm System, \$168,000
- Q. What is the age of the fire alarm system at Hopedale? 2

3 4

5 A. The existing equipment is 15 years old.