

1 **Re: Page B-142, Replace Fire Alarm System, \$168,000**

2 Q. At each of the plants described in this project, what method of response is in  
3 place to deal with any fire that triggers the system?

4

5

6 A. As detailed in the project explanation the fire alarm system will automatically  
7 shut the plant down and notify Hydro personnel. At Hopedale, the local  
8 community volunteer fire department would automatically respond to a fire at  
9 the diesel plant. At Paradise River, Hydro personnel would contact the  
10 volunteer fire department in Cartwright who would respond to a fire.