

1 Q. **Re Complete Condition Assessment Phase 2**

2 At page B3 of Tab 5, AMEC indicates that a part of the Level 2 costs pertain to
3 "Hydrogen Storage and Supply". Will this work be required if the Board approves
4 Hydro's Upgrade Hydrogen System at p. B-10?

5

6

7 A. Yes, the Level 2 condition assessment and life extension study pertaining to
8 Hydrogen Storage and Supply will still be required if the Board approves Hydro's
9 Upgrade Hydrogen System at p. B-10. The detailed design requirements to upgrade
10 the hydrogen system are unknown at this time; however, portions of the existing
11 system, located in the generator areas, are expected to remain for continued use.
12 These portions of the existing system will require more detailed Level II
13 investigation as part of the Phase 2 study.