

1 Q. **Re Replace Fuel Storage Facility - Postville (B-45)**

2 P. 6 of the report at Tab 18 refers to s. 27(5). Can Hydro confirm whether the U.L.C.
3 label requirement referred to applies to tanks already in the field as s. 27(5)
4 appears to be referring only to how new tanks which have been constructed and
5 shop tested are to be labeled?

6
7

8 A. Yes, the U.L.C. label requirement applies to tanks already in the field. Section 27.
9 (5) states the tanks must be constructed in accordance with U.L.C. CAN4-S601 and
10 bear a U.L.C. label. The label must remain on the tank for the entire time the tank is
11 in service. Section U.L.C. CAN4-S601, Section 3.16, Marking, states as follows: the
12 nameplate must be permanently attached to the tank. The existing tanks were
13 constructed and shop tested and originally had U.L.C. labels. Since the labels are
14 now missing, the tanks no longer meet the U.L.C. standard.