

1    Q.    **Re 2011 Capital Plan**

2            The 2011 Capital Plan does not contain any projects pertaining to Install Low No x  
3            Burners or Upgrade Soot blowing Controls over the 2011 to 2015 period, both of  
4            which were listed in the 2010 Capital Plan as 2014 Projects. Please explain.

5

6

7    A.    The 2011 Capital Plan does not contain any projects pertaining to Install Low No<sub>x</sub>  
8            Burners or Upgrade Soot Blowing Controls over the 2011 to 2015 period due to the  
9            performance of 0.7% heavy fuel oil which is in compliance with the ambient air  
10           quality standards. These projects are included in the long term capital plan but  
11           contingent on the decision to bring power to the Island from Lower Churchill.