Page 1 of 1

1	Q.	Re 2011 Capital Plan
2		As regards Holyrood soot blowing operations, has the environmental regulator
3		imposed fines or amended Hydro's Certificate of Approval?
4		
5		
6	A.	Though Holyrood Thermal Generating Station NO _x and particulate emissions exceed
7		the 20 tonne annual limit according to Air Pollution Control Regulations, 2004, the
8		Government has not imposed fines or amended Hydro's Certificate of Approval.