

1 Q. **Re 2011 Capital Plan - Individual Capital Projects:**

2 **Project C-44, Install Weatherhoods for Vent Fans-Holyrood:** What quantitative
3 evidence, if any, does Hydro have that air quality inside the plant is being impaired
4 by the backflow?

5

6

7 A. The quantitative evidence available is included in Appendix A to the proposal. This
8 evidence indicates that the design air exhaust flow rate is not being achieved during
9 times of high winds. Air quality inside the plant will be impaired whenever these
10 exhaust fans fail to operate to their design capacities as the concentration of
11 unhealthy gases will increase.