

1 Q. **B-24, Replace Relay Panels Unit 3, 2011 – \$271,100, 2012 –\$553,600**

2 Please provide a detailed description of the condition of the relay panels for Units 1  
3 and 2.

4

5

6 A. Relay panels for Units 1 and 2 are of a different layout and cabinet design than the

7 Unit 3 relay panel. All relays are installed in the back of the cabinets, with

8 associated wiring and terminal blocks below the relays on the same vertical plane.

9 This design allows for the doors of the cabinets to be opened, relays inspected,

10 tested and replaced as necessary with minimal disturbance to the wiring and

11 terminal blocks. The cabinets are in satisfactory condition as compared to Unit 3

12 cabinet (relays installed in doors, terminal blocks in back of cabinets so wiring is

13 disturbed each time doors are opened).