

1 Q. **Re: Unit 1 and Unit 2 Generator Stator Rewind (Tab 2)**

2 At page 21, please provide the basis for assuming a 30 percent risk of stator winding
3 failure and the basis for a 10 percent increase year to year. Have these assumptions
4 taken into account AMEC's recommendation of a "bump" test if no winding takes
5 place? If this bump test was completed, would there be a corresponding reduction
6 in the associated risk of failure on a go-forward basis?

7
8
9 A. The risk values referenced in the question are judgements by an independent
10 consultant AMEC, including input from Robert Jeffries, Generator Specialist
11 contracted by AMEC, to assist in the analysis of the present condition and
12 remaining life of Holyrood Units 1 and 2 stator windings.

13
14 A bump test is an acoustical measurement of the physical response of the stator to
15 a slight tap of the end of stator. It is a non-destructive test used to determine if
16 there are any loose components such as windings or blocking within the stator. A
17 bump test will be carried out on Unit 1 during the 2012 major outage. It should be
18 noted that a bump test and any resulting blocking that may be added will have no
19 effect on the stator winding insulation degradation issues that are the paramount
20 concern. As such, no corresponding reduction in associated risk of stator winding
21 insulation failure would be realized with the completion of this test.