

1 Q. **Re: Project B-5 Unit 1 and Unit 2 Generator Stator Rewind**

2 At page 21 of the July 2011 report supporting this Project, Hydro posits the
3 assumption of a "30 percent risk of stator winding failure in the year after the base
4 case rewind date, and growing by ten percent per year to the year of the stator
5 rewind for the option being considered". What is the source and support for this
6 assumption?

7

8

9 A. Please refer to the response to P2-PUB-NLH-14.