

1 Q. Re: B-12, Install Plant Operator Training Simulator – Holyrood \$1,028,200 in
2 2012 and \$1,072,700 in 2013.

3 In Volume I, Tab 5, page 17, Hydro states that: *“The Board also requires the plant to*
4 *regularly practice black starts.”* Please provide the basis for this statement.

5

6

7 A. Hydro has reviewed its correspondence from the Board, and can find no Order or
8 other specific requirement to regularly practice a black start at Holyrood.

9 Correspondence from the Board related to the restricted use of the gas turbine,

10 following the issuance of stop work orders, demonstrated that the Board had

11 concerns about assuring the continued ability of the gas turbine to fulfill its role in a

12 black start. Hydro shares the view that black start capability is essential to assuring

13 the ready availability of the Holyrood plant when required.