

- 1 Q. **Re: B-23, Upgrade Forced Draft Fan Ductwork Unit 2 - \$928,600 in 2012**
- 2 In Volume II, Tab 8, page 12, in the report *Upgrade Generating Unit 2 Forced Draft*
- 3 *Fan Ductwork*, Hydro states that if there is a failure of the FD fan/ductwork the
- 4 damage could be in the range of \$350,000. Please provide a detailed breakdown of
- 5 this amount.
- 6
- 7
- 8 A. If there is a failure of the FD fan/ductwork the damage could be in the range of
- 9 \$350,000. Table 1 below provides a detailed breakdown of that figure.

Table 1

Item #	Work Description	Cost (\$)
1	Installation work by Boiler Service Contractor	90,000
2	Professional Engineering Services	6,000
3	FD Fan Original Equipment Manufacturer Materials & Services	110,000
4	Civil/Structural Work	27,000
5	Transportation/Shipping	10,000
6	Motor Electrical Repairs	19,000
7	Non Destructive Testing	500
8	Machining	21,000
9	Fall Arrest Rescue	8,000
10	Scaffolding	19,000
11	NL Hydro Labour & Materials	39,000
12	Sandblasting	500
	Total:	350,000