

1 **Q. Re: B-23, Upgrade Forced Draft Fan Ductwork Unit 2 - \$928,600 in 2012**

2 In Volume II, Tab 24, page 12, in the report *Unit 1 Turbine Generator Major*
3 *Overhaul*, Hydro writes that in its 2010 Holyrood Condition Assessment: “...AMEC
4 *concluded that Unit 1 turbine has a reliable remaining life in the order of twenty*
5 *years (to 2020)*”. Please confirm whether 2020 is correct.

6

7

8 **A.** The year 2020 is correct. The AMEC study focuses on the End of Life required for
9 Unit 1 turbine as 2020, i.e. the point at which the turbine will no longer be required
10 to produce electricity. However, “....twenty years.....” is incorrect. Therefore, the
11 wording in Volume II, Tab 24, page 12, in the report *Unit 1 Turbine Generator Major*
12 *Overhaul*, should actually read “...AMEC concluded that Unit 1 turbine has a reliable
13 *remaining life in the order of ten years (to 2020)*”.