

1 Q. Re: Stationary Battery and Charger Replacement Program Volume II (Tab
2 21)

3 Please outline how often Hydro Personnel test the batteries using a conductance
4 tester as referenced on page 7?

5

6

7 A. Hydro personnel test the batteries using a conductance tester every twelve months
8 as part of Hydro's written preventative maintenance procedures. Additional
9 testing is completed as required when there is any concern about the condition of
10 the batteries.