

1 Q. **Project B-25, Replace Emergency Diesel Generator (Bay d'Espoir):** What would be
2 the cost of installing a new 200 kW emergency diesel generator in the existing
3 diesel generating room?

4

5

6 A. The cost of installing a new 200 kW emergency diesel generator in the existing
7 diesel generating room at Bay d'Espoir is estimated to be \$461,400.

8

9 The existing 200 kW backup emergency diesel generating unit installed at Bay
10 d'Espoir is unable to provide sufficient power to the station service panel to meet
11 emergency conditions. The proposed 500 kW unit will provide sufficient and reliable
12 power to meet that demand.