

1    Q.    **B-70, Overhaul Diesel Units, \$974,100**

2            Please provide a listing of the portable diesel units in Hydro's fleet, the ages of the  
3            units, the number of operation hours of each unit as of August 31, 2011, and the  
4            location of each unit.

5

6

7    A.

Unit	Location	Age (years)	Operating Hours
Unit 2003	St. Anthony Diesel Plant	31	57352
Unit 2035	Little Bay Islands Diesel Plant	19	13537
Unit 2044	Port Hope Simpson Diesel Plant	15	64099
Unit 2061	Charlottetown Diesel Plant	11	36466
Unit 2071	Bishop's Falls Regional Office	14	16640
Unit 2072	Bishop's Falls Regional Office	12	21420
Unit 2082	Lance au Loup Diesel Plant	2	3197
Unit 2088	Charlottetown Diesel Plant	0	813
Unit 229	St. Anthony Diesel Plant	31	30158