

1 Q. **Page E-4, Replace Programmable Logic Controllers – Holyrood, \$901,700**

2 Does the manual operation of the make-up air units meet occupational health and
3 safety requirements with regard to ventilation and avoid concerns in relation to the
4 freezing of equipment and losses in boiler efficiency?

5

6

7 A. Yes, the manual operation of the warm air make up units is in compliance with
8 occupational health and safety requirements with regard to ventilation. Hydro does
9 not anticipate any appreciable difference with either freezing of plant equipment,
10 or boiler efficiency with a change from automatic to manual control of the system.