

1 Q. **Page E-4, Replace Programmable Logic Controllers – Holyrood, \$901,700**

2 Is it possible that the mechanical issues with the warm air make-up system that
3 have caused it to be delayed may be resolved in time that it could be included with
4 the replacement of the Programmable Logic Controllers at Holyrood in Phase II of
5 the 2012 Capital Budget?

6

7

8 A. Work to resolve the mechanical issues with the system are underway. We are
9 converting the system to be fully manual, and will not be seeking to automate its
10 control. Accordingly, there is no rationale for including automation in Phase II of
11 the 2012 Capital Budget.