| 1  | Q. | Page E-9, New 25 kV Terminal Station – Labrador City, \$3,507,000                        |
|----|----|--|
| 2  |    | Please provide a detailed explanation of the work that will be undertaken in 2012.       |
| 3  |    |  |
| 4  |    |  |
| 5  | A. | The 2011 work includes the delivery and assembly of the four power transformers;         |
| 6  |    | the installation of the majority of a fibre-optic cable link between the existing        |
| 7  |    | Wabush Terminal Station, new Quartzite Station and new Vanier Station; the               |
| 8  |    | completion of the majority of the civil upgrades to both new stations; the delivery      |
| 9  |    | and installation of the Quartzite terminal station building; and the installation of the |
| 10 |    | Quartzite electrical equipment.  |
| 11 |    |  |
| 12 |    | The 2012 work includes the commissioning of the Quartzite Station; the installation      |
| 13 |    | of the remainder of the fibre-optic cable; the delivery and installation of the Vanier   |
| 14 |    | terminal station building; the installation of the Vanier electrical equipment; the      |
| 15 |    | commissioning of the Vanier Station; and the completion of the remaining civil           |
| 16 |    | upgrades.  |
|    |    |  |